

**BENLO
BENTEC INDIA LIMITED**

Test Certificate

Items Single phase static Wattour Meter
Rating 240Volt/5-30 A /50Hz
Class 1
Meter Constant 3200 Imulse/Kwh
Standard IS13779 : 1999

The meter was tested & has passed following routine test as per
IS : 13779 at reference Condition:

Test	Result
No Load Conditions	Passed
AC Voltage test	Passed
Insulation resistance test	Passed
Starting test	Passed
Meter accuracy test	Passed
	Meter accuracy observed within $\pm 1\%$

Office

150, Upen Banerjee Road ,
Kolkata - 700060 (INDIA)

Certified Signature

Amit Bhattacharya
10/8/2023

Meter Initial Reading: 000001

METER NUMBER	7515030
---------------------	----------------

Mehta
**Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong**

Y. Passah
**(Y. Passah)
Assistant Engineer
MTI Lab
MePDCL, Shillong.**

1000 867 899.

Aitidalyne Kunit

Patarim

DOI 15/11/24

Received on 07/01/25.