



MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED  
 OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER, INVESTIGATION & ENFORCEMENT SUB-DIVISION  
 RIBHOI DISTRIBUTION CIRCLE, UMIAM, Email: aeie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-07/2025-26/705

Dated, Umiam the 20th November, 2025

To,

The Assistant Executive Engineer  
 Umsning Distribution Sub-Division  
 MePDCL, Umsning

METER REPLACEMENT REPORT AT Airtel Tower, Umtrew UNDERTAKEN ON THE 18th November, 2025.

SL. NO	CONSUMER ID.	NAME OF CONSUMER	ADDRESS	CONTRACT DEMAND (KW or KVA)	CATEGORY	M.F	OLD METER NO.	NEW METER NO & SPECIFICATION	DATE OF REPLACEMENT WITH NEW METER	INITIAL READINGS OF NEW METER						Old Seal	New Seal	Remark
										KWH	KVAH	KW	R-N (V)	Y-N (V)	B-N(V)			
1	1000198027	Airtel Tower, Umtrew,	C/O Mrs. Brjita Nongsiej, Umtrew., Umtrew, #31C51	8	CLT	10	MS5000544	MS5001088 Class: 0.5S, -/5A, Ib=5A, Imax=2xIb 3x240V 50Hz 16000Pules/Unit (kWh, kVAh, kVArh) Type: CTSM N5 HPL Electric & Power Ltd make	18-11-2025	3403	3406	0	241	240	242	BOX-22001208 TTB-22001208	BOX-0050495 TTB-22000671/0050497	Old Meter's display found defected and therefore replaced with new meter. Simcard used: AIRTEL SIM No. 0524 ID 89.....002 6471978U H1

20/11/2025

(F.L. KYNSHI)  
 ASSISTANT EXECUTIVE ENGINEER  
 I & E Sub-Division, Ribhoi Distribution Circle  
 MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-07/2025-26/705(a)

Dated, Umiam the 20th November, 2025

Copy to -

1. The Superintending Engineer, Ribhoi (D) Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. The Executive Engineer, Umiam Distribution Division for kind information.
4. The Executive Engineer (HVC), O/o CE (Commercial) for kind information with a request to integrate the new meter with HES/MDM.
6. R/F.

ASSISTANT EXECUTIVE ENGINEER