

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION,
RIBHOI DISTRIBUTION CIRCLE, UMIAM

No. MePDCL /I&E/RBDC/T-07/2024-25/555

Dated Umiam the 27th February, 2025

To,

The Assistant Executive Engineer,
Umiam Rural Distribution Sub-Division
MePDCL, Umiam

Sub: Inspection cum Meter Replacement Report at the metering unit of Madan Sohriman W.S.S, Bhoirymbong (Cons. ID: 1000198339).

Sir,

The office of the undersigned has on the 27.02.2025, inspected the metering unit at the premises of **Madan Sohriman W.S.S, Bhoirymbong (Cons. ID: 1000198339)** and has found the Meter No. 277972 to be defected (no reading could be read). The defected Meter is therefore replaced with an LT-CT HPL Make Smart Meter No.: **MS5001010** and the corresponding Meter Replacement Report is enclosed herewith for your kind perusal. It is to be noted that the new Multiplication Factor (M.F) for this consumer shall be **10**.

This is for your kind information and necessary action.

Yours faithfully,

Encl. Inspection cum Meter Replacement Report.


(Fullmoon L. Kynshi)
Assistant Executive Engineer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-07/2024-25/555(a)

Dated Umiam the 27th February, 2025


Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. The Junior Engineer, Billing Section, Umiam Distribution Division, MePDCL, Umiam for kind information and necessary action to please update the Meter No. of this consumer as stated.
4. R/F.


ASSISTANT EXECUTIVE ENGINEER

INSPECTION CUM METER REPLACEMENT REPORT OF Madan Sohriman W.S.S, BHOIRYMBONG UNDERTAKEN ON THE 27TH FEBRUARY, 2025.

| SL NO | CONSUMER ID. | NAME OF CONSUMER | ADDRESS | CONNECTED LOAD (KW) | DATE OF REPLACEMENT WITH NEW METER | OLD METER NO. | OLD M.F | NEW METER NO & SPECIFICATION | NEW M.F | CATEGORY | INITIAL READINGS OF NEW METER | | | | | | SIM CARD (Service/Sim No.: | | New Seal | Remark |
|-------|--------------|----------------------|------------|---------------------|------------------------------------|---------------|---------|---|---------|----------|-------------------------------|------|----|---------|---------|---------|----------------------------|-----------------------------|-------------------------------------|--|
| | | | | | | | | | | | KWH | KVAH | KW | R-N (V) | Y-N (V) | B-N (V) | | | | |
| 1 | 1000198339 | Madan Sohriman W.S.S | Bhoirybong | 11 | 27.02.2025 | 277972 | 1 | Meter No: MS5001010 Class: 0.5S, -/5A, Ib=5A, Imax=2xIb 3x240V 50Hz 16000Pules/Unit (kWh, kVAh, kVArh) Type: CTSM N5 HPL Electric & Power Ltd make | 10 | WSLT | 0 | 0 | 0 | 244 | 245 | 245 | JIO | 8991 8650 5070 6001 5207 | TTB Seal:11112854 BOX:0052451 | <u>Old meter Defected & replaced with New LT-CT Meter (External CT Ratio: 50/5A)</u> |


 (F. KYNSHI)

ASSISTANT EXECUTIVE ENGINEER
 I & E Sub-Division, Ribhol Distribution Circle
 MePDCL,Umiam