

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER, INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM, Email: aeeie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-07/2025-26/616

Dated, Umiam the 5th June, 2025


To,

The Assistant Executive Engineer
Umsning Distribution Sub-Division
MePDCL, Umsning

METER REPLACEMENT REPORT of Vodafone Essar Spacelet Ltd, Patarim UNDERTAKEN ON THE 5th June, 2025.

SL. NO	CONSUMER ID.	NAME OF CONSUMER	ADDRESS	CONTRACT DEMAND (KW)	CATEGORY	O.M.F	OLD METER NO.	NEW METER NO & SPECIFICATION	DATE OF REPLACEMENT WITH NEW METER	INITIAL READINGS OF NEW METER						Old Seal	New Seal	Remark
										KWH	KVAH	KW	R (V)	Y (V)	B (V)			
1	1000198054	Vodafone Essar Spacelet Ltd.	Patarim	12	CLT	10	MS5002031	Meter No: MS5003532 Class: 0.5S, -/5A, Ib=5A, Imax=2xIb 3x240V 50Hz 16000Pules/Unit (kWh, kVAh, kVArh) Type: CTSM N5 HPL Electric & Power Ltd make	05.06.2025	0	0	0	245	245	245	MTC: NA	BOX- 0054324/326 TTB: 0050459/ 0054329 MT: 0054325	Meter Uses Jlo SIM No-8991 8650 4060 0182 0983

Note: The Old Meter & CTs (R & B Ph CT Rings) were found defected & replaced with new Meter No. above. MF =10 (CTR:50/5A).



(F.L. KYNSHI)
ASSISTANT EXECUTIVE ENGINEER
I & E Sub-Division, Ribhoi Distribution Circle
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-07/2025-26/616(a)

Dated, Umiam the 5th June, 2025

Copy to:-

1. The Superintending Engineer, Ribhoi (D) Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. The Executive Engineer, Umiam Distribution Division for kind information.
4. The Executive Engineer, MTI Division, MePDCL, Shillong for kind information.
5. The Junior Engineer (Central Billing Section), Umiam Distribution Division for kind information and necessary action with a request to update the new Meter No. as stated.
6. R/F.

ASSISTANT EXECUTIVE ENGINEER-A1:X25