

*Fishery Str No 2, Maunpan.
Cons. No: 1000200582
1kW, DLT.

Old Meter No. 11044036 found defected
(partially burnt) and therefore replaced
with new Meter No. 11122176 on 11/10/2025.

SIM card used: (Jio)

899186504060

0069 6475

Rajyada 11/10/25
ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT,
RIBHOI DISTRIBUTION CIRCLE
MEPDCL, UMIAM