

To,
JE (Central Billing Section), UDD

Please cancel the bill No. 223101225A200357 issued
on 20/10/2025 of Melbon Lynshiang,
Cno 20: 1000202869.

1KW, BPL(M).

Mamshut.

Finding: Meter No. 5680263 found defective
(readings move forward without loads).

Replaced with new meter No. 5514531745
on the 20/11/2025.

Initial Reading: 00.00 kWh
00.00 kVAh
00.00 kW.

Ryngdol 29/11/2025
ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT,
RIBHOI DISTRIBUTION CIRCLE
MEPDCL, UMIAH