

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM

No. MePDCL /I&E/RBDC/T-07/2024-25/500
To

Dated, Umiam the 16th October, 2024

The Assistant Executive Engineer
Umiam Urban Distribution Sub-Division
MePDCL, Umiam

Sub: Replacement Report of 11KV CT/PT Unit at the HT-CT Metering Unit of Water Treatment Plant And Pump House, C/o Director NEPA, Umsaw (Cons. Id.: 1000639426) undertaken on the 16.10.2024.

Sir,

With reference to the subject cited above, this is to inform you that the office of the undersigned along with your staffs, has on the 16.10.2024 installed a new 11KV CT/PT Unit at the HT-CT Metering Unit of Water Treatment Plant And Pump House, C/o Director NEPA Umsaw and the metering unit was restored with readings as enclosed in the report.

It is to be noted that only the CT/PT Unit was replaced keeping the same Old Meter No: **MEB97046**, the Multiplication Factor (M.F) of the metering system remains unchanged.

Since, this consumer was last billed on 04.10.2024 on Direct Connection (DC) basis, hencefort, billing may again be done on OK (Normal) basis (based on actual readings) and **6972.40 kVAh (or 6275.16 kWh) of Additional Units** may please be included in the bill cycle of November, 2024 to account for the energy consumption from the last billing date (04.10.2024) up to 16.10.2024 (Meter Restoration Date).

This is for favour of your kind information and necessary action.

Encl. Report.

Yours faithfully,

(Pullmoon L. Kynshi)
Assistant Executive Engineer
Investigation & Enforcement
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-07/2024-25/500(a)

Dated, Umiam the 16th October, 2024

Copy to:-


1. The Superintending Engineer, Ribhoi (D) Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. The Executive Engineer, Umiam Distribution Division, MePDCL, Umiam for kind information.
4. The Executive Engineer, MTI, MePDCL, Shillong for kind information.
5. The Junior Engineer, Central Billing Section, Umiam Distribution Division for kind information and necessary action to bill the consumer as stated above.
6. R/F.

ASSISTANT EXECUTIVE ENGINEER

Replacement Report of 11KV CT/PT Unit at the HT-CT Metering Unit of Water Treatment Plant And Pump House, C/o Director NEPA Umsaw undertaken on the 16.10.2024

Name of Consumer:											Water Treatment Plant And Pump House						
Consumer Id:											1000639426						
Date of Installation of New 11KV CT/PT Unit:											16-10-2024						
Date of Restoration of Metering Unit:											16-10-2024						
Sub-Division:											Umiam Urban Distribution Sub-Division						
Metering Parameters	Specification of Old CT/PT Unit			Specification of new CT/PT Unit			CT Ratio Selected	Meter No. & Specification	Meter Ratio	O.M.F	READINGS (16.10.2024 @14:32 HRS)					Seal Number	Remarks
	Parameter	CT	PT	Parameter	CT	PT					KWH	KVAH	KVA	R-Y (V)	B-Y (V)		
	Serial No.	NA		Serial No.	69219		20/5A	Meter No.: MEB97046	1	400	868.08	980.70	0	108	109	MB/MT/TTB: 4039920/0051674/0 052130	O.M.F=400
	Ratio:	NA	NA	Ratio:	10-20*/5A	11KV/110V		Class: 0.5S, -/5A, Ib=5A, I _{max} =2xIb									
	Burden:	NA	NA	Burden:	15VA	50VA		110V									
	Class	NA	NA	Class	0.5S	0.5		16000Pules/Unit (kWh, kVAh, kVArh, KVA)									
	Freq.	NA	NA	Freq.	50Hz	50Hz		50Hz									
	Make:	NA		Make:	Macroplast Pvt Ltd.			Make: Secure Meters Ltd									
	Type:			Type:	3P 3W			Type: E3V054, 3P 3W									
								Phase Sequence: Forward									

Note: O.M.F: 400 (kWh, kVAh, kVA)


 (F.L. Kynshi)
 Asstt Executive Engineer
 Investigation & Enforcement
 Ribhoi (D) Circle, MePDCL,Umiar