



Me PDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION, RIBHOI (D) CIRCLE
MePDCL, UMIAM

No. MePDCL /I&E/RBDC/T-07/2024-25/514

Dated Umiām the 6th September, 2024

To,

The Assistant Executive Engineer,
Umiām Urban Distribution Sub-Division
MePDCL, Umiām.

Sub: To correct the Multiplication Factor (M.F) of M/S Manson Fruit Product, M.I.D.C.Complex Umiām, (Consumer ID: 1000198283).

Sir,


This is to inform you that the office of the undersigned has on the 23.10.2024 inspected the LT-CT Metering Unit at the premises of **M/S Manson Fruit Product, M.I.D.C.Complex Umiām, (Consumer ID: 1000198283)** and found that R Ph PT supply to meter was missing (corrected) and the CTs used are of ratio 100/5A. However, the **M.F in billing system is 10 which should be 20.** Therefore, correction in Multiplication Factor may please be taken up at your end. Also, to account for the unmetered power consumption in R Ph, **2232.04 kWh (or 2567.41 kVAh)** of Additional Units may please be included in the coming bill cycle of this consumer.

Updation in M.F from 10 to 20 and revision of bills on account of wrong entry of M.F may please be taken up at the most appropriate time to arrest the energy loss.

This is for your kind information and necessary action.

Encl.: CT Replacement & Installation Report.

Yours faithfully,


(Fullmoon L. Kynshi)

Assistant Executive Engineer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiām

No. MePDCL /I&E/RBDC/T-07/2024-25/514(a)

Dated Umiām the 6th September, 2024

Copy to:-

1. The Superintending Engineer, Ribhoi (D) Circle, MePDCL, Umiām for kind information.
2. The Superintending Engineer, I & E, MePDCL, Shillong for kind information.
3. The Executive Engineer, Umiām Distribution Division, MePDCL, Umiām for kind information.
4. The Executive Engineer, MTI Division, MePDCL, Shillong for kind information.
5. R/F.

ASSISTANT EXECUTIVE ENGINEER

INSPECTION REPORT OF LT-CT METERING UNIT AT THE PREMISES OF M/S Manson Fruit Product, M.I.D.C.Complex Umiam CONDUCTED ON THE 23.10.2024.

SL NO	Consumer No	SUPPLY VOLTAGE (KV)	NAME OF CONSUMER	ADDRESS	CT RATIO	O.M.F	METER NO.	CATEGORY	CONTRACT DEMAND (KW)	DATE	TIME	READINGS						SEALS		Remark
												KWH	KVAH	KVA	V1	V2	V3	OLD	NEW	
1	1000198283	11	M/S Manson Fruit Product	M.I.D.C.Co mplex Umiam	100/5	20	MS5004337	ILT	39	23.10.2024	16:48	994.47	1169.53	1.54	0	243	242	TTB:0051314 Box:0051718/11 102329	TTB:4055178 Box: 0051527	R Ph PT supply <u>missing</u> <u>(corrected)</u> .


Note: (1) Attention may kindly be paid to the underline bolted remarks.

(2) Cells which are left blank indicate either "No Data Available" or "Not Applicable" during inspection.

F.L. Kynshi
6/11/24

F.L. Kynshi
Asstt Executive Engineer
Investigation & Enforcement Sub Division
MePDCL,Umiam.

Energy Consumption Statement					
Consumer ID/ Account No. 1000198283					
Consumer's Name : M/S Manson Fruit Product					
Meter Readings for New Meter ID: MS5004337 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	Kvah Meter	Recorded Demand	Recorded PF
Current Reading	11-10-2024	928.68	1094.12	1.54	0
Previous Reading	21-09-2024	837.5	989.24		
No Of Days	20				
Difference		91.18	104.88		
Multiplying Factor		10	10	10	
Net Consumption (R Ph PT missing)		911.8	1048.8	15.4	0.87
Net Consumption calculated (R, Y & B Ph)		1367.7	1573.2		
Additional Unit to be included*		2232.04	2567.41		
(A). Average Per Day Consumption with normal PT supply (in kVAh)					78.66
R Ph PT Missing Date (estimated)					18-07-2024
kVAh on 18-07-2024					663.269
R Ph PT Correction Date					23-10-2024
kVAh on 23-10-2024					1169.53
No. of days between 18-07-2024 & 23-10-2024					97
(B). Actual Consumption between 18-07-202 & 23-10-2024 (kVAh) with Y & B Ph only					5062.61
©. Consumption between 18-07-202 & 23-10-2024 (kVAh) based on (A)					7630.02
Number of units (in kVAh) to be compensated as additional units [C-B]					2567.41



(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.