



MePDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION,
RIBHOI DISTRIBUTION CIRCLE, UMIAM

No. MePDCL /I&E/RBDC/T-96/2024-25/572

Dated Umiam the 21st March, 2025

To,

The Assistant Executive Engineer
Byrnihat Revenue Sub-Division
MePDCL, Byrnihat.

Sub: Inclusion of "Additional Units" to the electricity bills of Soil Conservator Training Institute, 12th Mile (Consumer Id.: 1000345292).

Sir,

During the random Inspection of HT Consumers under Byrnihat Division on the 12.02.2025, it was found that the R & Y Phase PT Supplies to Billing Meter No. IN4000303 of Soil Conservator Training Institute, 12th Mile (Consumer Id.: 1000345292) were missing due to carbon formation at PT tapping points which were then corrected only on the 20.03.2025 (on the spot correction on the 12.02.2025 could not be done due to unavailability of metering materials at site). From the trend of consumption, it may be estimated that the PT supplies (R & B Phase) might have got missing since the 01.02.2025.

In view of the above and to compensate for the loss of revenue to MePDCL on account of voltage supply missing in R & Y Ph, **3502.78 kVAh** of additional units may please be included into the Electricity Bill of this consumer and may be added along with the Bill Cycle of March or April, 2025.

This is for your kind information and necessary action.

Encl. Consumption statement.

Yours faithfully,

(Fullmoon L. Kynshi)

Assistant Executive Engineer-Cum-Assessing Officer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-96/2024-25/572(a)

Dated Umiam the 21st March, 2025

Copy to:-


1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. The Executive Engineer, Byrnihat Distribution Division for kind information.
4. The Executive Engineer, High Value Cell, MePDCL, Shillong for kind information.
5. The Executive Engineer, MTI Division Shillong for kind information.
6. The Joint Director, Soil Conservation Training Institute, Byrnihat for kind information.
7. R/F.

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement
Consumer ID/ Account No. 1000345292

Consumer's Name : Soil Conservator Training Institute.

Meter Readings for Meter ID:IN4000303 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	Kvah Meter	Recorded Demand	Recorded PF
Reading	01-Feb-25	4872.263	5002.981	0.616	
Reading (PT Supply Correction Date)	20-Mar-25	5044.4	5207.1		
No Of Days	47				
Difference		172.137	204.119		
Multiplying Factor		20	20		
Net Consumption		3442.74	4082.38	12.32	
Average Per Day Consumption (With missing B Ph PT Voltage)		73.25	86.86		
Additional Units to be included (kVAh)		3152.50	3502.78		
R&Y Ph PT Supply missing on (estimated)					01-02-2025
R & B Ph PT Supply restored/ corrected on					20-03-2025
No. of days between 01-02-2025& 20-03-2025					47
Per Day Consumption (kVAh) between 01-02-2025& 20-03-2025					86.86
kVAH (05-08-2024)					3815.40
kVAH (01-11-2024)					4525.50
No. of days between 05-08-2024 & 01-11-2024					88
Per Day Consumption (kVAh) between 05-08-2024 & 01-11-2024					161.39
Number of units (in kVAh) to be compensated as additional units					3502.78


(F.L. Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.