

Conid: 1000214159
B Nong bet.
category

(6.9)

MEGHALAYA ENERGY CORPORATION LIMITED

METER TESTING, INSPECTION DIVISION

METER TESTING LABORATORY

LUM JINGSHAI, SHORT ROUND ROAD, SHILLONG - 793001

TEST REPORT

NO. CP-25/03/08

DATE 17/03/2025

METER NO. SS17177710

5-30 AMP, 240V 50 C/S

MAKE- Socome

CREEP TEST

✓ OK/NOT OK

STARTING CURRENT TEST

✓ OK/NOT OK

INSULATION TEST


OK/NOT OK

(AT 2000 VOLTS)

LOAD	POWER FACTOR	ERROR
FL	1	-0.01%

TESTED BY :


INITIAL READING 03684.4



METER TESTER

METER TESTING LAB.

CHECKED BY :

12/3/25.

ASSISTANT ENGINEER
Executive Engineer
MTI Division
MePDCL, Shillong

Date of Re installation: 12/4/25
Date of Installation: 12/4/25

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASST. EXECUTIVE ENGINEER
UMIAM REVENUE SUB DIVISION

(65)

"SAVE ENERGY FOR THE BENEFIT OF SELF AND NATION"

No. MePDCL/URSD/T-5 /2024-2025/

Dated Umiām the 11/4/25.

To,

The Lineman, In-charge

Village: madan maukhar:

Sub:- Installation of meter

Kindly install the meter of the consumer mentioned below at the earliest for necessary action from this end.

Consumer Name :

B. Nong bet

Category :

DLT

Meter Number :

SS 17177710 (initial rd: 03684.4)

signature of U.M. [Signature]

Date of installation 12/04/25

ASST.
Assistant Executive Engineer
Umiām Distribution Sub-Division
MePDCL, Umiām