



Me PDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM

Email: aeeie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-96/2025-26/605

Dated Umiām the 19th May, 2025

To,

The Assistant Executive Engineer,
Umiām Distribution Sub-Division
MePDCL, Umiām.

Sub: Additional Units (kWh) to be included into the electricity bills of Indian Oil Depot (P) Ltd. , Umiām (Consumer Id.: 1000198042).

Sir,

The office of the undersigned has on the 06.05.2025 inspected the LT-CT metering unit of **Indian Oil Depot (P) Ltd. , Umiām (Consumer Id.: 1000198042)** and has found that Y Ph PT supply to meter missing due to carbon formation at PT tapping point (corrected).

In view of the above and to compensate for the loss of energy for the period w.e.f 10.04.2025 (estimated date of Y Ph PT supply failure) and 06.05.2025 (Y PT correction date), **1196.00** of Additional Units (kWh) may please be included into the electricity bills of this consumer (Bill Cycle of June, 2025).

This is for your kind information and necessary action.

Encl. Assesment of Additional Unit.

Yours faithfully,

(Fullmoon L. Kynshi)

Assistant Executive Engineer-Cum-Assessing Officer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiām

No. MePDCL /I&E/RBDC/T-96/2025-26/605(a)

Dated Umiām the 19th May, 2025


Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Umiām for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. Executive Engineer, Umiām Distribution Division, MePDCL, Umiām for kind information.
4. The Executive Engineer, MTI Division, MePDCL, Shillong for kind information.
5. The Junior Engineer (Central Billing Section), Umiām Distribution Division, MePDCL, Umiām for kind information and necessary action to include the additional unit as mentioned.
6. R/F.

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement
Consumer ID/ Account No. 1000198042
Consumer's Name : Indian Oil Depot (P) Ltd.

Meter Readings for Meter ID:MEB02261 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	Kvah Meter	Recorded Demand	Recorded PF
Reading (Y Ph PT Correction Date)	06-05-2025	5890.2			
Reading (estimated PT missing date)	10-04-2025	5830.4			
Difference		59.8			
Multiplying Factor		60			
Net Consumption		3588			
Additional Units to be included (kVAh))		1196.00			
Y Ph weightage (33.33%)					1196.00
Number of units (in kWh) to be compensated as additional units					1196.00


(F.L. Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.