

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED  
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER  
INVESTIGATION & ENFORCEMENT SUB-DIVISION  
RIBHOI DISTRIBUTION CIRCLE, UMIAM  
Email: aecie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-96/2025-26/604

Dated Umiam the 19<sup>th</sup> May, 2025

To,

The Assistant Executive Engineer,  
Umiam Distribution Sub-Division  
MePDCL, Umiam.

**Sub: Additional Units (kVAh) to be included into the electricity bills of M/S MEGHALAYA BRIQUETTE INDUSTRIES MIDC UMIAM (Consumer Id.: 2232000107).**

Sir,

M/S MEGHALAYA BRIQUETTE INDUSTRIES MIDC UMIAM (Consumer Id.: 2232000107) was first charged on 21.01.2025 and this firm has also started operationalizing and functioning on the same date. However, following the detection of incorrect CTR of the 11KV CT-PT Unit by the undersigned, the old CT-PT Unit was replaced with new Unit (Sl. No. 70330) on the 01-04-2025.

In view of the above and to compensate for the loss of energy for the period w.e.f 21.01.2025 (Date of service/ operationalization) and 01.04.2025 (CT-PT replacement date), **1,53,323.33** of Additional Units (kVAh) may please be included into the electricity bills of this consumer (Bill Cycle of May, 2025).

This is for your kind information and necessary action.

Encl. Assesment of Additional Unit.

Yours faithfully,

(Fullmoon L. Kynshi)

Assistant Executive Engineer-Cum-Assessing Officer  
I & E Sub-Division, Ribhoi (D) Circle  
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-96/2025-26/604(a)

Dated Umiam the 19<sup>th</sup> May, 2025

Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. Executive Engineer, Umiam Distribution Division, MePDCL, Umiam for kind information.
4. The Executive Engineer, MTI Division, MePDCL, Shillong for kind information.
5. The Junior Engineer (Central Billing Section), Umiam Distribution Division, MePDCL, Umiam for kind information and necessary action to include the additional unit as mentioned.
6. The Manager, M/S MEGHALAYA BRIQUETTE INDUSTRIES MIDC UMIAM for kind information.
7. R/F.


ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement

Consumer ID/ Account No. 2232000107

Consumer's Name : M/S MEGHALAYA BRIQUETTE INDUSTRIES MIDC UMIAM

Meter Readings for Meter ID: MS5000046 and Meter Status: OK (Normal)					
Description	Date	KWH Motor	Kvah Motor	Recorded Demand	Recorded PF
Reading	19-05-2025	18023	27251	53.2	
Reading (CT-PT Unit Replacement Date)	01-04-2025	820	967		
No Of Days	48				
Difference		17203	26284		
Multiplying Factor		4	4		
Net Consumption		68812	105136	212.8	
Average Per Day Consumption (APDC)		1433.58	2190.33		
Additional Units to be included (kVAh)		137991.00	153323.33		
No. of days between 21-01-2025 (Date of Service) & 01-04-2025 (CT-PT Replacement Date)					70
(B). Consumption (kVAh) between 21-01-2025 (Date of Service) & 01-04-2025 (CT-PT Replacement Date) based on APDC should have been					153323.33
Number of units (in kVAh) to be compensated as additional units [B-A]					153323.33

  
19/05/25

(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer  
I & E Sub Division, Ribhoi (D) Circle  
MePDCL, Umiam.