MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRICT CIRCLE, UMIAM
Email: aeeie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-96/2025-26/624 Dated Umiam the 20th June, 2025

To,

The Assistant Executive Engineer,
Umiam Distribution Sub-Division
MePDCL, Umiam.

Sub: Additional Units (kVAh) to be included into the electricity bills of Sird Complex, C/O.Director Sird Nonsder (Consumer Id.: 1000345350).

Sir,

The office of the undersigned has on the 02.06.2025 inspected the LT-CT metering unit of **Sird Complex, C/O.Director Sird Nonsder (Consumer Id.: 1000345350)** and has found that Y Ph PT supply to meter missing due to carbon formation at PT tapping point (corrected).

In view of the above and to compensate for the loss of energy for the period w.e.f 21-03-2025 (date of Y Ph PT supply failure as per MRI) and 02-06-2025 (Y Ph PT correction date), **4934kVAh** of Additional Units may please be included into the electricity bills of this consumer (Bill Cycle of July, 2025).

This is for your kind information and necessary action.

Encl. Assesment of Additional Unit.

Yours faithfully,

(Fullmoon L. Kynshi)
Assistant Executive Engineer-Cum-Assessing Officer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-96/2025-26/624(a) Dated Umiam the 20th June, 2025

Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. Executive Engineer, Umiam Distribution Division, MePDCL, Umiam for kind information.
4. The Executive Engineer, MTI Division, MePDCL, Shillong for kind information.
5. The Junior Engineer (Central Billing Section), Umiam Distribution Division, MePDCL, Umiam for kind information and necessary action to include the additional unit as mentioned.
6. R/F.

20/06/2025

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement

Consumer ID/ Account No. 1000345350

Consumer's Name : Sird Complex

Meter Readings for Meter ID:IN4000314 and Meter Status: OK (Normal)					
Description	**Date**	**KWH Meter**	**Kvah Meter**	**Recorded Demand**	**Recorded PF**
Reading (Y Ph PT Correction Date)	02-06-2025	1911.06	2123.40		
Reading (Y Ph PT missing date as per MRI)	21-03-2025	1763.05	1958.94		
Difference		148.01	164.46		
Multiplying Factor		60.00	60.00		
Net Consumption		8880.72	9867.47		
Additional Units to be included (kVAh))			**4933.73**		
Y Ph weightage (=1/2 of R & B together)					4933.73
Number of units (in kVAh) to be compensated as additional units					**4933.73**

20/06/2025

(F.L Kynshi)
Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.