

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM
Email: aecie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-96/2025-26/624

Dated Umiam the 23rd June, 2025

To,

The Assistant Executive Engineer,
Nongpoh Urban Distribution Sub-Division
MePDCL, Nongpoh.

Sub: Additional Units (kWh) to be included into the electricity bills of Hindustan Petroleum Corporation Limited, (Consumer Id.: 1000350836) & June Rose Tynsong, Nongpoh Proper (Consumer Id.: 1000354263).

Sir,

The office of the undersigned has on the 30-05-2025 & 05-06-2025 inspected the LT-CT metering units of Hindustan Petroleum Corporation Limited, (Consumer Id.: 1000350836) & June Rose Tynsong, Nongpoh Proper (Consumer Id.: 1000354263) respectively and has found the CT secondaries of all Phases partially open circuited at TTB (corrected) possibly due to incorrect smart metering work undertaken by the contractor resulting to loss of revenue to MePDCL.

In view of the above and to compensate for the loss of energy due to such improper metering work, Additional Units (kWh) against each consumer as tabulated below may please be included into their respective electricity bills (Bill Cycle of July, 2025).

Sl. No	Name of Consumer	Cons. ID	Additional Unit (kWh) to be added
1	Hindustan Petroleum Corporation Limited	1000350836	5483
2	June Rose Tynsong, Nongpoh Proper	1000354263	18252

This is for your kind information and necessary action.

Encl. Assesment of Additional Unit.

Yours faithfully,

(Fullmoon L. Kynshi)

Assistant Executive Engineer-Cum-Assessing Officer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-96/2025-26/624(a)

Dated Umiam the 23rd June, 2025

Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. Executive Engineer, Nongpoh Distribution Division, MePDCL, Nongpoh for kind information.
4. The Executive Engineer, MTI Division, MePDCL, Shillong for kind information.
5. R/F.

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement
Consumer ID/ Account No. 1000350836
Consumer's Name : Hindustan Petroleum Corporation Limited


Meter Readings for Meter ID: MS5004800 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	Remarks		
Reading	30-Apr-24	64505	Pre-installation of Smart Meter (MEB96660, M.F=1)		
Reading	27-Sep-24	68080			
No Of Days	150				
Difference		3575			
M.F		1			
Net Consumption		3575			
Average Per Day Consumption (APDC) A		23.83			
Reading	26-Sep-24	0	Post-installation of Smart Meter (MS5004800, M.F=20)		
Reading	30-May-25	19			
No Of Days	246				
Difference		19			
M.F		20			
Net Consumption		380			
Average Per Day Consumption (APDC) B		1.54			
Difference (D=A-B)		22.29			
Additional Units to be included (kWh)		5483.00			
Number of days between 26-09-2024 (MChD) and 30-05-2025 (MCoD)=N					246
Number of units (in kWh) to be compensated as additional units (=DxN)					5483

(Signature) 28/06/2025
(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000354263
Consumer's Name : June Rose Tynsong, Nongpoh Proper

Meter Readings for Meter ID: MS5004614 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	Remarks		
Reading	28-Mar-24	75559.6	Pre-installation of Smart Meter (MEB96542, M.F=1)		
Reading	06-Aug-24	88794			
No Of Days	131				
Difference		13234.4			
M.F		1			
Net Consumption		13234.4			
Average Per Day Consumption (APDC) A		101.03			
Reading	15-Oct-24	63.48	Post-installation of Smart Meter (MS5004614, M.F=20)		
Reading	05-Jun-25	538.65			
No Of Days	233				
Difference		475.17			
M.F		20			
Net Consumption		9503.4			
Average Per Day Consumption (APDC) B		40.79			
Difference (D=A-B)		60.24			
Additional Units to be included (kWh)		18252.37			
Number of days between 06-08-2024 (MChD) and 05-06-2025 (MCoD)=N					303
Number of units (in kWh) to be compensated as additional units (=DxN)					18252


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.