

U Prasad, Rangnen
 Cons. ID: 1000208934
 1KW, DLT

Date of inspection: 25/07/2025

Finding: Wrong Meter Connection
 (Attributed to local metering contractor).

24/7/25 → 265.78 kwh
 01/7/25 → 353.69 kwh
 87.91 kwh
 90 days = 0.977 unit/d

18/9/2023 → 1810 kwh
 18/01/2024 → 2028 kwh
 218 kwh
 123 days
 = 1.772 unit/day
AU = $(1.772 - 0.977) \times 12 \times 30$

(Additional units) = 286 units

Main Meter 11103533 wrongly placed
 at location of consumer sub-meter no. 4971175
 (video proof available) → corrected.

SE (Central Billing Section), UDD for kind
 information and necessary action to ~~be~~
 add. the additional units above. (286 kwh).

P. Prasad 29/07/2025
 ASSISTANT EXECUTIVE ENGINEER,
 INVESTIGATION & ENFORCEMENT,
 RIBHOI DISTRIBUTION CIRCLE
 MEPDCL, UMAM.