

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM
Email: aceie.rb.mepdcl@meghalaya.gov.in

No.MePDCL/I&E/RBDC/T-96/2025-26/646

Dated, Uiam the 7th August, 2025

To,

The Assistant Executive Engineer
Uiam Rural Distribution Sub- Division
MePDCL, Uiam.

Sub: Additional Units (kWh) to be included into the Electricity Bill of State Bank Of India (Cons. ID: 1000197935), Umroi.

Sir,

This is to inform you that the office of the undersigned has found the old meter No. 767566 of **State Bank Of India (Cons. ID: 1000197935), Umroi** to be defected (Meter Impulse fails to blink inspite of heavy current (21A) flowing through the conductor). The defected meter above was replaced with 3Ph Whole Current JPM Make Smart Meter No. 22001209 on the 03-07-2025 with initial readings: 00.00KWH, 00.00KVAH. To asses the consumption pattern of this consumer, inspection was again conducted on the 05-08-2025 (after 33 days) and the kWh reading observed was 1268.22 (Video Proof available).

In light of the above, the unit loss of **13296.00 KWH** considered for 365 days only (One Year) may please be recovered as Additional Units (kWh).

This is for your kind information and necessary action.

Yours sincerely,

(F.L Kynshi)

Assistant Executive Engineer cum Assessing Officer
Investigation & Enforcement Sub-Division
Ribhoi Distribution Circle
MePDCL, Uiam

No.MePDCL/I&E/RBDC/T-96/2025-26/646(a)

Dated, Uiam the 7th August, 2025


Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle for kind information.
2. The Superintending Engineer (I&E), Eastern Zone, MePDCL, Shillong for kind Information.
3. The Executive Engineer, Uiam Distribution Division for kind information.
4. The Junior Engineer (Central Billing Section), Uiam Distribution Division, MePDCL, Uiam for kind information and necessary action with a request to include the additional unit as mentioned.
5. The consumer, State Bank Of India (Cons. ID: 1000197935), Umroi for kind information.
6. R.F.

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement
Consumer ID/ Account No. 1000197935
Consumer's Name : State Bank Of India

Meter Readings for Meter ID: 22001209 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	Remarks		
Reading	23-May-24	14217	With defected Meter No. 767566		
Reading	16-Jun-25	14996			
No Of Days	389				
Difference		779			
M.F		1			
Net Consumption		779			
Average Per Day Consumption (APDC) A		2.00			
Reading	03-Jul-25	0	Post-installation of Healthy Meter No.: 22001209		
Reading	05-Aug-25	1268.22			
No Of Days	33				
Difference		1268.22			
M.F		1			
Net Consumption		1268.22			
Average Per Day Consumption (APDC) B		38.43			
Difference (D=A-B)		36.43			
Additional Units to be included (kWh)		13296.34			
Number of days taken for recovery of unit loss (12 months) N					365
Number of units (in kWh) to be recovered as additional units (=DxN)					13296


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umlam.