



Me PDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM
Email: aecie.rb.mepdcl@meghalaya.gov.in

No.MePDCL/I&E/RBDC/T-96/2025-26/649

Dated, Umiam the 31st July, 2025

To,

The Assistant Executive Engineer
Umiam Rural Distribution Sub- Division
MePDCL, Umiam.

Sub: Meter Replacement Report & Additional Units (kWh) to be included into the Electricity Bill of Bharti Infratel (Cons. ID: 1000197963), Nongtraw.

Sir,

This is to inform you that the office of the undersigned has found the billing of Bharti Infratel (Cons. ID: 1000197963) being billed on "TOD 2 CkWh" reading instead of the Total Cumulative kWh reading resulting into loss of revenue to MePDCL on account of such wrong entry of billing components. Therefore, the unbilled units (TOD 1 & TOD 3) may please be recovered as Additional Units.

In light of the above and to account for the loss of revenue to MePDCL due to such wrong entry of CKWH by Meter Reader, **28102.00 kWh** of Additional Units may please be included into the electricity bill of the said consumer (Bill Cycle of August, 2025).

Further, to ensure that only the Actual CKWH are taken for billing, the old TOD Meter No.: WBBD8424 was replaced with Non-TOD JPM Make 3Ph Whole Current Smart Meter No.: **22001204** (uses Airtel SIM Card No.: 0621 ID 899116099001 8245120U, Initial Readings: 00.00KWH, 00.00KVAH, 00.00KW) on the 30-07-2025.

This is for your kind information and necessary action.

Yours sincerely,

Note: The system self generated MC unit shall be kept at "00.00" and only the Additional Units above shall be the MC unit.

[Signature]
31/07/2025
(F.L Kynshi)

Assistant Executive Engineer cum Assessing Officer
Investigation & Enforcement Sub-Division
Ribhoi Distribution Circle
MePDCL, Umiam

No.MePDCL/I&E/RBDC/T-96/2025-26/649(a)

Dated, Umiam the 31st July, 2025


Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle for kind information.
2. The Superintending Engineer (I&E), Eastern Zone, MePDCL, Shillong for kind Information.
3. The Executive Engineer, Umiam Distribution Division for kind information.
4. The Junior Engineer (Central Billing Section), Umiam Distribution Division, MePDCL, Umiam for kind information and necessary action with a request to update the new Meter No. above and to include the additional unit as mentioned.
5. Bharti Infratel (Cons. ID: 1000197963), Nongtraw for kind information.
6. R.F.

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement
Consumer ID/ Account No. 1000197963
Consumer's Name : Bharti Infratel.

Meter Readings for Meter ID: WBBD8424 and Meter Status: OK (Normal)					
Description	Date	CKWH Meter	TOD 1 (KWH)	TOD 2 (KWH)	TOD 3 (KWH)
Reading (Meter Replacement Date)	30-Jul-25	172735.16	77592	50885	44283
Reading already billed (TOD 3)	17-Jun-25			49930	
Last Normal Reading with CKWH	19-Jan-24	134507.6			
Diff. CKWH		38227.56			
Diff. TOD 2 (30-07-25 & 22-03-24)				10125.8	
Number of units (in kWh) to be included as additional units (=TOD 1+TOD3 w.e.f 22-03-2024 to 30-07-2025)					28102


31/7/25

(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.