



Me PDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM

Email: aeeie.rb.mepdcl@meghalaya.gov.in

No.MePDCL/I&E/RBDC/T-96/2025-26/653

Dated, Umiam the 5th August, 2025

To,

The Assistant Executive Engineer
Umiam Rural Distribution Sub- Division
MePDCL, Umiam.

Sub: Additional Units (kWh) to be included into the Electricity Bill of Banaiti Maring (Cons. ID: 1000215227), Lumdaitkhla.

Sir,

This is to inform you that the office of the undersigned has found the old meter No. 5095 of **Banaiti Maring (Cons. ID: 1000215227), Lumdaitkhla** to be defected (Meter Impulse fails to blink inspite of current flowing through the conductor). The defected meter above was replaced with 1Ph JPM Make Smart Meter No. 11122141 with initial readings: 00.00KWH, 00.00KVAH. To asses the consumption of this consumer, inspection was again conducted on the 05-08-2025 (after 18 days) and the kWh reading observed was 121.23.

In light of the above, the unit loss of **2458.00 KWH** considered for 365 days (One Year) may please be recovered as Additional Units (kWh).

This is for your kind information and necessary action.

Yours sincerely,

(F.L Kynshi)

Assistant Executive Engineer cum Assessing Officer
Investigation & Enforcement Sub-Division
Ribhoi Distribution Circle
MePDCL, Umiam

No.MePDCL/I&E/RBDC/T-96/2025-26/653(a)

Dated, Umiam the 5th August, 2025


Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle for kind information.
2. The Superintending Engineer (I&E), Eastern Zone, MePDCL, Shillong for kind Information.
3. The Executive Engineer, Umiam Distribution Division for kind information.
4. The Junior Engineer (Central Billing Section), Umiam Distribution Division, MePDCL, Umiam for kind information and necessary action with a request to include the additional unit as mentioned.
5. The consumer, Banaiti Maring (Cons. ID: 1000215227), Lumdaitkhla for kind information.
6. R.F.

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement
Consumer ID/ Account No. 1000215227
Consumer's Name : Banaiti Maring.

Meter Readings for Meter ID: 11122141 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	Kvah Meter	Recorded Demand	Recorded PF
Reading (2nd Inspection)	05-08-2025	121.23			
Reading (New Meter Installation Date)	18-07-2025	0			
Difference	18	121.23			
Multiplying Factor		1			
Net Consumption		121.23			
Average Per Day Consumption (APDC) kWh		6.74			
Additional Units to be included (kWh)		2458.28			
No. of days under consideration (1year) for recovery of unit loss on account of meter defective					365
Number of units (in kWh) to be included as additional units					2458



(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.