

Meghalaya State Electricity Board

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

NEARLESS KSHAR

(Please leave one block between name & surname)

(Full Name)

NONGTYNGUR

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

I. The load has been arranged as follows: -

Details of Load	Wattage of each item	Phase - I		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total watt	
1. Light points (i) Fluorescent (ii) Incandescent (iii) CFL (iv) Halogen (v) Others	60w	7	420w					
2. Fan points								
3. Plug points (3-pin) (i) 6 Amps (ii) 16 Amps	100w	2	180w					
4. Electrical gadgets (i) Water Heater (Geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Others								
5. Welding Transformer								
6. Motor								
Total			520w					
In case of load enhancement Existing load (in watts)			1000w					
Total load in the premises (in watts)			1520w					or 2kw

Notes: -

- Details of any apparatus (other than the above mentioned) should be given.
- Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed).

KVAR

II. Type of wiring

Looping system.

III. Voltage and system of supply

240V.

IV. Test Result:

OK

Date of Testing by Licensed Contractor:

1 6 0 6 2 4

Type of Test	Result of test carried out by licensed contractor (In (M Ω)/ Ω)	Result of test carried out by the supplier under relevant IE Rules, in (M Ω)/ Ω
a. Insulation resistance between earth and whole system of conductor.	10 M	
b. Insulation resistance between all conductors.	15 M	
c. Earth continuity between earth electrode and earth continuity conductor.		
d. Polarity of non-linked SP switches.	Phase	

V. Full Name with signature of Licensed contractor :

LIC No. :

J. D. D.
Jangshorn Dhangdon
Elect. Contractor
Lic. No : 9836
Pynursala.

VI. Full Name with signature of supervisor :

(with date)

LIC No. :

J. D. D.
J. Dhangdon
Elect. Supervisor
Lic. No. 1974
Pynursala.

VII. Full Name with signature of wireman
(with date)

PERMIT No. :

J. D. D.
J. Dhangdon
Elect. Wireman
Lic. No : 3480
Pynursala.

VIII. Signature of the authorized official who tested
The installation of behalf of supplier. :

IX. Date of connection of supply to the installation :