

Meghalaya Energy Power Distribution Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

GLOAY KHAMSTIN

(Please leave one blank between name & surname)

(Full Name)

MONGLEZTANANG

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	No. of points	Total Watt	No. of points	Total Watt	No. of points	Total Watt	Total watt of all 3 phases
1. Light points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others								
2. Fan points								
3. Plug points (3-pin)								
(i) 6 Amps								
(ii) 16 Amps	1000	1	1000					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) Air Conditioner								
(iv) Others								
5. Welding Transformer								
6. Motor								
Total			1000					
In case of load enhancement Existing load (in watts)			1000					
Total load in premises (in watts)			2000					or 2 kW.

Notes :-

- (a) Details of any apparatus (other than the above mentioned) should be given.
- (b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed).

KVAD

6. Type of wiring

P.V.C Looping system

7. Voltage and system of supply

230V

8. Test Result:

Date of Testing by Licensed Contractor

03 09 2021

Type of Test	Result of test carried out by licensed contractor (in M Ω) / Ω	Result of test carried out by Supplier under relevant IE Rules, in (M Ω) / Ω
a. Insulation resistance between earth and whole system of conductor	25 M Ω	
b. Insulation resistance between all conductors	26 M Ω	
c. Earth continuity between earth electrode and earth continuity conductor		
d. Polarity of non-linked SP switches	Phase	

9. Full Name with signature of Licensed contractor

LIC No.

Chhaya

10. Full Name with signature of supervisor (with date)

LIC No.

Chhaya

11. Full Name with signature of wireman (with date)

PERMIT NO.

Chhaya KHONGWET
Electrical Workman
Regd No. 4978

VIII. Signature of the authorized official who tested
The installation of behalf of supplier

IX. Date of connection of supply to the installation

X. Date of completion of work