

MEGHALAYA POWER GENERATION CORPORATION LIMITED

OFFICE OF THE EXECUTIVE ENGINEER :: SHILLONG CIVIL DIVISION-II ::

LUMJINGSHAI :: SHORT ROUND ROAD :: SHILLONG : 793 001.

☎ 0364 2592237 :: Email ID: shillongcivildivision@gmail.com

EE/SCD-II/Farmer's Hostel (AGRI)/Pt-I/2023-24/16

Dated Shillong the 6th November, 2023

To,
The Assistant Executive Engineer (EL),
Distribution Sub-Division,
MePDCL, Upper Shillong.

Sub: Service Connection for "Construction of Farmer's Training Centre Building including Internal Electrification, Sanitary Fitting and Internal Water Supply at Upper Shillong, East Khasi Hills District"

Ref: No.DAD-1799/RKVY/COR/2022-23/349 Dated: 20th October, 2023

Sir,


With reference to the above, enclosed please find herewith a copy of letter under reference above alongwith the Application Form and Test Report in original for "Construction of Farmer's Training Centre Building including Internal Electrification, Sanitary Fitting and Internal Water Supply at Upper Shillong, East Khasi Hills District", executed by the office of the undersigned.

In view of the above, you are requested to kindly submit the Bill/Estimate for necessary approval from the Client Department.

This is for favour of your kind information and necessary action.

Enclo: As stated above.

Yours faithfully,


Executive Engineer (C),
Shillong Civil Division-II
Me.P.G.C.L., Shillong.

Memo No. EE/SCD-II/Farmer's Hostel (AGRI)/Pt-I/2023-24/16(a) Dated Shillong the 6th November, 2023

Copy to:-

1. The Superintending Engineer (C), Shillong Civil Circle, MePGCL, Shillong for favour of information.



JE for joint inspection.

Upper Shillong Dist. Sub Division
MePDCL, Shillong

Diary No. 60.

Date 13.11.2023

File No. T-3

EXECUTIVE ENGINEER (C)

186
(15)

**GOVERNMENT OF MEGHALAYA
DIRECTORATE OF AGRICULTURE
MEGHALAYA, SHILLONG**

No.DAD-1799/RKVY/COR/2022-23/349

Dated Shillong, the 20th October, 2023

From: J. C. Lyngdoh,
Director of Agriculture,
Meghalaya, Shillong.

To: ✓ Executive Engineer (C),
Shillong Civil Division- II,
Me.P.G.C.L., Shillong.

Sub: Application Form for 'Providing Service Connection to the Newly Constructed Farmers Training Centre at Upper Shillong'.


Ref: No. EE/SCD-II/Farmer's Hostel (AGRI)/Pt-I/2023-24/6, Dated Shillong the 25th July, 2023.

Sir/Madam,

With reference to the subject* and your Letter No. EE/SCD-II/Farmer's Hostel (AGRI)/Pt-I/2023-24/6, Dated Shillong the 25th July, 2023, please find enclosed herewith the duly signed Test Report in Annexure-3 for further necessary action from your end.

Enclosed: As stated.


Yours faithfully,


**Director of Agriculture,
Meghalaya, Shillong.**

Memo No.DAD-1799/RKVY/COR/2022-23/349 ,
Copy to:

Dated Shillong, the 20th October, 2023

1. Deputy Director of Agriculture (Planning), Shillong for kind information.
2. Office Copy.


**Director of Agriculture,
Meghalaya, Shillong.**

NBC- 120 kw

GHALAYA ENERGY POWER DISTRIBUTION CORPORATION LIMITED
APPLICATION FORM FOR PROVIDING SERVICE CONNECTION
(FOR ALL CATEGORY AND FOR ALL PURPOSE)

To, The Area Manager/Assistant Executive Engineer
Service Connection Sub Division/.....Distribution Sub Division
MePDCL Upper Shillong
(Indicate the local area of the jurisdiction of the Engineer of the Licensee)

Sir,

1. I/We hereby request you to supply electricity to the premises located at the address more fully described below.
2. I/We agree to abide by the terms and conditions relating to the supply of electricity by MePDCL and to make all payments as may be required and also to pay regularly all charges as may become due.
3. (a) Full name and address of the applicant with contact telephone/Mobile number :

CONSTRUCTION OF FARMERS TRAINING CENTRE BUILDING
INCLUDING INTERNAL ELECTRIFICATION, SANITARY FITTING
AND INTERNAL WATER SUPPLY AT UPPERSHILLONG,
EAST KHASI HILLS SHILLONG

(b) Status in relation to the premises : Owner ☒
Occupier ☐

(c) Location and address of the premises including Police Station :

(d) Nature of LT Supply : Commercial ☐
General Purpose ☐
Agriculture ☒

Domestic ☐
WSLT ☐
KJ ☐

Industrial ☐
PL ☐
MePDCL ☐
Employee ☐

Date :

Applicant's Signature

NB : The following documents are to be enclosed :

- 1) Test Report from Licensed contractor.
- 2) Agreement form duly filled in
- 3) Proof of ownership (in case an applicant is owner)
- 4) Number of nearest Electric Pole Number of nearest Consumer.....
- 5) NOC of the owner of the premises (in case an applicant is an occupier).
- 6) Attested copies of permission obtained from Pollution Control Board (if applicable).
- 7) Building permission from the concerned authority (if applicable).
- 8) Occupancy Certificate from MUDA for areas within Shillong Municipal Limit (if applicable).
- 9) Proof of Identification (any one of the following) :-

Electoral Identity Card/Passport/Driving Licence/Ration Card/Photo Identity Card issued by Government agency/PAN Card/Certificate of residence or identity from the Headman/Nokma Village Levelworker/Primary School Teacher/Incharge of primary health centre.

I. Type of wiring

PVC Cabling in system

III. Voltage and system of supply

415V

IV. Test Result :

OK

Date of Testing by Licenced Contractor :

07/07/23

Type of Test	Result of test carried out by licensed contractor (In MΩ) /Ω	Result of test carried out by Supplier under relevant IE Rules, in (MΩ) /Ω
a. Insulation resistance between earth and whole system of conductor.	38 MΩ - 36 MΩ	35 MΩ
b. Insulation resistance between all conductors.	36 MΩ - 36 MΩ	35 MΩ
c. Earth continuity between earth electrode and earth continuity conductor.	3 Ω - 3 Ω	3 Ω
d. Polarity of non-linked SP switches.	+	+

V. Full Name with signature of Licensed contractor

LIC No.

M/S. P. S. Enterprise
Electrical Contractor
Lic No - 1421

VI. Full Name with signature of supervisor
(with date)

LIC No.

Shri Paramjit Singh Ray
Electrical Supervisor
Registration No - 1372
Shillong Meghalaya

VII. Full Name with signature of wireman
(with date)

PERMIT No. :

R. N. Ray
2665

VIII. Signature of the authorized official who tested
The installation of behalf of supplier.

IX. Date of connection of supply to the installation.