

Total load in the premises (in watts)										9580	watts
---------------------------------------	--	--	--	--	--	--	--	--	--	------	-------

OR
10 KW

Notes:

(a) Details of any apparatus (other than the above mentioned) should be given.

(b) Rating of capacitor used in induction Motor and welding

Transformer (Test report of capacitor is to be enclosed)

KVAR

II. Type of wiring *Acrophy in System*

III. Voltage and system of supply *440V*

IV. Test Result

Date of testing by licensed contractor

2	3	0	8	2	4
---	---	---	---	---	---

	Type of test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant Cea regulations. (in MΩ) / Ω
(a)	Insulation resistance between earth and whole system of conductor.	50Ω, 50Ω, 50Ω	
(b)	Insulation resistance between all conductors		
(c)	Earth continuity between earth electrode and earth continuity conductor	45Ω, 45Ω, 45Ω	
(d)	Polarity of non-linked SP switches	Phase, Phase, Phase	

V. Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.

VI. Full name with signature of supervisor (with date)

LIC No.

Mobile No.

VII. Full name with signature of wireman (with date)

LIC No.

Mobile No.

VIII. Signature of the authorized official who

tested the installation on behalf of supplier (with date)

Mobile No.

IX. Date of connection of supply to the installation

[Signature]
Electrician
Regd. No. 1515

[Signature]
PSR Shanyanjah
Electric Supervisor
Regd. No 1112