

2007 V/P



Annexure -3

Agreement for Supply of Electricity Low Tension

An Agreement made this the _____ day of _____ of 20 24 between _____ and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution/Utility/MaPDCL) of the other part.

Note : The term 'consumer' includes an individual person (Whether male or female), a body of persons, a company, society, firm, association or organization.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereafter appearing.

Now, therefore, the agreement witness :-

(1) That the supply shall be given to the premises located at Devotee's Abode with the Consumer as owner/occupier of ;

(2) That the supply shall be for the purpose of Commercial the load whereof shall not exceed 5000 watts.

(3) That the provision of the EA, 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumer and the distribution utility alike.

(4) That the consumer shall regularly and timely pay to MaPDCL all charges may be due for the supply of electricity.

(4-a). That the consumer shall pay the Transformer Maintenance Charge as stipulated in the license and thereby maintenance and replacement of the transformer on account of failure shall be the responsibility of the licensee.

(5). That the agreement shall be a period of two years and may be renewed for a further period. Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed,

(6). That the agreement shall be terminated if the consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

Provided that on the part of the MePDCL, notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any, duly considered before the agreement is terminated and the supply of Electricity cut off.

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties herein have set their hands and seals the date, month, and year first above written.


(For and on behalf of and by
Authorization the) consumer.

For and on behalf of MePDCL

Witness :-

1. Signature : _____
Name : _____
Address : _____

2. Signature : _____
Name : _____
Address : _____

ME 31.11 Schedule I Form B

Meghalaya Energy Corporation Limited

TEST REPORT

This is to certify that a transformer and distribution system, installed at the premises of

BELINDA KIRKONGER

(Please leave one blank between name & address)

(Full Name)

KIRKONGER

(Address)

is duly completed, tested and is ready for your signature to test and connect to your main line.

The load has been arranged as follows:-

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of poles	Total watt	No. of poles	Total watt	No. of poles	Total watt	
1. Light points (i) Fluorescent (ii) Incandescent (iii) CFL (iv) Halogen (v) Other / LED	9W	25	225					
2. Fan points	100W	22	2200					
3. Plug points (2 pin) (i) 5 Amps (ii) 15 Amps	100W	15	1500					
4. Electrical gadgets (i) Water Heater (Geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Other								
5. Welding Transformer								
6. Motor								
Total			4925					
Rating of load arrangement								
Rating load (in watt)								
Total load on the premises (in watt)			5KW					

Notes:-

(i) Details of any appliances other than the above mentioned should be given.

(ii) Rating of transformer used in induction Motor

and Welding Transformer (Test report of appliance is to be provided)

KW

16. Typical wiring

Carry over

17. Voltage and current supply

230 VAC

18. Test Results

OK

Date of Testing by Licensed Contractor

25 1 0 2 4

Type of Test	Result of test carried out by licensed contractor (to BS246)	Result of test carried out by the supplier under relevant IE Regulation (MCO 1)
a. Insulation resistance between cable and whole system of installations	<i>110 MΩ</i>	
b. Insulation resistance between all conductors	<i>107 MΩ</i>	
c. Earth resistance between cable electrode and earth continuity conductor	<i>3 Ω</i>	
d. Polarity of non-linked SP switches	<i>0 MΩ (PN-230V) EA-0V</i>	

V. Full Name with signature of Licensed contractor

LIC No.

Robbie
Don E. Smith
Electrical Contractor
Govt. of Maharashtra
Regd. No. 1445

VI. Full Name with signature of supervisor
(with date)

LIC No.

For J. M. J.
Don J. M. J.
Electrical Supervisor
Govt. of Maharashtra, Regd. No. 1187

VII. Full Name with signature of witness
(with date)

PERMIT No.

S. K. Kulkarni
Smt. K. Kulkarni
Electrical Worker
Govt. of Maharashtra
Regd. No. 14570

VIII. Signature of the authorised official who tested
The installation on behalf of supplier

IX. Date of commissioning of supply to the installation

JORBAR SHNONG UMROI NONGRAH

RAID MAWBUH, MYLLIEM SYIEMSHIP

RI-RIHOI DISTRICT MEGHALAYA - 793103

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District
Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

Ref. No.

Date: 19 Jan 2024

DULIR AI SIEM SHIM SIEM KHYNDEW

To,

Mrs. Belinda Kharkongor

Residing at Market Hill - 1, Belling East Road Hill

The Letter is sent to 19-01-2024

Regarding the fact that you are the Belinda Kharkongor

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District

Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

The fact is that you are the Belinda Kharkongor

It is noted that you are the Belinda Kharkongor

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District

Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

The fact is that you are the Belinda Kharkongor

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District

Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

The fact is that you are the Belinda Kharkongor

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District

Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

The fact is that you are the Belinda Kharkongor

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District

Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

The fact is that you are the Belinda Kharkongor

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District

Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

The fact is that you are the Belinda Kharkongor

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District

Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

The fact is that you are the Belinda Kharkongor

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District

Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

The fact is that you are the Belinda Kharkongor

Under rule 19(2) of the administration of Mylliem Township rules, 2011 of the Rihoi Hills Autonomous District

Hydroponics and conservation of forest, forest, forest, forest and forest of Mylliem Township for 2011

The fact is that you are the Belinda Kharkongor

GORBAR SHNONG UMROI NONGRAH

RAID MAWBUN – MYLLIEM SYIEMSHIP

RI BHOI DISTRICT MEGHALAYA – 793103

Notice under 48(2) of the Administration of Habitations (Meghalaya) Act, 2013 of the Meghalaya Panchayats (District) Act, 1994
Meghalaya Panchayats and Areas Council of Meghalaya District and Rangbahi Shnong of Mylliem Syiemship (District) 2013

11/7/20

(Date: District Head Office)

The 8th / July / 2020

No Objection Certificate

Da kane nga U Rangbahi Shnong Umroi Nongrah nga pynshishka ba i Käng/Bah
Bolinda Kharkanyat i dong jaka / ting hapoh ka shnong
Umroi Nongrah kaba hap hapoh ka Rangbahi Shnong

Kuenta ngam don kane kane ka jingjor ne pynshah halor ka jing tan tight (fresh
connection) is katei ka jaka / ting kila dei ki nong shong Shnong ba pura jong ka Umroi
Nongrah.


Rangbahi Shnong
Umroi Nongrah
P. D. O.
Rangbahi Shnong
Umroi Nongrah