

AGREEMENT FOR SUPPLY OF ELECTRICITY  
LOW TENSION.



AN AGREEMENT made this the \_\_\_\_\_ day of \_\_\_\_\_  
between \_\_\_\_\_ and his successors and assigns  
(hereinafter referred to as the Consumer) of the One Part and the Meghalaya State Electricity Board  
and electricity distribution licensee under the Electricity Act, 2003 and its successors and assigns  
(hereinafter referred to as the Board) of the Other Part

Note The term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organization.

WHEREAS, the consumer has applied to the Board for supply of electricity to its premises and the Board has agreed to give the supply under the terms and conditions hereinafter appearing.

NOW, THEREFORE, the agreement witnesses-

- 1) That the supply shall be given to the premises located at... *Lawbyrion*... with the consumer as owner/occupier of;
- 2) That the supply shall be for the purpose of... *LT*... the load whereof shall not exceed... *2000*... watt(s);
- 3) That the provisions of the Electricity Act, 2003 and the Regulations, Code and Orders, including Tariff Orders, as may be made from time to time by the Meghalaya State Electricity Regulatory Commission shall apply and bind the consumer and the Board alike;
- 4) That the consumer shall regularly and timely pay to the Board all charges and may be due for the supply of electricity;
- 5) That the Agreement shall be for a period of two years and may be renewed for a further period: Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- 6) That the Agreement shall be terminated if the consumer on its part desires it so and give to the Board a prior notice of not less than one month or, on the part of the Board, if the consumer has violated any of the terms and conditions of the agreement:

However, the... shall be... to the... shall...  
... to... and... to... and...  
... to... and the... of...

... shall be... from the... of...

**IN WITNESS WHEREOF**, the... have hereunto set their hands and seals the date...  
... and...

... on behalf of the Board

- ...
- ...
- ...
- ...
- ...
- ...
- ...
- ...

# MEGHALAYA ENERGY CORPORATION LTD

## TEST REPORT.

This is to certify that repaired/renewed/additional/new electric installation at the premises of

L O R R O R A M A N L O N G

(Please leave one block between name & surname)

(Full name)

L A N B Y R W A

(Address)


is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total Watt of all 3 phases
1. Light Points (i) Fluorescent (ii) Incandescent (iii) CFL (iv) Halogen (v) Others	100 Wt	3 No	300 Wt					
2. Fan Points								
3. Plug Points (3-pin) (i) 6Amps (ii) 16Amps	100 Wt 1000 Wt	2 No 1 No	200 Wt 1000 Wt					
4. Electrical gadgets (i) Water Heater (geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Other								
5. Welding Transformer								
6. Motor								
Total			2000 Wt					
In case of load enhancement Existing load (in watts)								
Total load in the premises (in watts)			2 kW					

Notes :-

- (a) Details of any apparatus (other than the above mentioned) should be given.
- (b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed)



KVAR

II Type of wiring

Cable Capping

III Voltage and system of supply

230V/φ

IV Test Result - OK

Date of Testing by Licensed Contractor :

220724

Type of Test	Result of test carried out by licensed contractor In (MΩ)/Ω	Result of test carried out by the supplier under relevant IE Rules, In (MΩ)/Ω
a. Insulation resistance between earth and whole system of conductor	107 MΩ	
b. Insulation resistance between all conductors	110 MΩ	
c. Faulty continuity between earth of service and earth continuity conductor	3 Ω	
d. Polarity on non-linked SP switches	0 MΩ (PN-230V) EN-0V	

V. Full Name with signature of Licensed Contractor :

LIC No. :



VI. Full Name with signature of supervisor  
(with date) :

VII. Full Name with signature of wireman  
(with date) :

PERMIT NO. :

VIII. Signature of the authorized official who tested  
The installation of behalf of supplier. :

IX. Date of connection of supply to the installation :

  
S. Lalgan  
Licensed Contractor  
Lic. No. 402  
  
D. RYMBAL  
Electrical Supervisor  
Govt. Regd. No - 1593  
  
W. Bynath  
Electrical Wireman  
Regd. No. 4178

Bill No: 100/2024  
Bill No: 100/2024

Bill No: 100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

100/2024

Due Date : 29-May-2024

Net Bill Amount : 2968.0

Vat  
Total  
Net Total

We hereby certify that the above bill is correct and true and correct copy of the bill is available at the office of the Billing Department, 2000, Group of Institutions, Jalandhar, Punjab, India. The amount of Rs. 2968.00 is due from the customer.

# DORBAR SHNONG LAWBYRWA

RAID MAWBUIH :: MYLLEM SYIEMSHIP

RI-DHOI DISTRICT, MEGHALAYA - 793104

Under Rule 10 (1) of the Administration of Myllem Syiemship Rules 2015 of the Khasi Hills Autonomous District (Appointment and Succession of Syiem, Deputy Syiem, Electors and Rangbah Shnong of Myllem Syiemship) Act 2007

NSI/NSC (2011) 20

Date 11/7/2011

## NO OBJECTION CERTIFICATE

Da kane nga u Rangbah Shnong jang ka  
Lawbyrwa nga pynshisha ba u Bahi Surbar Mawlong  
khan jang i kony Awiah Mawlong ba Shnong ba Sah  
ka Lawbyrwa. Nga u Rangbah Shnong ngan dan jangwad  
eici ia u ba Shm Connection light na byeta ka  
jangdon kam jang u

Shublei Shihun

  
Rajed Kha Krang  
Rangbah Shnong  
Lawbyrwa  
Ri-Dhoi District



Name - LURBOR MAWLONG  
 Father's Name : K NGONBSAP

Gender : Male  
 Date of Birth/Age : 22

Address : H No 28, LAWBYRWA, VILL LAWBYRWA,  
 DIST MI BHOJ: 792103

Date : 10.08.2021

*[Signature]*  
 Electoral Registration  
 Officer

Assembly Constituency No. and Name : 11  
 UMNINE (ST)

Part No. and Name : 41 LAWBYRWA

*[Small, faint text, likely a notice or disclaimer regarding the registration process, partially illegible due to low resolution.]*


DULIR KHYNDEN

Printed in ...

Nga ... ka ...  
ka ... R. ... District ...  
...  
...  
...  
...  
...

1. Mithari - 3. ...
2. Sefroni - 7. ...
3. Skatei - 8. ...
4. Skathie - 9. ...

So ...  
ka ...  
...  
...  
...  
...  
...

  
Nengquibhynta

Nengquibhynta  
...

1. ...  
... KHREP

Secretary ...  
...





ROUTINE TEST REPORT

Serial Number: SS17175142      Customer: M/S MANTA ELECTRICALS  
Customer P.O Number: MANTA/23-24/002  
Customer P.O Date: 03-AUG-2023  
Voltage: 240V      Current: 05-30A      Accuracy Class: 1.0  
Ref. Standard: IS : 13779  
Meter Constant: 6400

- 1. AC VOLTAGE TEST: PASS
- 2. TEST OF NO LOAD CONDITION: PASS
- 3. TEST OF STARTING CURRENT: PASS
- 4. INSULATION TEST: PASS
- 5. METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz    Ib = 05-30A    Amb, Temp = 27 +/- 2 Deg. C

METER ACCURACY


Active Import Errors

Load % Ib	0.5 Lag	0.9 Lead	UPF
600	0.3	-0.1	-0.1
100	0.1	0.0	0.0
10	0.1	0.0	0.0
5			0.0

00001.0

TEST DATE: 11-07-2023

This is computer generated test report no signature required

  
Meter Tester Gr - 1  
MTI Laboratory  
MePDCL, Lumjingshal  
Shillong

  
(Y. Passah)  
Assistant Engineer  
MTI Lab  
MePDCL, Shillong