

2041

## ADDITIONAL / SUB-METER



## Personal Details

\*Application No

\*Consumer Name

Husbanis

\*Father's Name

Phymailin Chyrmang

Isahap T. Deleo

\*Mobile No

9233323204

Email

\*Aadhar No

## Address Details

\*Accommodation

Own / Rented (Please tick one)

\*Discom

Meghalaya Power Distribution Corporation

\*Zone

Eastern Zone \*Circle - Ribhoi Circle \*Division - Umiam Division

\*Sub-Division

Umiam Rural Distribution Sub-Division

\*Village Name

Pyllun

\*State

Meghalaya \*City - Ribhoi (Nongpoh)

\*Area Pin code

793103

Locality

Pyllun

\*Full Address

Pyllun

Smt. E. Surangi  
Please  
necessary  
action

Super Engineer,  
Umiam Distribution Sub-Division  
Ma. P.D.C.L. Umiam

## New Connection Details

\*Product Type

LT/HT/EHT (Please tick one) \*Consumer type - SG/CG/NG (Please tick one)

\*Connection Type

Commercial

(Select anyone below)

Agriculture/Commercial/Crematorium/Domestic/EV Charging Station/ Ferro Alloy/General

Purpose/ Industrial/Kutir Jyoti(BPL)/Public Lighting/ Public Water Supply/Special Tariff

\*Area Type

Urban / Rural (Please tick one)

\*Activity

Shop

\*Contract Load Unit

KW / KVA (Please tick one)

\*Contract Load

6KW

## Payment Details

\*Scheme

All Categories excluding Industrial/Industrial/Free Scheme (Please tick one)

\*Sub Scheme

One Time Connection - Rs. 200/-

Mode of Payment

Cash / Cheque / DD/RTGS (Please tick one)

Payment Amount

DD/RTGS/Cheque No.

DD/RTGS/Cheque Date

IFSC Code

Bank Name

If fields mark with \* are mandatory

Additional 6KW

Annexure - 1

20 meters  
Transformer  
63 K.V.A

Meghalaya Power Distribution Corporation Limited  
Application form for providing LT Service Connection  
(for all categories and for all purposes)

To

The Area Manager / Asst. Executive Engineer  
Service Connection Sub-Division / UR Distribution Sub-Division  
Meghalaya Power Distribution Corporation Limited  
Umiam.  
(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

I / We hereby request you to supply electricity to the premises located at the address fully described below:

I / We agree to abide by the terms and conditions relating to the supply of electricity by MePDCL and to make all payments as may be required and also to pay regularly all the charges as may become due.

(a) Full name and address of the applicant with contact telephone number, Mobile Number,

E-Mail

9233323204

(b) Status in relation to the premises

Owner



Occupier



(c) Location and address of the premises including Police Station

Pyllun

(d) Nature of LT supply

Commercial



Domestic



Industrial



General purpose



WSLT



Public lighting



Agriculture



KJ



MeECL employee



DATE:

27/9/23

Assistant Executive Engineer  
Umiam Rural Distribution Sub-Division  
MePDCL, Umiam

Applicant's Signature

CHH

6KW Load Sanction from  
Pyllun 03 KVA S/S

Agreement for supply of electricity Low Tension



An agreement made this the 25<sup>th</sup> day of Sept of 2023 between \_\_\_\_\_ and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution Utility / MePDCL) of the other part.

Note: the term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereinafter appearing;

Now, therefore, the agreement witness –

- (1) That the supply shall be given to the premises located at Pyllun with the consumer as owner / occupier of;
- (2) That the supply shall be for the purpose of CLT  
The load whereof shall not exceed 6000 watts
- (3) That the provisions of the EA 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike;
- (4) That the consumer shall regularly and timely pay to MePDCL all charges as may be due for the supply of electricity;
- (5) That the agreement shall be a period of two years and may be renewed for a further period;  
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- (6) That the agreement shall be terminated if he consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or, on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

51

Provided that on the part of the MOPDCA, notice shall be given to the consumer signing the contract for the proposed termination and giving him opportunity to state his case and his statement, if any, duly considered before the agreement is terminated and the supply of electricity cut off.

(2) The terms and conditions of this agreement shall be effective from the date of supply of electricity to consumer.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

  
Consumer

For and behalf of MOPDCA,

Witness

1. Signature

Name

Address

2. Signature

Name

Address



**Meghalaya Power Distribution Corporation Limited**  
**Test Report (LT Supply)**

Annexure - 5

To, \_\_\_\_\_  
The \_\_\_\_\_

This is to certify that repaired/renewed/additional/new electric installation at the premises of

Full name

**P H Y R N A I L I N C H Y R M A N G**

(Please leave one block between name & surname)

Address

**P Y L L U N**

1. The load has been arranged as follows:

Details of load	Wattage of each item	Phase I		Phase II		Phase III		Total wattage of all 3 phases
		No. of points	Total wattage	No. of points	Total wattage	No. of points	Total wattage	
1. Light points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others LED	9watt	10	90	10	90	10	90	270watt
2. Fan points								
3. Plug points (3-Pin)								
(i) 6 Amps	100watt	5	500	5	500	5	500	1500watt
(ii) 16 Amps	1000	1	1000	1	1000			2000watt
4. Electrical gadgets								
(i) Water Heater (Geyser)	2000					1	2000	2000watt
(ii) Refrigerator								
(iii) AC								
(iv) Others								
5. Welding transformer								
6. Motor								
Total		1590	1590 watt	1590	1590 watt			2590 5770watt
In case of load enhancement existing load (in watts)								

Total load in the premises (in watts)									6kw
---------------------------------------	--	--	--	--	--	--	--	--	-----

Notes:  
 (a) Details of any apparatus (other than the above mentioned) should be given.  
 (b) Rating of capacitor used in induction Motor and welding Transformer (Test report of capacitor is to be enclosed)

KVAR

- II. Type of wiring *Cabling Capping*
- III. Voltage and system of supply *230 Vlt*

IV. Test Result

Date of testing by licensed contractor

2	5	/	0	9	/	2	3
---	---	---	---	---	---	---	---

	Type of test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant Cea regulations, (in MΩ) / Ω
(a)	Insulation resistance between earth and whole system of conductor	$P_1 - E$ $P_2 - E$ $P_3 - E$	40 mΩ
(b)	Insulation resistance between all conductors	$P_1 - P_2$ $P_2 - P_3$ $P_3 - P_1$	47 mΩ
(c)	Earth continuity between earth electrode and earth continuity conductor	0.2 Ω	0.2 Ω
(d)	Polarity of non-linked SP switches	Phase	Φ.

✓ Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.

*S. Khongbuh*  
 Govt. Electrical & Civil Contractor  
 Regd. No. 1183

VI. Full name with signature of supervisor (with date)

LIC No.

Mobile No.

VII. Full name with signature of wireman (with date)

LIC No.

Mobile No.

VIII. Signature of the authorized official who

tested the installation on behalf of supplier (with date)

Mobile No.

6419

*[Signature]*  
 Electrical Engineer  
 Regd. No. 1191

IX. Date of connection of supply to the installation



Gender : Female  
Date of Birth/ Age : 12-01-1985

Address : HNo.102, DYMMIEW, VILL-SHILLONG,  
DIST-EAST KHASI HILLS-793002

Date : 20-06-2019  
Electoral Registration Officer

Assembly Constituency No. and Name : 18-WEST SHILLONG

Part No. and Name : 11-DYMMIEW B

नोट / Note :

1. इस कार्ड को धारण करने मात्र से यह कोई गारंटी नहीं है कि आप वर्तमान निर्वाचक नामावली में निर्वाचक हैं। कृपया अपना नाम प्रत्येक चुनाव से पहले वर्तमान नामावली में जांच लें।  
Mere possession of this card is no guarantee that you are elector of the current electoral roll. Please check your name in the current electoral roll before every election.

2. इस कार्ड में उल्लिखित जानकारी को निर्वाचक नामावली में पंजीकरण के अलावा अन्य किसी भी स्थिति में आयु के प्रमाण के रूप में नहीं माना जाएगा।  
Date of Birth mentioned in this card shall not be treated as a proof of age/D.O.B. for any purpose other than registration in electoral roll.

Attested  
CHH



# DORBAR SHNONG PYLLUN

RAID MAWBUH, MYLLIEM SYIEMSHIP  
P.O. UMIAM 793103, RI BHOI DISTRICT

Date 05<sup>th</sup> May 2012

## DEED OF GIFT

I, ka Tyngshainlin Chyrmang daughter of ka (Late) Briancy Chyrmang and U (Late) Phrun Kyndiah at present residing at Dymmiew, Shillong out of my own free will and as a token of love and in good health and in full possession of my senses do hereby make a gift of a portion of my land situated at Pyllun Village, Raid Mawbuh, Myllem Syiemship, Ri-Bhoi District to my sister Dr. Phyrnailin Chyrmang.

The boundary of the land and its area are as follows:-

North :- Land of <sup>(L)</sup> Kher Shylla  
West :- Land of ka Tyngshainlin Chyrmang  
South :- Shillong Bye Pass Road  
East :- Land of ka Sunarin Chyrmang  
The total area is 5087.253 sq. ft. mt.

The condition of my gift of this portion of my land is Dr. Phyrnailin Chyrmang shall be the sole owner of the plot of land gifted to her and she has every right to utilize it in any manner she likes. There should not be any one to question the rightful ownership of my sister over the said land.

In confirmation of the above gift I put my signature below, in the presence of the village head and representatives as the witnesses here under.

1. Shri. Melansius Warbah - Headman.
2. Shri. Anthony Passah - Secretary.
3. Shri. Wellborn Rynjah - Executive Members

*(Signature of Headman)*  
*(Signature of Secretary)*  
*(Signature of Executive Members)*  
w. Rynjah  
RI BHOI DISTRICT

I, Ka Dr. Phyrnailin Chyrmang do hereby accepted with gratitude the above mentioned gift of my youngest sister @ of Rs. \_\_\_\_\_ p. sqft.

Tyngshainlin Chyrmang (Doner)

Dr. Phyrnailin Chyrmang (Donee)

*Attested*  
*(Signature)*

*(Signature)*





# DORBAR SHNONG PYLLUN

RAID MAWBUH, MYLLIEM SYIEMSHIP  
P.O. UMIAM 793103, RI BHOI DISTRICT

Ref No

Date

## TO WHOM IT MAY CONCERN

Certified that Phyrnailin Chyrmang daughter of ( Late ) Phrun Kyndiah is the legal and sole owner of a plot of land situated at Pyllun Village, Block-3, Shillong Bye pass Road, Raid Mawbuh Mylliemyiemship, Ri Bhoi district. The scheduled of boundaries of the said landed property is morefully and specifically described as under.

NORTH : Land of Late Kher Shylla.

SOUTH : Shillong Byepass.

EAST : Land of Ka Sumarlin Chyrmang.

WEST : Land of Ka Tyngshainlin Chyrmang

This certificate is issued by the Dorbar Shnong Pyllun, Raid Mawbuh, Mylliemyiemship, that it has got no Objection to the said Mrs. Phyrnailin Chyrmang to take loan and mortgage the said landed property in any financial institution.

Secretary  
Shnong Pyllun  
Mawbuh  
Ri Bhoi District

Attested  
CHT



Headman

Kangbah Shnong  
Dorbar Shnong Pyllun  
Raid Mawbuh  
Mylliemyiemship

# Meghalaya Power Distribution Corporation Limited

CONSUMER ID  
1000621056

PHYMAILIN CHYRMANG  
PHYMAILIN 703103  
Mobile No : 9250051041

BILL DATE  
22-Sep-2023

DUE DATE  
29-Sep-2023

NET BILL AMOUNT  
₹ -1068.00

To avoid inconvenience,  
Kindly pay your bill timely.



For complaints/ query, Please contact to nearest  
Division/ sub-division.

LINKARA DIVISION / LINKARA SUB-DIVISION

Bill Number 500100007451  
Category Consumer ID  
C. Demand/Load 1.000 KW  
Meter No. 501002156  
DMS 1.00  
No. of Days 65  
RTI Basis OK  
Category CAT

## CONSUMPTION DETAILS

### PREV READING

Prev. Reading Date : 21-Jul-2023  
Prev KWH : 864.000  
Prev KVAr : 0.000

### CURRENT READING

Cur. Reading Date : 22-Sep-2023  
Current KWH : 1295.000  
Current KVAr : 0.000

### OTHER READING

Req. Demand KW :  
Req. Demand KVA :

Billed Unit : 431.000  
Billed Demand : 2.000

## MISCELLANEOUS

Last Payment Date : 05-Jul-2023  
Last Payment Amount : ₹ 3805.00  
Payment Amount : ₹ 0.00  
Security Amt Deposited : 9252.00  
Connection Type : NG

Consumer Type : Commercial(LT)  
Connection Location : Rural

## CHARGES DETAILS (IN RUPEES)

Energy Charge	3135.00
Fixed Charge	140.00
ED Amount	25.86
FPPRA Charges	0.00
Minor Rent	0.00
TMC	0.00
OPC	0.00
Current Bill Amt	3744.66
Prev Outstanding	₹ -4812.80
Gross Bill Amount	₹ -1068.14

Download App from Google Playstore



Me PDC

LIGHTING UP YOUR LIFE

**SAVE ENERGY SAVE MONEY  
SAVE THE PLANET**

Turn off the lights before leaving...

**Megha Power App**

View electricity bill, Make payment, Know your daily  
consumption, Trust billing, Raise complaint &  
Apply for new connection and many more...



Cheque should not be post dated and please mention A/c No. as well  
on the back of the Cheque/DD.

This bill will be construed as final notice under Section 9.2 of MSERC (Electricity Supply Code) Regulations, 2018. Supply of electricity shall be  
disconnected at any date, if dues of Electricity bill is not paid within 15 (fifteen) days (notice period) after due date of the bill.

X



Cheque should not be post dated and please Mention A/c No.  
as well on the back of the Cheque/ DD.

Signature :

Consumer Id  
000621056

Consumer Name  
Phymailin Chyrmang

Net Bill Amount  
-1068.00

Paid Amount

Paid Date

**SECURE**

## ROUTINE TEST REPORT

Serial Number: SS21625017

Customer: R.K. TRADING CO.

Customer P.O Number: RKTC/PO/Secure Meters/2023 - 24/011

Customer P.O Date: 27-JUN-2023

Voltage: 240V

Current: 10-100A

Accuracy Class: 1.0

Ref. Standard: IS : 13779

Meter Constant: 1600

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions:  $V_{ref} = 240V/50Hz$   $I_b = 10-100A$  Amb. Temp =  $27 \pm 2$  Deg. C

## METER ACCURACY

% Active Import Errors

% Reactive Import Errors


Load % $I_b$	0.5 Lag	0.8 Lead	UPF
1000	0.0	0.1	0.1
100	0.0	0.1	0.1
10	0.2	0.0	0.1
5			0.1


Load % $I_b$	0.5 Lag	0.8 Lead
1000	0.1	0.1
100	0.1	0.1
10	0.0	0.0

000000 4.0

TEST DATE: 31-05-2023

This is computer generated test report no signature required

  
Meter Tester Gr - I  
MTI Laboratory  
MePDCL, Lumjingshal  
Shillong

  
(Y. Passah)  
Assistant Engineer  
MTI Lab  
MePDCL, Shillong.