

Uttarakhand Energy Power Distribution Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

MANO SHA DEKHAR

(Please leave one block between name & surname)

(Full Name)

SOH KYNDUR

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each Item	No. of points		Total Watt		No. of points		Total Watt		Total watt of all 3 phases
		No. of points	Total Watt	No. of points	Total Watt	No. of points	Total Watt	No. of points	Total Watt	
1. Light points										
(i) Fluorescent										
(ii) Incandescent										
(iii) CFL										
(iv) Halogen										
(v) Others / LED	9Wt	5 Nos	45Wt							
2. Fan points										
3. Plug points (3-pin)										
(i) 6 Amps	100Wt	2 Nos	200Wt							
(ii) 16 Amps	1000Wt	1 No	1000Wt							
4. Electrical gadgets										
(i) Water Heater (Geyser)										
(ii) Refrigerator										
(iii) Air Conditioner										
(iv) Others										
5. Welding Transformer										
6. Motor										
Total			1245Wt							
In case of load enhancement										
Existing load (in watts)										
Total load in premises (in watts)										

Notes :-

- Details of any apparatus (other than the above mentioned) should be given.
- Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed)

KVAR

II. Type of wiring

Cabling Capping

III. Voltage and system of supply

220V/1φ

IV. Test Result:

OK

Date of Testing by Licensed Contractor:

26/07/23

Type of Test	Result of test carried out by licensed contractor (In MΩ) /Ω	Result of test carried out by Supplier under relevant IE Rules, in (MΩ) /Ω
a. Insulation resistance between earth and whole system of conductor	105 MΩ	
b. Insulation resistance between all conductors	108 MΩ	
c. Earth continuity between earth electrode and earth continuity conductor	3Ω	
d. Polarity of non-linked SP switches	0Ω (PN-220) EN-0V	

V. Full Name with signature of Licensed contractor

LIC No.

S. Wahlang
Electrical Contractor

VI. Full Name with signature of supervisor
(with date)

LIC No.

Regd. No. 383

VII. Full Name with signature of wireman
(with date)

PERMIT No. :

K. Nongshet
Electrical Supervisor

Regd No. 1028

VIII. Signature of the authorized official who tested
The installation on behalf of supplier

S. Wahlang
Electrical Wireman

Regd. No. 2468

IX. Date of connection of supply to the installation

X. Date of Commencement of work