



ISO: 9001: 2015. & ISO 14001: 2015.

HPL Electric & Power Ltd.

TEST CERTIFICATE

ITEM : Single Phase Static Watthour Meter

METER SL. NO. : 1107285

RATING : 5-30A 240V, 50Hz

CLASS : 1.0
METER

CONSTANT : 6400 Impulses per kWh

STANDARD : IS 13779 :1999

The Meter was tested & has passed following routine tests as per IS: 13779 at reference conditions:

	TEST	RESULT
01	No-Load Conditions	Passed
02	AC Voltage Test	Passed
03	Insulation Resistance Test	Passed
04	Starting Test	Passed
05	Meter Accuracy Test	Passed Meter Accuracy Observed within $\pm 1\%$

Initial Reading

00001

CERTIFIED

Signature:

Date: 30/09/2023

Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong

(Y. Passah)
Assistant Engineer
MTI Lab
MePDCL, Shillong.

Book No.

073



Sl. No.

3637



GARO HILLS AUTONOMOUS DISTRICT COUNCIL, TURA
OFFICE OF THE A-KING NOKMA,
WEST/EAST/SOUTH/SOUTH-WEST/NORTH GARO HILLS

A-KING NOKMANI A-ANA SEE ON-ANI

Anga Shri / Smt. Melji Ch. Marak

A-kingni Nokma ka-mao sima-arirang baksa mesokgipa a-ako Shri/Smt Patish Sangma

Son/Daughter of Shri Edosing G. Momini

Song Damalgre P.O. Damalgre P.S. Damalgre

District East / West / South Garo Hills na nokap / apal / bagan-bari dake dongchina uni kanggipa
ba occupy ka-gipa a-ako Garo Hills Autonomous District Council- Patta dake ra-china kusi
ong-e been bimang an-senge see-jote on-enga.

Anga iako chra-depante, Mahari aro sakirangni mikkango uamangni soirang baksa
champengani grian see-jote on-enga aro mikkangchi anga mamungba kangpilani dongjawa.

A-ani Sima-arirang:-

1. Salgrochi Tura to Garobadhe Road
2. Salgipengchi Shri Rambang G. Momini's
3. Salaramchi Son. Nitish Momini's
4. Saliramchi Sorok

Approx. A-ani dal-a 07 B 04 K 10 Ls.

A-ani biap Lower Damalgre, 8/6 Garo Hills

Nokma me-asani soi _____

Nokma me-chikni soi Amak
Damalgre A-kingland

Nokma No. 01 Elaka No. 11-10

(Nokma Seal)

Nokma II-10 (01)

Damalgre A-king


8/6, West Garo Hills

Chra-depanterangni soi:-

1. Chalangkuth Marak
2. _____
3. _____

भारत निर्वाचन आयोग
ELECTION COMMISSION OF INDIA
मतदाता फोटो पहचान कार्ड - ELECTOR PHOTO IDENTITY CARD

BNK0665430



NAME : **PAILISH SANGMA**

HUSBAND'S NAME : **SUNIL SANGMA**

SEX : **FEMALE**
DATE OF BIRTH/AGE : **09/06/1968**
ADDRESS : **335, AJIREGRE, AJIREGRE, WEST GARO HILLS, 794014**

S. Sangma

Date : 10/12/2013 Electoral Registration Officer.

AC No & Name : **49-DADENGRE**
Part No & Name : **3-DILSIGRE**

नोट / Note :-
1. इस कार्ड को धारण करने मात्र से यह कोई गारंटी नहीं है कि आप वर्तमान निर्वाचक नामावली में निर्वाचक हैं। कृपया आगामी आम प्रत्येक चुनाव से पहले वर्तमान नामावली में जांच लें।
(Mere possession of this card is no guarantee that you are elector in the current electoral roll. Please check your name in the current electoral roll before every election.)
2. इस कार्ड में उल्लिखित सम्मति को निर्वाचक नामावली में परिवर्तन के अभाव में अन्य किसी भी समिति में आगु के इस्तेमाल के रूप में नहीं माना जाएगा।
(Date of Birth mentioned in this Card shall not be treated as proof of age / D.O.B. for any purpose other than registration in electoral roll.)

Pailish Sangma



भारत सरकार

Government of India

Pailish S Sangma

DOB: 09/06/1968

Female

8137 6815 3794



मेरा आधार, मेरी पहचान



भारतीय विशिष्ट पहचान प्राधिकरण

Unique Identification Authority of India

Address: W/O: Sunil A Sangma,
DADENG AJIGRE, Dadenggre,
West Garo Hills, Jorhat,
Meghalaya, 794104

8137 6815 3794



1947



help@uidai.gov.in

www

www.uidai.gov.in

Pailish Sangma

APPENDIX - I

Form of application for supply of electricity at Low Tension / High tension

To,

The S.D.O Me. P. D. C. L (Elec)
P.O Garobadha
Dist. West Garo Hills Meghalaya

Sir,

I/We request you to supply electricity at Low Tension/High Tension to my/our premises situated at Damalgre

The requisite information is furnished below :-

- i) Name of the applicant (consumer)
- ii) Address for communication.
- iii) Status of the consumer (applicant should state the legal status i.e. whether he is an individual owner or lawful occupant of the premises for which the supply is required, partnership firm or limited company or any other local person and in case of partnership firm it should be stated whether it is registered, or unregistered, location of its head office, names and address of all partners and a copy of the partnership deed should be filled. In case of company it should be stated whether it is a Private Ltd. or Public Ltd. names of present Directors and a copy of the memorandum of articles of association should be furnished. In case of any other type of articles of association should be furnished. In case of any other type of local person, full details and name and address of the person, competent to represent the consumer should be stated.
- iv) Location of the premises where supply is required Damalgre
- v) Character of Supply 230 volt AC 6 phase
- vi) Purpose for which supply is required Commercial
- vii) Contracted load 2290 Watt
- viii) Details of the concerned load (The consumer should furnish the requirement for a period not less than 2 years and preferably for a period of 5 years)

Pailish Sangma
P.O. Vill Damalgre
Dist. West Garo Hills

$L.P. = 5 \times 604 = 3020$
 $P.P. = 2 \times 1024 = 2048$
 $F.P. = 2 \times 1024 = 2048$
 $Power = 3 \times 7524 = 22572$
Total = 29584

2. I/We hereby agree to take supply and to pay all charges such as for energy, service connection and other dues including deposit of such security as may be demanded in accordance with the rates and conditions of supply of the Board in force from time to time. I/We further declare and agree to take supply of electric power for the above-mentioned purpose for a period of not less than 2 years from the date of commencement of supply and, in case of reconnection of supply after a period of 6 months from the date of disconnection for not less than one year from the date of re-connection.
3. I/We also undertake to receive supply within 3 months from the date of Board intimates that it is ready to give supply to our premises failing which I/We undertake to pay the Board the minimum charges as may be applicable.
4. This application is for
 - a) A new service connection Yes
 - b) Re-connection X
 - c) Alteration to may existing installation X
 - d) Temporary Service Connection X
 - e) Change of Service Connection in the name of X

APPENDIX - II
AGREEMENT FOR SUPPLY AT LOW TENSION

Agreement executed this _____ day of _____ 20____ by _____
for themselves/ himself/herself/itself and for their/his/ her/ its assigns and successor of the Meghalaya State Electricity Board statutory corporation constituted under Section 5 of the Electricity (Supply) Act, 1948 and its successor and assigns hereinafter called the BOARD.

2. SUPPLY OF POWER

I/We the above mentioned have requested the Board to supply electricity at High Tension for the purpose of Commercial and the Meghalaya State Electricity Board has agreed to afford such supply Act on the terms and conditions notified by them from time to time under Section 49 of the Electricity (Supply) Act, 1948 and those herein contained.

Details of Supply

- a) Purpose Commercial
b) Category 23000T A/c sphere

3. LOAD

I/We agree to take from Meghalaya State Electricity Board electric power for a load not exceeding 23000T A/c HP/KW for exclusive use for the purpose as mentioned above at our mills/factory/premises situated at Damalgre

The contract demand agreed between the Board and myself/ourselves are _____ KW/ HP for the first year 2295040th KW/HP for 2 year.

4. OBLIGATION TO COMPLY WITH REQUIREMENT OF ACTS, RULES, TERMS AND CONDITIONS OF SUPPLY :

I/We further undertake to comply with all the requirements of the Indian Electricity Act, 1940, the Electricity (Supply) Act, 1948, the rules thereunder, the provisions of the Schedule of Miscellaneous charges, the terms and conditions of supply prescribed by the Board from time to time and not to dispute the same.

5. DATE OF COMING INTO FORCE OF THE AGREEMENT :

I/ We undertake to receive the supply within 3 months from the date the Board intimates that it is ready to give the supply to my/our premises, failing which I/We undertake to pay the Board the minimum charges as may be applicable and decided by the Board, further the provisions of the contracts shall be deemed to have come force into from the date of commencement of the supply or the date of expiry of 3 months notice above referred to whichever is earlier.

6. PERIOD OF AGREEMENT

I/We undertake to avail supply for a minimum period of 2 years from the date of this agreement has come into force.

7. DETERMINATION OF THE AGREEMENT

I/We shall be at liberty to determine the contract by giving in writing one month's notice expressing such intentions at any time after the expiry of 2 years. I/We agree that Meghalaya State Electricity Board may terminate the contract at any time giving 7 days notice if I/We violate the terms of this agreement and the terms and conditions of supply notified by the Meghalaya State Electricity Board from time to time or provisions of any law touching this agreement including the Electricity (Supply) Actm 1948 the Indian Electricity Act, 1910

Notice of commencement of works

The Inspector of Electricity
Meghalaya, Shillong

From

M/S. Modern Electrical House
Halliday Ganj
West Garo Hills, Meghalaya
Regd. No. 428

TED

es of

Subject :- Notice of commencement of works under clause 36 of Rules and
condition prescribed under Rule 45 (1) of India Electricity Rules, 1956

Sir,

I have the honour to inform you that Addition/ Alternation/ Repair New Electricity installation
will be executed by me/us in the undermentione premises and the particulars are stated below.

1. Owner of premises :- Name :- Pailish Sangma
Address :- Damalgre
P.O. :- Damalgre Dist :- West Garo Hills

2. Number of points	Nos	Watts	Total Wattage
i) Light points	5 x	60W	300W
ii) Plug point	2 x	100W	200 "
iii) Fan point	2 x	100W	200 "
ii) Plug point			
ii) Power plug	3 x	750W	2250W
ii) Other apperatus			2950W

3. Type of Wiring :- Lapping

4. Date of commencement :- 08/11/24

5. Name of supervisor :- A.F. Hoque
Regd. No. 670

6. Name of Wireman

i) Bijendra Paul

ii)

Regd. No. 2308

Yours faithfully

ATL

M/S. Modern Electrical House
Hallydayganj
Regd. No. 428

Copy to :-

The S.D.O. (Elect.)

Me. P.D.C.L

Grobaths

TOTAL	2950W
In Case of load enhancement	
Existing load	
Total load in premises	

Notes :

- Details of any apparatus (other than the above mentioned) should be given
- Rating of capacitor used in Induction Motor and welding Transformer (Test report of capacitor is to be enclosed.

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED

TEST REPORT

This is to certify that repaired / renewed / additional / new electric installation at the premises of

P A I L I S H S A N G M A

(Full Name)

P O + V I L L D A M A L G R E

(Address) Dist West Garo Hills

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total Watt of all 3 phases
		No. of Points	Total Watt	No. of Points	Total Watt	No. of Points	Total Watt	
1. Light Points	60W x	5 No	300W					
i) Fluorescent								
ii) Incandescent								
iii) CFL								
iv) Halogen								
v) Others								
2. Fan Points	150W x	2 No	300W					
3. Plug Points (3-pin)								
i) 6 Amps	100W x	2 No	200W					
ii) 16 Amps	750W x	3 No	2250W					
4. Electrical gadgets								
i) Water Heater (Geyser)								
ii) Refrigerator								
iii) Air Conditioner								
iv) Others								
5. Welding Transformer								
6. Motor								
TOTAL			2950W					
In Case of load enhancement								
Existing load								
Total load in premises								

Notes :

- Details of any apparatus (other than the above mentioned) should be given
- Rating of capacitor used in Induction Motor and welding Transformer (Test report of capacitor is to be enclosed).

- I. System of Wiring Looping
- II. Type of Wiring
- III. Voltage and system of supply
- IV. Test Result :

Date of Testing by Licensed Contractor : 12/11/24

Type of Test	Result of test carried out by licensed contractor in (M Ω) / Ω	Result of test carried out by the supplier under relevant IE Rules in (M Ω) / Ω
a. Insulation resistance between earth and whole system of conductor.		
b. Insulation resistance between all conductor.		
c. Earth continuity between earth electrode and earth continuity conductor.	14 mesh	
d. Polarity of non-linked SP switches.	at phase	

V. Full Name with signature of Licensed contractor : Atique Abul Fozal Hoque
LIC No.: MODERN ELECTRICAL HOUSE
Hallinamangal, West 1104
Regn. No. 423
West Ganga Hills, Megh.

VI. Full Name with Signature of Supervisor (With date): Atique Abul Fozal Hoque
LIC No.: 12/11/24
Regn. No. 670

VII. Full Name with Signature of Wireman (With date):
PERMIT No.: 141697 Area 2303
12/11/24

VIII. Signature of the authorized official who tested the
installation on behalf of supplier.

IX. Date of connection of supply to the installation :