

ISO: 9001: 2015. & ISO 14001: 2015.
HPL Electric & Power Ltd.

TEST CERTIFICATE

ITEM : Single Phase Static Watthour Meter
METER SL. NO. : 1750172
RATING : 5-30A 240V, 50Hz
CLASS : 1.0
METER CONSTANT : 6400 Impulses per kWh
STANDARD : IS 13779 :1999

The Meter was tested & has passed following routine tests as per IS: 13779 at reference conditions:

	TEST	RESULT
01	No-Load Conditions	Passed
02	AC Voltage Test	Passed
03	Insulation Resistance Test	Passed
04	Starting Test	Passed
05	Meter Accuracy Test	Passed Meter Accuracy Observed within $\pm 1\%$

Initial Reading


00001

CERTIFIED

Signature: 

Date: 10/01/2025


Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshai
Shillong


Executive Engineer
MTI Division
MePDCL, Shillong