

1287

ADDITIONAL/SUB-METER

Personal Details

*Application No _____
 *Consumer Name Balensha: hadia:
 *Father's Name / husband SD Sang ma:
 *Mobile No 8416068054:
 Aadhar No / epicard No. DH20508408:

Address Details

*Accommodation Own/ Rented (Please tick on)
 *Discom Meghalaya Power Distribution Corporation
 *Zone Eastern Zone *Circle Ribhoi Circle *Division Umiam Division
 *Sub-Division umiam Distri bution: Sub Division:
 *Village Name Nongsdor Block1:
 *State Meghalaya *City Ribhoi (Nongpoh)
 *Area Pin Code 793103 Locality _____
 *Full Address Nongsdor: Block1:

New Connection Details

*Product Type LT/HT/EHT (Please tick one) *Consumer type 5G/CG/NG (Please tick one)
 *Connection Type DLT (Select any one below)

Agriculture/Commercial/Crematorium/Domestic/EV-Charging Station/Ferro Alloy/General

Purpose/Industrial/Kutir Jyoti (BPL)/Public Lighting/Public Water Supply/Special Tariff

*Area Type Urban/Rural (Please tick one)
 *Activity House
 *Contract Load Unit KW/KVA (Please tick one)
 *Contract Load 2 KW:

please take necessary action
Smt E Seelangi
[Signature]
 2018/24
 Junior Engineer
 Umiam District Sub Division
 Mr. R. D. C. L. [Signature]

Payment Details

*Scheme All Categories excluding industrial/industrial/Free Scheme (Please tick one)
 *Sub Scheme _____

One Time Connection - Rs. 200/-

Mode of Payment - Cash/ Cheque/DD/RTGS (Please tick one)

Payment Amount

DD/RTGS/Cheque No.

DD/RTGS/Cheque Date

IFSC Code

Bank Name

All fields with * are mandatory

Additional Matter
Customer Id - 1000198472

Meghalaya Power Distribution Corporation Limited
Application form for providing LT Service Connection
(for all categories and for all purposes)

Annexure - 1

Transformer - 250 KVA
Distance - 5 meter

L.M. Singh

To

The Area Manager / Asst. Executive Engineer
Service Connection Sub-Division / _____ Distribution Sub-Division
Meghalaya Power Distribution Corporation Limited

(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

I / We hereby request you to supply electricity to the premises located at the address fully described below:

I / We agree to abide by the terms and conditions relating to the supply of electricity by MePDCL and to make all payments as may be required and also to pay regularly all the charges as may become due.

(a) Full name and address of the applicant with contact telephone number. Mobile Number
E-Mail 8416068654

(b) Status in relation to the premises

Owner ☒ Occupier ☐

(c) Location and address of the premises including Police Station

Nangsdor, block-1 - Ribhoi, Umiam P.S

(d) Nature of LT supply

Commercial ☐

Domestic ☒

Industrial ☐

General purpose ☐

WSLT ☐

Public lighting ☐

Agriculture ☐

KJ ☐

MeECL employee ☐

B. Hadia
Applicant's Signature

Sanctioned for 250 KVA txr
Nangsdor block 1
21/8/24
Junior Engineer
Distribution Sub Division-I
MePDCL Umiam

Consumer ID : 1000198472
Legacy Consumer Id : 48030059781
Bill Number : E00290985506
Consumer Name : Balensha Hadia
Address : Nongsder, Nongsder Village #3
C.Demand/Load : 1.0 KW
Category : DLT
Bill Basis : De
Meter No : 169868
OMF : 1.0
Prev. Reading Date : 04-Oct-2023
Curr. Reading Date : 04-Nov-2023
Bill Date : 04-Nov-2023 09:44
No. of Days : 31
Prev KWH : 20268.000
Current KWH : 20268.0
Add. KWH : 0.0
Billed Unit : 0.0
Energy Charges : 0.0
Fixed Charge : 82.67
FPPPA Charges : 0.0
Rebate : 0.0
Meter Rent : 0.0
DPC : 0.0
Current Bill Amt : 82.67
Prev Outstanding : -0.52
Payment Amount : 219.0
Last Payment Date : 05-Oct-2023
Last Payment Amount : 115.0
Gross Bill Amount : 82.15
Net Bill Amount : 83.0

Power Distribu
form for provid
all categories a

st. Executive E

Division /

ibution Corpo

of the jurisd

supply ele

terms a

ments a

he appl

865

mises

pre

8-



Agreement for supply of electricity Low Tension

Annexure - 3

An agreement made this the 1 day of 8 of 2024 between Balinta and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution Utility / MePDCL) of the other part.

Note: the term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereinafter appearing;

Now, therefore, the agreement witness -

- (1) That the supply shall be given to the premises located at Nongstien with the consumer as owner / occupier of;
- (2) That the supply shall be for the purpose of DLT
The load whereof shall not exceed 2 KW watts
- (3) That the provisions of the EA 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike;
- (4) That the consumer shall regularly and timely pay to MePDCL all charges as may be due for the supply of electricity;
- (5) That the agreement shall be a period of two years and may be renewed for a further period;
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
-) That the agreement shall be terminated if he consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or, on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

Provided that on the part of the MePDCL notice shall be given to the consumer for reasons for the proposed termination and giving him opportunity to state his statement, if any duly considered before the agreement is terminated and the electricity cut off.

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the day of _____ month and year first above written.

B. Hadin
Consumer

For and behalf of MePDCL

Witness:

1. Signature:

Name:

Address:

2. Signature:

Name:

Address:

Meghalaya Power Distribution Corporation Limited
Test Report (LT Supply)

Annexure - 5

To,
The _____

This is to certify that repaired/renewed/additional/new electric installation at the premises of

Full name
BALENSHA HADIA

(Please leave one block between name & surname)

Address
NONGS DER VILLAGE

1. The load has been arranged as follows;

Details of load	Wattage of each item	Phase I		Phase II		Phase III		Total wattage of all 3 phases
		No. of points	Total wattage	No. of points	Total wattage	No. of points	Total wattage	
1. Light points								
(i) Fluorescent	40-watt	4-Nos.	160-watt					
(ii) Incandescent								
(iii) CFL/LED	9-watt	10-Nos	90-watt					
(iv) Halogen								
(v) Others								
2. Fan points	40-watt	3-Nos	120-watt					
3. Plug points (3-Pin)	100-watt	6-Nos.	600-watt					
(i) 6 Amps								
(ii) 16 Amps	1000-watt	1-Nos	1000-watt					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) AC								
(iv) Others								
5. Welding transformer								
6. Motor								
Total			1970 watt					
In case of load enhancement existing load (in watts)			1000-watt					

Notes: (in watts)

2970-watt

- (a) Details of any apparatus (other than the above mentioned) should be given
(b) Rating of capacitor used in induction Motor and welding Transformer (Test report of capacitor is to be enclosed)

II. Type of wiring *3pc loop system*
III. Voltage and system of supply *240 volt*

IV. Test Result

Date of testing by licensed contractor

08/07/2024

	Type of test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant Cea regulations (in MΩ) / Ω
(a)	Insulation resistance between earth and whole system of conductor	100 Ω	
(b)	Insulation resistance between all conductors	100 Ω	
(c)	Earth continuity between earth electrode and earth continuity conductor		
(d)	Polarity of non-linked SP switches		

V. Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.

VI. Full name with signature of supervisor (with date)

LIC No.

Mobile No.

VII. Full name with signature of wireman (with date)

LIC No.

Mobile No.

VIII. Signature of the authorized official who

tested the installation on behalf of supplier (with date)

Mobile No.


IX. Date of connection of supply to the installation

Mr. B. L. Nongbri
Mr. B. L. Nongbri
Electrical Contractor
License No-707

Mr. B. L. Nongbri
Mr. B. L. Nongbri
Electrical Supervisor
License No-1250

Mr. B. L. Nongbri
Mr. B. L. Nongbri
Electrical Wireman
License No-9015

KNAR



TWENTY RUPEES

20RS

KA DULIR KHYNDEW (SALE DEED).

Date 22/02/2003.

Ma Nga, U Stendro Wahlang, Uba shong basah ha Mawlai, Shillong, ha -
pdeng ka jingkoit jingkhish bad ka jingtip briew bha biang biang, Nga la ai
siew bailut noh ia ka jaka jong nga kaba don ha Nongshim, Raid Mawtuh, ha
phi Ka Salinsha Hadia, Ka lok U Suzit D. Sangma, Ka ba shong basah ha -
Uniam (Damsite) tang ha ka dor Rs.30,000/- (Laiphew hajar tyngka).

Ki Pud sawdong jong katei ka jaka ki long kumbe hazum :-

- 1. Shatei (North) :- KA LYNTI (BURUK) SHALONG. = 89 ft
- 2. Shathie (South) :- KA KPER (ING) KA PRISKA NONGRUM. = 50 ft
- 3. Mihngi (East) :- KA JAKA KA KONG TILAL SYIEMUNG. = 100 ft
- 4. Sapngi (West) :- KA JAKA/ING U BAH MARKES NONGRUM. = 148 ft

Ka jingheh kyllum jong katei ka jaka ka long kumbe 5,000 59 ft.

Ia ka pisa baroh kat kum katei ka dor, Nga U Nong ai siew bailut, Nga
la iohpdang lut mynta ka sngi kaba 22 tarik u Nymphang (February), 2003.
Kumta, naduh mynta hi ka sngi (22/02/03), katei ka jaka kan long noh ka -
Hok Long Trai jong phi Ka Nongshim siew bailut bad Nga ngen nym don hok ei
ei shuh ban dang dawa halor jongka; hynrei lada don kano kano ka jingujor
pyrshah ia ka jinglong trai jong phi la katei ka jaka, Nga hi ngen hap bah-
khlieh nadong shadong lane ngen hap pynphai noh ia ka jingsiew bai lutken
jongphi baroh.

Kum ka dak ka jingaiti hok jong nga ha phi la katei ka jaka, Nga -
Signed hangne ha khmat U Rangbah shnong bad ki Riew Rangbah jong ka shnong
kum ki s a k h i.

Attest / Sharyma

U/Ka Nongshim siew bai lut. U Nong ei siew bai lut.

K I S A K H I :-

T. NONGRUM -

S. LYNGDOH

R-P. MUKHIN

T. LYNTSEK

bph

S

Secret to
Durbar Shnong
No. 1206

Recommended

Rangbah Shnong
Nongrider
Raid Shnong
P.O. Uniam-783103

Meter Number: SS17270772
 Customer: M/S KAMTA ELECTRICALS
 P.O Number: MAMTA/23-24/005
 P.O Date: 21-SEP-2023
 Voltage: 240V
 Current: 05-30A
 Standard: IS : 13779
 Accuracy Class: 1.0
 Meter Constant: 6400

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions: $V_{ref} = 240V/50Hz$ $I_b = 05-30A$ Amb. Temp = 27 ± 2 Deg. C
 METER ACCURACY


% Active Import Errors

Load % I_b	0.5 Lag	0.8 Lead	UPF
600	0.4	0.0	0.0
100	0.2	0.0	0.0
10	0.2	0.0	0.0
5			0.0

00001.0

TEST DATE: 11/11/2023

This is computer generated test report no signature required


 Meter Tester Gr - I
 MTI Laboratory
 MePDCL, Lumjingshai
 Shillong


 (Y. Passah)
 Assistant Engineer
 MTI Lab
 MePDCL, Shillong.