



ROUTINE TEST REPORT

Serial Number: **SS17228558**

Customer: **M/S MAMTA ELECTRICALS**

Customer P.O Number: **MAMTA/23-24/003**

Customer P.O Date: **28-AUG-2023**

Voltage: **240V**

Current: **05-30A**

Accuracy Class: **1.0**

Ref. Standard: **IS : 13779**

Meter Constant: **6400**

1. AC VOLTAGE TEST: **PASS**

2. TEST OF NO LOAD CONDITION: **PASS**

3. TEST OF STARTING CURRENT: **PASS**

4. INSULATION TEST: **PASS**

5. METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz Ib = 05-30A Amb. Temp = 27 +/- 2 Deg. C

METER ACCURACY

% Active Import Errors


Load % Ib	0.5 Lag	0.8 Lead	UPF
600	0.2	0.0	0.0
100	0.0	0.0	0.0
10	0.0	0.0	0.0
5			0.0

00001.0

TEST DATE: 22-09-2023

This is computer generated test report no signature required


Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingsha
Shillong


(Y. Passah)
Assistant Engineer
MTI Lab
MePDCL, Shillong.