


Total demand of Rs 56,108.55 (Rs 1699.55 + 54409.00). (Rupees fifty six thousand one hundred eight and fifty five paise) only. Must be erase/delete from the consumer's bill as it has been explained in letter No MPPDCL / I & E / RBDC / T-01/2024-25/516 dated 14th November 2024 on account of inadvertent entry of the Maximum Demand, Revision for the same is permitted.


 19/12/24

Ref (20)

UMIAM RURAL DIST SUBDIVISION

Legacy Consumer ID	Consumer ID	Bill No	Billing Period	Bill Generated Date	Due Date	Disconnection Date
	1000620695	500298702796	19-Feb-2024 to 22-Mar-2024	22-Mar-2024 12:00	06-Apr-2024	22-Apr-2024

Name & Address: Eastern Ri Bhoi Organic F. Prod. Co. Ltd- Khapmara, Bhoirymbong	Type	LT	Meter No	MEB98202
	Category	ILT	Bill Type	OK (Normal)
	Sanction Load(KW)	15	Sanction Load(KVA)	0
	Connection Type	NG	Connection Status	INSERVICE
	Connection Location	RURAL		
	Monthly Average Units	239.29		

Meter Readings for New Meter ID: MEB98202 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	KvAh Meter	Recorded Demand	Recorded PF
Current Reading	22-03-2024	5176.9	6088.6	198.840	0.78
Previous Reading	19-02-2024	5071.1	5952.2		
No Of Days	32				
Difference		105.8	136.4		
Multiplying Factor		1	1	1	
Consumption		105.8	136.4		
Additional Units		0	0		
Meter Change Units		0	0		
Violation Energy Units		0	0		
Net Consumption		105.80	136.4	198.84	

Your Detailed Bill	
Description	Amount (Rs.)
Fixed Charges:	2,488.94
Energy Charges:	77.75
FPPAS	0
Electricity Duty:	6.82
Excess Demand Charges	1,699.55
Excess Energy Charges	54,409.00
TMC Charges	533.33
DPC	113.60
Current Bill Amount	59,328.99
Previous OutStanding	11,495.84
Gross Bill Amount	70,824.83
Net Bill Amount	70,825.00
AMOUNT IN WORDS	Seventy Thousand Eight Hundred and Twenty Five Rupees only
Due Date	06-04-2024
Last Payment Details	
Last Payment Date	21-12-2023
Last Payment Amount	4,861.00
Sd/-	
Asst Executive Engineer UMIAM RURAL DIST SUBDIVISION	

Save Energy for the Benefit of Self and Nation

This Bill will be Constructed as final notice under Section 9.2 of MSERC (Electricity Supply Code) Regulations, 2018. Supply of Electricity shall be disconnected at any date, if dues of Electricity bill is not paid within 15 (fifteen) days (notice period) after due date of the bill. Thanks for paying. We really appreciate it.

Phw: 9856 9855 98

Rory Anglue
Please check and revise
this bill as per inspection
by AEE, I & E.
6/4/24

EASTERN RI BHOI ORGANIC FARMER PRODUCER COMPANY LIMITED

KHAPMARA, LUMDAITKHLA,

PO BHOIRYMBONG, RI BHOI, MEGHALAYA-793116, INDIA.

Email : easternribhoiorganicfpc@gmail.com & rkharumnuid08@gmail.com

Contact details:08414926216:

Regn. No: CIN: U01100ML2017PTC013648 (Registered under Companies Act, 2013).



Date:30/05/2024

erbofpc/12/2019-20/194

To

The Assistant Executive Engineer
Umiam Rural Distribution Sub-Division
MePDCL, Umiam

Subject: Request for the Testing of Meter MRI

Sir/Madam,

In light of the subject mentioned therein, Eastern Ri Bhoi Organic Farmer Producer Company LTD are pleased to inform you that due to the rapid increasing of the Electricity Bill having a customer Id :1000620695 in the previous month so we request your kind office to send someone to test the meter as soon as possible so that the meter can be read correctly and the correct electric bills may be generated.

For **EASTERN RI BHOI ORGANIC FARMER PRODUCER COMPANY LIMITED**

Yours' Faithfully

Mr.REVISTAR KHARUMNUID
Chief Executive Officer



MePDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION,
RIBHOI DISTRIBUTION CIRCLE, UMIAM

No. MePDCL /I&E/RBDC/T-01/2024-25/516

Dated Uiam the 14th November, 2024

To,

The Assistant Executive Engineer
Uiam Rural Distribution Sub-Division
MePDCL, Uiam.

Sub: To revise the electricity bill of Eastern Ri Bhoi Organic F. Prod. Co. Ltd, Khapmara, Bhoiymbong (Cons. Id: 1000620695).

Ref. No: MePDCL/UDSD/T-15/2024-25/150

Dt. 10.09.2024

Madam,

This is to inform you that based on the complaint of skyrocketed electricity bills of Eastern Ri Bhoi Organic F. Prod. Co. Ltd, Khapmara, Bhoiymbong (Cons. Id: 1000620695) under reference No. above, the office of the undersigned has on the 8th October, 2024 inspected and tested the metering unit at the premises of Eastern Ri Bhoi Organic F. Prod. Co. Ltd, Khapmara, Bhoiymbong and found that the percentage error of the Consumer Billing Meter No. MEB98202 to be -0.27% (Test Report enclosed) which is below the permissible limit of (+/-) 1.0 % . On further investigation, the sudden jump in electricity bill was found to be due to Excess Demand/Excess Energy charges on account of wrong entry of Bill Maximum Demand (BMD) as 198.84KW instead of 1.98KW. Therefore, the electricity bills period of this consumer from 19-Feb-2024 to 22-Mar-2024 (32 days) generated on 22nd March, 2024 may please be revised and the BMD may please be corrected as 1.98KW instead of 198.84KW.

This is for favour of your kind information and necessary action.

Encl. Meter Test Report & BMD History.

Yours faithfully,

(Fullmoon L. Kynshi)

Assistant Executive Engineer

I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Uiam

No. MePDCL /I&E/RBDC/T-01/2024-25/516(a)

Dated Uiam the 14th November, 2024

Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Uiam for kind information.
2. The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
3. The Executive Engineer, Uiam Distribution Division, MePDCL, Uiam for kind information and necessary action.
4. The Executive Engineer, MTI Division, Shillong for kind information.
5. R/F.

ASSISTANT EXECUTIVE ENGINEER

Secure Meters Limited

Name Of Operator
Testing Standard
Date

: Name Of Operator
: Testing Standard
: 14-11-2024

Detail Error Report

Work File	lhghg.KFR
Date Time	08/10/2024 15:40
Record Number	2
Security	PASS
AccucheK Serial Number	MEB93016
Program Name	A57101A
AccucheK Range	LT, Clamp-On CT(500A)
Meter Under Test	MEB98202
Consumer Id	6400
Meter Constant	800.00 (Revs/kWh)
Number of Test Revolutions	50
PT Ratio	1.0000
CT Ratio	1.0000
Test Mode	Snap Switch In Start/Stop Mode
Test Duration	1 Min
App. calc. based on	Lag + Lead

Percentage Error

Error	Value
Active (Total)	-0.27 %
Reactive Lag	-----
Reactive Lead	-----
Apparent	-----

Energy Recorded

Energy	AccucheK+	MUT
Active (Total)	62.6704 Wh	62.5000 Wh
Reactive Lag	53.1760 VAh	-----
Reactive Lead	0.0000 VAh	-----
Apparent	82.2240 VAh	-----

Electrical Parameters (During Test)

Percentage Load	1.370 %
Power Factor	0.762 Lag
Active Load (Total)	3760.224 W
Reactive (Lag) Load	3190.560 VAr
Reactive (Lead) Load	0.000 VAr
Apparent Load	4933.440 VA

PageNo:1/2

[Signature] 14/11/2024
 ASSISTANT EXECUTIVE ENGINEER
 INVESTIGATION & ENFORCEMENT
 RICHOL DISTRIBUTION
 EPDCL, UMIA

Electrical Parameters (When Test Ended)

Frequency : 49.76 Hz

Phase	Voltage(V)	Line Current(A)	Reactive Current(A)
R Phase	241.70	7.900	5.100
Y Phase	241.57	8.000	6.000
B Phase	242.25	8.100	4.600

PageNo:2/2

[Signature] 14/11/2024
ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT,
RIBHOI DISTRIBUTION CIRCLE
MEPDCL, UMIAM

Search:

view Bill	Reading Date	Bill Number	Bill Source	Recorded BMD	Recor
	13/NOV/2024	223100524B130209	SBD-V3.3	1.08	
	18/OCT/2024	223100524A180229	SBD-V3.1	2.1	
	14/SEP/2024	2231005249140048	SBD-V2.6	5.84	
	09/AUG/2024	500308291027		5.74	0.
	11/JUL/2024	500306746428		1.74	0.
	21/JUN/2024	500306380947		1.74	0.
	18/APR/2024	500300711032		2.4	0.
	22/MAR/2024	500298702796		198.84	0.
	19/FEB/2024	500297046442		0	0.
	18/JAN/2024	500294713725		0	0.

Showing 1 to 10 of 11 entries

Previous 1 2 Next