



Me PDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM
Email: aecie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-96/2025-26/699

Dated Uiam the 27th November, 2025

To,

The Assistant Executive Engineer,
Uiam Distribution Sub-Division
MePDCL, Uiam.

Sub: Additional Units (kVAh) to be included into the electricity bills of M/S R.N.B.Carbides & Ferro Alloys. (Consumer Id.: 1000345358), MIDC, Uiam.

Sir,

As reported earlier, due to defected CT-PT Unit & poor quality of TTB, the undersigned has found discrepancy in the reading of then billing Meter No. MS5000060 of **M/S R.N.B.Carbides & Ferro Alloys. (Consumer Id.: 1000345358), MIDC, Uiam**. Billing for this consumer has already been done from Check Meter No. 4019009 till the arrangement of new and healthy 33 KV CT-PT unit & TTB is made. The undersigned would like to suggest that in all HT consumers, the quality of TTB should not be compromised. For instance, the existing HPL Make TTB that comes along with Smart Meter is of poor, inferior and sub-standard quality, it breaks when slightly tighten (many voltage missing issues happen at TTB). **Only Excellent and superior DAV Make TTB shall be used for all metering system.**

In light of the above to recover for the loss of energy due to defected CT-PT unit and low quality of TTB, **1095974.00 kVAh** of Additional Units may please be included into the electricity bill of this consumer in installments month wise **@136997.00 kVAh (or 123297.00 kWh) per month** starting from the month of December, 2025 as tabulated in the enclosed schedule.

This is for your kind information and necessary action.

Encl. Assessment of Additional Unit.

Yours faithfully,

(Fullmoon L. Kynshi)

Assistant Executive Engineer-Cum-Assessing Officer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Uiam

No. MePDCL /I&E/RBDC/T-96/2025-26/699(a)

Dated Uiam the 27th November, 2025

Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Uiam for kind information.
2. The Superintending Engineer (I&E), EZ, MePDCL, Shillong for kind information.
3. Executive Engineer, Uiam Distribution Division for kind information.
4. The Assistant Executive Engineer, MTI Sub-Division, MePDCL, Shillong for kind information.
5. M/S R.N.B.Carbides & Ferro Alloys. (Consumer Id.: 1000345358), MIDC, Uiam for kind information.
6. R/F.

± Copy to SE (CBS), UAD for necessary action.


ASSISTANT EXECUTIVE ENGINEER

**Schedule for inclusion of Additional Units on account of CT-PT Unit & TTB defective to Meter
No. MS5000060.**

Consumer ID/ Account No. 1000345358

Consumer's Name : M/S R.N.B.Carbides & Ferro Alloys.

Sl. No.	Bill Cycle	Quantum of Additional Units (kVAh)
1	Dec-25	136997.00
2	Jan-26	136997.00
3	Feb-26	136997.00
4	Mar-26	136997.00
5	Apr-26	136997.00
6	May-26	136997.00
7	Jun-26	136997.00
8	Jul-26	136997.00



(F.L. Kynshi)

Asstt. Executive Engineer cum Assessing
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345358

Consumer's Name : M/S R.N.B.Carbides & Ferro Alloys

Description		Meter No: MS5000060 (CT-PT & TTB defected)	Billing Meter No: 4019009	Recorded Demand	Number of Days
M.F		120	120		31
01-09-2025	KVAH	380342.88	403922.49		
02-10-2025	KVAH	397063.19	429775.92		
Net Consumption between 01-09-2025 and 02-10-2025 (31 days)	KVAH	2006437.2	3102411.6		
(A). Energy (kVAh) recorded by Meter No.: MS5000060 (Defected TTB) for 31 days					2006437.20
(B). Same Energy (kVAh) recorded by healthy Check Meter No.: 4019009 (R+Y+B Ph) for 31 days					3102411.60
Number of units (in kVAh) to be included as additional units [CT-PT & TTB defected]					1095974.40



(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.