



**MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED**  
**OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER, INVESTIGATION & ENFORCEMENT SUB-DIVISION**  
**RIBHOI DISTRIBUTION CIRCLE, UMIAM, Email: aeie.rb.mepdcl@meghalaya.gov.in**

No. MePDCL /I&E/RBDC/T-07/2025-26/713

Dated, Umiam the 2nd February, 2026

To,

The Assistant Executive Engineer  
 Patharkmah Distribution Sub-Division  
 MePDCL, Patharkmah

**METER REPLACEMENT REPORT AT DEGREE MODEL COLLEGE, PATHARKHMAH UNDERTAKEN ON THE 27th JANUARY, 2026.**

SL. NO	CONSUMER ID.	NAME OF CONSUMER	ADDRESS	CONTRACT DEMAND (KVA)	CATEGORY	OLD		NEW		DATE OF REPLACEMENT WITH NEW METER	INITIAL READINGS OF NEW METER						Old Seal	New Seal	Remark
						METER NO.	M.F	METER NO.	M.F		KWH	KVAH	KW	R-N (V)	Y-N (V)	B-N(V)			
1	2223000014	DEGREE MODEL COLLEGE	PATHARKH MAH	140	DHT	MS5004416	20	MS5005513 Class: 0.5S, -/5A, Ib=5A, Imax=2xIb, 11KV/110V 50Hz 16000Pules/Unit 16000Pules/Unit (kWh, kVAh, kVArh) Make: HPL Electric & Power Ltd make Type: HST52 Smart Meter	10	27-01-2026	0	0	0	55	55	55	BOX-22001208 TTB-22001208	BOX-0050495 TTB-22000671/0050497	Meter replacement necessitated as per office letter No. MePDCL /I&E/RBDC/T-01/2025-26/683 Dated Umiam the 11th November, 2025. SIM CARD (Airtel No.): 0524 ID 899116099002 6471264U H1

*MS5005513  
 Reading (31/01/2026)  
 kWh : 21.41  
 kVAh : 26.45  
 kVA : 0.20*

*Signature*  
 (F.L KYNSHI)  
 ASSISTANT EXECUTIVE ENGINEER  
 I & E Sub-Division, Ribhal Distribution Circle  
 MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-07/2025-26/713(a)

Dated, Umiam the 2nd February, 2026

Copy to:-

- The Superintending Engineer, Ribhoi (D) Circle, MePDCL, Umiam for kind information.
  - The Superintending Engineer, Investigation & Enforcement, MePDCL, Shillong for kind information.
  - The Executive Engineer, Nongpoh Distribution Division for kind information.
  - The Executive Engineer (HVC), O/o CE (Commercial) for kind information with a request to integrate the new meter with HES/MDM.
6. R/F:

ASSISTANT EXECUTIVE ENGINEER