



MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM
Email: aeeie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-96/2025-26/714

Dated Uiam the 9th February, 2026

To,

The Assistant Executive Engineer,
Uiam Distribution Sub-Division
MePDCL, Uiam.

Sub: Request to update the new M.F and corresponding Additional Unit of M/S Riangdo Veneer(P)ltd. (Cons. ID: 1000345365), M.I.D.C.Complex Uiam.

Sir,

This is to inform you that due to wrong CT Ratio selection vis a vis Contract Load/M.D, the office of the undersigned has on the 13-01-2026 replaced the 11KV CT-PT set of CT Ratio 10/5A at the metering unit of **M/S Riangdo Veneer(P)ltd. (Cons. ID: 1000345365), M.I.D.C.Complex Uiam** with CT Ratio 50/5A. *The new M.F of this consumer is therefore to be updated from the existing 2 to 10 w.e.f 31-01-2026.*

Also, to recover for the unit loss for the period w.e.f 13-01-2026 to 31-01-2026 for which billing with M.F of 2 has already been done, **61767.00 kVAh** (or 55590 kWh) of Additional Unit may please be included into the electricity bill of this consumer preferably in the bill cycle of February, 2026.

This is for your kind information and necessary action.

Encl. Assessment of Additional Units.

Yours faithfully,

(Fullmoon L. Kynshi)

Assistant Executive Engineer-Cum-Assessing Officer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Uiam

No. MePDCL /I&E/RBDC/T-96/2025-26/714(a)

Dated Uiam the 9th February, 2026

Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Uiam for kind information.
2. The Superintending Engineer (I&E), EZ, MePDCL, Shillong for kind information.
3. Executive Engineer, Uiam Distribution Division for kind information.
4. The Executive Engineer (HVC), O/o CE (Commercial) for kind information
5. The Assistant Executive Engineer, MTI Sub-Division, MePDCL, Shillong for kind information.
6. The Junior Engineer (Central Billing Section), Uiam Distribution Division, MePDCL, Uiam for kind information and necessary action to update the new M.F and include the Additional Unit above.
7. **M/S Riangdo Veneer(P)ltd. (Cons. ID: 1000345365), M.I.D.C.Complex Uiam** for kind information.
8. R/F.

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement
Consumer ID/ Account No. 1000345365
Consumer's Name : M/S Riangdo Veneer(P)ltd.

Description		LT Meter No: IN4000415	HT Meter No: MS5000089 (Billing)	Recorded Demand	Number of Days
M.F		160	2		31
31-12-2025	KVAH	25954.19	1469464.6		
31-01-2026	KVAH	26809.25	1506986.05		
Net Consumption between 31-12-2025 and 31-01-2026 (31 days)		KVAH	136809.6	75042.9	
(A). Energy (kVAh) recorded by LT Meter No: IN4000415					136809.60
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000089					75042.90
Units loss (in kVAh) to be recovered as additional units (B-A-C)					61766.70

HT Meter No: MS5000089	
New M.F w.e.f 31-01-2026	10


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

13/1/25

Riam do (Chule meter)
Replacement of combine set.

old secondary seal :- M102583/M102584.

* New combine set :-

1100 CT/VT unit

CT Ratio :- 10-50/5A.

:- 50/5A.

SLNo :- 70344

made :- macro plast.

* old combine set :-

1100 CT/PT unit

CT Ratio :- 5-10A

CT connected - 10A.

SLNo :- 68276

New secondary seal :- 0054839/0054837