



Me PDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED  
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER  
INVESTIGATION & ENFORCEMENT SUB-DIVISION  
RIBHOI DISTRIBUTION CIRCLE, UMIAM  
Email: aecie.rb.mepdcl@meghalaya.gov.in

No.MePDCL/I&E/RBDC/T-96/2025-26/710

Dated, Umiam the 12<sup>th</sup> December, 2025

To,

The Assistant Executive Engineer  
Umiam Rural Distribution Sub-Division  
MePDCL, Umiam.

**Sub: Additional Units (kWh) to be included into the Electricity Bill of Don Bosco School (Cons. ID: 1000198357), Nonglakhiat.**


Sir,

Following the replacement of conventional meter with smart meter at the metering unit of **Don Bosco School (Cons. ID: 1000198357), Nonglakhiat** undertaken in March, 2024, the old meter Meter No. MEB67566 of this consumer was replaced with LT-CT operated HPL Make Smart meter by Satnam Global Infra. Ltd. However, the undersigned during inspection conducted on the 24-09-2024 has found that CT's secondaries (all phases) were open circuited at TTB (corrected) which is a case of wrong metering work.

In view of the above and to recover for the loss of revenue to MePDCL due to wrong metering work, the unit loss of **15776.00 kWh** (or 17529 kVAh) considered for 249 days only may please be recovered as Additional Units (preferably in the bill cycle of January, 2026).

This is for your kind information and necessary action.

Yours sincerely,



(F.L Kynshi)

Assistant Executive Engineer cum Assessing Officer  
Investigation & Enforcement Sub-Division  
Ribhoi Distribution Circle  
MePDCL, Umiam

Dated, Umiam the 12<sup>th</sup> December, 2025

No.MePDCL/I&E/RBDC/T-96/2025-26/710(a)


Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle for kind information.
2. The Superintending Engineer (I&E), Eastern Zone, MePDCL, Shillong for kind Information.
3. The Executive Engineer, Umiam Distribution Division for kind information.
4. The Junior Engineer (Central Billing Section), Umiam Distribution Division, MePDCL, Umiam for kind information and necessary action with a request to include the additional unit above.
5. The consumer concern, Don Bosco School (Cons. ID: 1000198357), Nonglakhiat for kind information.
6. R.F.

ASSISTANT EXECUTIVE ENGINEER

**Energy Consumption Statement**  
**Consumer ID/ Account No. 1000198357**  
**Consumer's Name : Don Bosco School**

Meter Readings for Meter ID:MS5001009 and Meter Status: OK (Normal)				
Description	Date	KWH Meter	Remarks	
Reading	04-Aug-23	137259	Old Meter No. MEB67566	
Reading	19-Jan-24	151155		
No Of Days	168			
Difference		13896		
M.F		1		
Net Consumption		13896		
<b>Average Per Day Consumption (APDC) A</b>		<b>82.71</b>		
Reading	19-Jan-24	0	Post-installation of Meter No.: MS5001009	
Reading cum Correction	24-Sep-24	124		
No Of Days	249			
Difference		124		
M.F		20		
Net Consumption		2480		
MC Units (26/JUN/2024)		2340.13		
<b>Average Per Day Consumption (APDC) B</b>		<b>19.36</b>		
<b>Difference (D=B-A)</b>		<b>63.36</b>		
<b>Additional Units to be included (kWh)</b>		<b>15775.73</b>		
<b>Number of days taken for recovery of unit loss (N)</b>				<b>249</b>
<b>Number of units (in kWh) to be recovered as additional units (=DxN)</b>				<b>15776</b>

  
12/12/25

(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer  
I & E Sub Division, Ribhoi (D) Circle  
MePDCL, Umiam.