

INSPECTION REPORT OF HINDUSTAN PETROLEUM CORPORATION LIMITED AT MAWTNUM NONGPOH CONDUCTED ON THE 15TH OCTOBER, 2025.

SL NO	CONS. NO	NAME OF CONSUMER	ADDRESS	VOLTAGE LEVEL (KV)	TYPE OF METERING UNIT	CONTRACT DEMAND	M/F	METER NO.	CATEGORY	DATE	READINGS						Old seal (TTB)	New seal (TTB)	Remark.
											KWH	KVAH	KVA	V1	V2	V3			
1	1000350836	Hindustan Petroleum Corporation Limited	Mawtnum, Nongpoh	11	LTCT	10	20	MS5004800	CLT	15.10.25	57.89	395.3	0.254	236	235	241	22001263	0.0054305	Wrong metering done by contractor. R-phase PT is connected to CT of R-phase, R-phase PT is connected to Y-phase PT & CT of B-phase is connected to Neutral.

Note: (1) Attention may kindly be paid to the underline bolted remarks.

(2) Cells which are left blank indicate either "No Data Available" or "Not Applicable" during inspection.

*kwh: 57.89
kVAh: 395.3
M.F = 20*

Bph of connected to neutral.

Bph = $\frac{57.89 \times 20}{2} = 578.9$

So,

BBE Abongpoh

Kindly add of additional bill of

Urban SD

579 kwh

(or 643 kVAh) the electricity of Hindustan Petroleum Corporation Limited. (Cons. No: 1000350836).

P. Jayalal 22/12/2025

(F.L KYNISHI)
ASSISTANT EXECUTIVE ENGINEER
Investigation & Enforcement Sub-Division
MePDCL, Umiam