

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM
Email: aecie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-96/2025-26/705

Dated Umiam the 14th January, 2025

To,

The Assistant Executive Engineer,
Umiam Distribution Sub-Division
MePDCL, Umiam.

Sub: Request to shift the metering unit of HT consumers from LT side to HT side.

Sir,

Pending estimation of HT metering, those HT consumers which are currently billed on LT side and have check metering unit on HT side are henceforth to be billed from HT side. Therefore, Billing Meters along with new M.F of the consumers (List enclosed) may please be updated and respective Additional Units exclusive of system self-generated MC Unit applicable against each may please be included accordingly (Initial Readings have been given separately in enclosed energy consumption annexures). From the next billing cycle, all consumers in the list shall be billed only from HT meters.

This is for your kind information and necessary action.

Encl. Assessment of Additional Units.

Yours faithfully,

(Fullmoon L. Kynshi)


Assistant Executive Engineer-Cum-Assessing Officer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-96/2025-26/705(a)

Dated Umiam the 14th January, 2025

Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer (I&E), EZ, MePDCL, Shillong for kind information.
3. Executive Engineer, Umiam Distribution Division for kind information.
4. The Executive Engineer (HVC), O/o CE (Commercial) for kind information
5. The Assistant Executive Engineer, MTI Sub-Division, MePDCL, Shillong for kind information.
6. The Junior Engineer (Central Billing Section), Umiam Distribution Division, MePDCL, Umiam for kind information and necessary action to update the billing meter No., M.F and include the additional units.
7. R/F.

 14/01/2026

ASSISTANT EXECUTIVE ENGINEER

NEW BILLING METERS (HT SIDE) OF 11KV CONSUMERS UNDER UMIAM DIVISION

SL NO	CONS. NO.	VOLTAGE LEVEL (KV)	NAME OF CONSUMER	ADDRESS	CATEGORY	OLD (LT SIDE)		NEW (HT SIDE)			EFFECTIVE DATE OF METER REPLACEMENT	ADDITIONAL UNITS (EXCLUSIVE OF SYSTEM SELF GENERATED MC UNIT)		
						METER	M.F	METER	M.F	SIMCARD		KVAH	KWH	
1	1000345379	11	Mawthilliang Wood Products(P) Ltd.,	MIDC	IHT	MS5001793	60	MS5000011	2	AIRTEL	0524ID 899116099002 6412554U H1	31-12-2025	125	113
2	1000345389	11	M/S Shree Mahabir Industries	MIDC	IHT	IN4000395	30	MS5000091	2	AIRTEL	0524ID 899116099002 6412555U H1	29-12-2025	1896	1706
3	1000345359	11	M/S Vishal Saw Cum Veneer Mills	MIDC	IHT	IN4000405	60	MS5000079	2	AIRTEL	0524ID 899116099002 6412557U H1	29-12-2025	4788	4309
4	1000345360	11	M/S Regitta Food Processing(P) Ltd.	MIDC	IHT	IN4000335	60	MS5000160	2	AIRTEL	0524ID 899116099002 6412559U H1	29-12-2025	15147	13632
5	1000345410	11	M/S Meghalaya Plywood	MIDC	IHT	IN4000294	60	MS5000157	4	AIRTEL	0524ID 899116099002 6412558U H1	30-12-2025	4086	3677
6	1000345400	11	M/S Sushil Kurbah Tylling Producton	MIDC	IHT	IN4000408	30	MS5000213	4	AIRTEL	0524ID 899116099002 6412556U H1	29-12-2025	13830	12447
7	1000345366	11	M/S S.K.Dewsaw Sawmill	MIDC	IHT	IN4000273	60	MS5000092	4	AIRTEL	0524ID 899116099002 6412553U H1	29-12-2025	2261	2035
8	1000345365	11	M/S Riango Veneer(P)ltd.	MIDC	IHT	IN4000415	160	MS5000089	2	AIRTEL	0524ID 899116099002 6412546U H1	31-12-2025	14098	12688
9	1000345361	11	M/S Eastern Sawmill	MIDC	IHT	MS5000917	60	MS5000158	2	AIRTEL	0524ID 899116099002 6412549U H1	29-12-2025	1557	1401

10	1000345399	11	M/S Girik Briquettes	MIDC	IHT	IN4000281	30	MS5000175	2	AIRTEL	0524ID 899116099002 6412590U H1	31-12-2025	4645	4181
11	1000345364	11	M/S Timber Craft Veneer Product Ltd	MIDC	IHT	IN4000310	60	MS5000012	4	AIRTEL	0524ID 899116099002 6412477U H1	29-12-2025	7876	7088
12	1000345340	11	M/S Premier Roller Mill & Bakery.	MIDC	IHT	IN4000282	160	MS5000094	4	AIRTEL	0524ID 899116099002 6412574U H1	29-12-2025	44599	40139

Rajesh 14/11/2026
(F.L. Kynshi)

Asstt Executive Engineer
Investigation & Enforcement Sub Division
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345379

Consumer's Name : Mawthiliang Wood Products(P) Ltd.,

Description		LT Meter No: MS5001793 (Billing)	HT Meter No: MS5000011 (Check)	Recorded Demand	Number of Days
M.F		60	2		131
22-08-2025	KVAH	11792.22	93233.26		
31-12-2025	KVAH	14289.98	170476.54		
Net Consumption between 22-08-2025 and 31-12-2025 (131 days)		149865.6	154486.56		
(A). Energy (kVAh) recorded by LT Meter No: MS5001793 (Billing)					149865.60
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000011 for 131 days					154486.56
©. 3% DT loss component of (A)					4495.97
Units loss (in kVAh) to be recovered as additional units (B-A-C)					124.99

HT Meter No: MS5000011 (Check)	
Initial Reading	31-12-2025
kWh	167471.65
kVAh	170476.54
M.F	2


(F.L. Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

ASSISTANT EXECUTIVE ENGINEER
DIVISION

MISID

Energy Consumption Statement
Consumer ID/ Account No. 1000345389
Consumer's Name : M/S Shree Mahabir Industries

Description		LT Meter No: IN4000395 (Billing)	HT Meter No: MS5000091 (Check)	Recorded Demand	Number of Days
M.F		30	2		
22-08-2025	KVAH	7314.087	89238.43		129
29-12-2025	KVAH	8556.881	109387.73		
Net Consumption between 22-08-2025 and 29-12-2025 (129 days)		37283.82	40298.6		
(A). Energy (kVAh) recorded by LT Meter No: IN4000395 (Billing)					37283.82
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000091 for 129 days					40298.60
©. 3% DT loss component of (A)					1118.51
Units loss (in kVAh) to be recovered as additional units (B-A-C)					1896.27

HT Meter No: MS5000091 (Check)	
Initial Reading	29-12-2025
kWh	73087.25
kVAh	109387.73
M.F	2


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345359

Consumer's Name : M/S Vishal Saw Cum Veneer Mills

Description		LT Meter No: IN4000405 (Billing)	HT Meter No: MS5000079 (Check)	Recorded Demand	Number of Days
M.F		60	2		
22-08-2025	KVAH	5872.77	109240.61		129
29-12-2025	KVAH	6637.382	135261.15		
Net Consumption between 22-08-2025 and 29-12-2025 (129 days)		45876.72	52041.08		
(A). Energy (kVAh) recorded by LT Meter No: IN4000405 (Billing)					45876.72
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000079 for 129 days					52041.08
©. 3% DT loss component of (A)					1376.30
Units loss (in kVAh) to be recovered as additional units (B-A-C)					4788.06

HT Meter No: MS5000079 (Check)	
Initial Reading	29-12-2025
kWh	117433.08
kVAh	135261.15
M.F	2


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.


Energy Consumption Statement

Consumer ID/ Account No. 1000345360

Consumer's Name : M/S Regitta Food Processing(P) Ltd.

Description	LT Meter No: IN4000335 (Billing)	HT Meter No: MS5000160 (Check)	Recorded Demand	Number of Days
M.F	60	2		
22-08-2025	KVAH	3909.496	94116.39	140
09-01-2026	KVAH	4536.427	121062.3	
Net Consumption between 22-08-2025 and 09-01-2026 (140 days)	KVAH	37615.86	53891.82	
(A). Energy (kVAh) recorded by LT Meter No: IN4000335 (Billing)				37615.86
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000160 for 140 days				53891.82
©. 3% DT loss component of (A)				1128.48
Units loss (in kVAh) to be recovered as additional units (B-A-C)				15147.48

HT Meter No: MS5000160 (Check)	
Initial Reading	29-12-2025
kWh	73203.73
kVAh	119155.5
M.F	2


14/01/2026


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345410
Consumer's Name : M/S Meghalaya Plywood

Description	LT Meter No: IN4000294 (Billing)	HT Meter No: MS5000157 (Check)	Recorded Demand	Number of Days
M.F	60	4		140
22-08-2025	KVAH 14704.146	127720.28		
09-01-2026	KVAH 16181.187	151562.17		
Net Consumption between 22-08-2025 and 09-01-2026 (140 days)	KVAH 88622.46	95367.56		
(A). Energy (kVAh) recorded by LT Meter No: IN4000294 (Billing)				88622.46
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000157 for 140 days				95367.56
©. 3% DT loss component of (A)				2658.67
Units loss (in kVAh) to be recovered as additional units (B-A-C)				4086.43

HT Meter No: MS5000157 (Check)	
Initial Reading	30-12-2025
kWh	113252.68
kVAh	149198.35
M.F	4


14/01/2026

(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345400

Consumer's Name : M/S Sushil Kurbah Tylling Producton

Description	LT Meter No: IN4000408 (Billing)	HT Meter No: MS5000213 (Check)	Recorded Demand	Number of Days
M.F	30	4		
22-08-2025	KVAH	32728.54	142406.35	
09-01-2026	KVAH	38626.72	190100.13	140
Net Consumption between 22-08-2025 and 09-01-2026 (140 days)	KVAH	176945.4	190775.12	
(A). Energy (kVAh) recorded by LT Meter No: IN4000408 (Billing)				176945.40
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000213 for 140 days				190775.12
©. 3% DT loss component of (A)				0.00
Units loss (in kVAh) to be recovered as additional units (B-A-C)				13829.72

HT Meter No: MS5000213 (Check)	
Initial Reading	29-12-2025
kWh	165265.43
kVAh	186046.08
M.F	4


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345366
Consumer's Name : M/S S.K.Dewsaw Sawmill

Description		LT Meter No: IN4000273 (Billing)	HT Meter No: MS5000092 (Check)	Recorded Demand	Number of Days
M.F		60	4		
22-08-2025	KVAH	6239.98	53155.33		140
09-01-2026	KVAH	7069.382	66534.96		
Net Consumption between 22-08-2025 and 09-01-2026 (140 days)		49764.12	53518.52		
(A). Energy (kVAh) recorded by LT Meter No: IN4000273 (Billing)					49764.12
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000092 for 140 days					53518.52
©. 3% DT loss component of (A)					1492.92
Units loss (in kVAh) to be recovered as additional units (B-A-C)					2261.48

HT Meter No: MS5000092 (Check)	
Initial Reading	29-12-2025
kWh	61406.06
kVAh	65198.58
M.F	4


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345365
Consumer's Name : M/S Riango Veneer(P)ltd.

Description		LT Meter No: IN4000415 (Billing)	HT Meter No: MS5000089 (Check)	Recorded Demand	Number of Days
M.F		160	2		138
22-08-2025	KVAH	22010.974	1137276.6		
07-01-2026	KVAH	26175.996	1487523.35		
Net Consumption between 22-08-2025 and 07-01-2026 (138 days)		666403.52	700493.5		
(A). Energy (kVAh) recorded by LT Meter No: IN4000415 (Billing)					666403.52
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000089 for 138 days					700493.50
©. 3% DT loss component of (A)					19992.11
Units loss (in kVAh) to be recovered as additional units (B-A-C)					14097.87

HT Meter No: MS5000089 (Check)	
Initial Reading	31-12-2025
kWh	1448404.33
kVAh	1469464.6
M.F	2


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345361
Consumer's Name : M/S Eastern Sawmill

Description		LT Meter No: MS5000917 (Billing)	HT Meter No: MS5000158 (Check)	Recorded Demand	Number of Days
M.F		60	2		140
22-08-2025	KVAH	2160.81	51019.3		
09-01-2026	KVAH	2564.38	64267.93		
Net Consumption between 22-08-2025 and 09-01-2026 (140 days)	KVAH	24214.2	26497.26		
(A). Energy (kVAh) recorded by LT Meter No: MS5000917 (Billing)					24214.20
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000158 for 140 days					26497.26
©. 3% DT loss component of (A)					726.43
Units loss (in kVAh) to be recovered as additional units (B-A-C)					1556.63

HT Meter No: MS5000158 (Check)	
Initial Reading	29-12-2025
kWh	57369.13
kVAh	62941.49
M.F	2

F.L Kynshi
14/01/2026
(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345399

Consumer's Name : M/S Girik Briquettes Pvt.Ltd.,

Description		LT Meter No: IN4000281 (Billing)	HT Meter No: MS5000175 (Check)	Recorded Demand	Number of Days
M.F		30	2		140
22-08-2025	KVAH	32350.68	440215.36		
09-01-2026	KVAH	38908.364	543854.07		
Net Consumption between 22-08-2025 and 09-01-2026 (140 days)		196730.52	207277.42		
(A). Energy (kVAh) recorded by LT Meter No: IN4000281 (Billing)					196730.52
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000175 for 140 days					207277.42
©. 3% DT loss component of (A)					5901.92
Units loss (in kVAh) to be recovered as additional units (B-A-C)					4644.98

HT Meter No: MS5000175 (Check)	
Initial Reading	31-12-2025
kWh	388579.43
kVAh	538201.74
M.F	2

(Signature)
 (F.L Kynshi)


Asstt. Executive Engineer cum Assessing Officer
 I & E Sub Division, Ribhoi (D) Circle
 MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345364

Consumer's Name : M/S Timber Craft Veneer Product Ltd

Description		LT Meter No: IN4000310 (Billing)	HT Meter No: MS5000012 (Check)	Recorded Demand	Number of Days
M.F		60	4		
08-09-2025	KVAH	4714.922	34478.85		121
07-01-2026	KVAH	5349.744	46255.82		
Net Consumption between 08-09-2025 and 07-01-2026 (121 days)		38089.32	47107.88		
(A). Energy (kVAh) recorded by LT Meter No: IN4000310 (Billing)					38089.32
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000012 for 121 days					47107.88
©. 3% DT loss component of (A)					1142.68
Units loss (in kVAh) to be recovered as additional units (B-A-C)					7875.88

HT Meter No: MS5000012 (Check)	
Initial Reading	29-12-2025
kWh	24893.46
kVAh	45461.14
M.F	4


(F.L. Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.

Energy Consumption Statement
Consumer ID/ Account No. 1000345340

Consumer's Name : M/S Premier Roller Mill & Bakery.

Description	LT Meter No: IN4000282 (Billing)	HT Meter No: MS5000094 (Check)	Recorded Demand	Number of Days
M.F	160	4		
22-08-2025	KVAH	12594.486	317469.32	131
31-12-2025	KVAH	14315.413	397456.11	
Net Consumption between 22-08-2025 and 31-12-2025 (131 days)	KVAH	275348.32	319947.16	
(A). Energy (kVAh) recorded by LT Meter No: IN4000282 (Billing)				275348.32
(B). Same Energy (kVAh) recorded by Check Meter No.: MS5000094 for 131 days				319947.16
©. 3% DT loss component of (A) not included				0.00
Units loss (in kVAh) to be recovered as additional units (B-A-C)				44598.84

HT Meter No: MS5000094 (Check)	
Initial Reading	29-12-2025
kWh	237511.02
kVAh	395749.36
M.F	4


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.