

16/01/2026

* Untung 1 Phe WSS, UMTUNG

Cons ID: 1000847757

10kW, GP

Meter No. MS5003927

CT operated.

CTR = 50/5, MF = 10.

SIM CARD (AIRTEL) NO: 0423 ID
899116099002
4336380UHI

Reading (16/01/2026): 281.9 kWh
(inspection date) 408.5 kVAh
0.3 kW } Bph PT found missing

Reading (14/01/2025): 73 kWh
(from Bill)

Bph ⁱⁿ ~~height~~ ^{at} least 12 months = $(281.9 - 73) \times 2$
= 1046 kWh

To,
JE (Central Billing Section), UDD
Umanin

Kindly add 1046 kWh (or 1160 kVAh)
into the electricity bill of this consumer.

16/01/2026
Assistant Executive Engineer
Investigation & Enforcement
RIBHOI DISTRIBUTION CIRCLE
MEPDCL, UMIAM