



MePDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED  
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER  
INVESTIGATION & ENFORCEMENT SUB-DIVISION, RIBHOI (D) CIRCLE  
MePDCL, UMIAM

No. MePDCL /I&E/RBDC/T-07/2025-26/724

Dated Umiam the 26<sup>th</sup> February, 2026

To,

The Assistant Executive Engineer,  
Umiam Distribution Sub-Division,  
MePDCL, Umiam.

**Sub: Inspection Report of New LT-CT Metering Unit of new consumer viz., Telecom Infrastructure PVT. Ltd, Lumsohpetbneng.**

Sir,

With reference to the subject cited above, this is to inform you that the office of the undersigned has on the 25-02-2026 inspected the new **LT-CT Metering Unit of Telecom Infrastructure PVT. Ltd, Lumsohpetbneng.** and the detailed Inspection Report is enclosed herewith for your kind perusal.

It is to be noted that the installed Meter No. **SS22171303** found at site is Whole Current Secure Make Meter (Non-Smart) and has therefore been replaced with JPM Make Whole Current Smart Meter No. **22002135** and the already consumed units of 11975.00 kWh is to be recovered later as Additional Units. The entire metering unit is as per standard metering practice with **Multiplication Factor (O.M.F for billing) of 1.**

This is for your kind information and necessary action.

Encl.: Inspection Report.

Yours faithfully,

(Fullmoon L. Kynshi)  
Assistant Executive Engineer  
I & E Sub-Division, Ribhoi (D) Circle  
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-07/2025-26/724(a)

Dated Umiam the 26<sup>th</sup> February, 2026

Copy to:-

1. The Superintending Engineer, Ribhoi (D) Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer (I & E), EZ, MePDCL, Shillong for kind information.
3. The Executive Engineer, Umiam Distribution Division for kind information.
4. The Executive Engineer, MTI Division, MePDCL, Shillong for kind information.
5. The Executive Engineer (HVC), O/o CE (Commercial) for kind information with a request to integrate this meter with HES/MDM.
6. The Junior Engineer (Central Billing Section), Umiam Distribution Division for kind information and necessary action.
7. R/F.

ASSISTANT EXECUTIVE ENGINEER

**INSPECTION REPORT OF NEW METERING UNIT OF ATC  
Telecom Infrastructure PVT. Ltd, Lumsohpetbneng CONDUCTED ON THE 25.02.2026.**

SL NO	Consumer No	SUPPLY VOLTAGE (KV)	NAME OF CONSUMER	ADDRESS	CT Ratio	O.M.F	METER NO.	CATEGORY	CONTRACT DEMAND (KW)	READINGS						Remark
										KWH	KVAH	KW	R-N (V)	Y-N (V)	B-N (V)	
1	New (Yet to be allotted)	11	ATC Telecom Infrastructure PVT. Ltd	Lumsohpetbneng	1	1	<b>22002135</b> 3Ph Whole Current 10(60)A, 3x240V/415V, 50Hz (kWh, kVAh, kVarh) 1000Imp/kWh, Type: DTZ1513 JPM Industries Ltd Make Smart Meter	CLT	22	0.00	0	0	240	240	238	<u>Old Meter No. SS22171303 (kWh as on 25-02-2026: 11975.00, to be added later as Additional Units) being non-smart was replaced with Whole Current Smart Meter Number with SIM CARD (JIO No.): 8991 8650 4060 0180 3484</u>

Note: O.M.F: 1 (kWh, kVAh, kVA)  
DTC: 63KVA  
Contract Demand Applied: 22KVA

*Revised 26/02/2026*

F.L Kynshi  
Asstt Executive Engineer  
Investigation & Enforcement Sub Division  
MePDCL,Umiam.