



Me PDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM
Email: aeeie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-96/2025-26/697

Dated Umiam the 27th November, 2025

To,

The Assistant Executive Engineer,
Umiam Distribution Sub-Division
MePDCL, Umiam.

Sub: Request for inclusion of Additional Units (kVAh) and to change the Billing Meter Number of N.E.S.A.C Gh & Ab (Consumer Id.: 1000345404), Nongsder Umiam.

Sir,

This is to inform you that the undersigned during random inspection of HT Government consumers on the 26-11-2025, has found three meters located at the premises of NESAC, Nongsder viz., LT-CT Meter No. MEB97158 (Current Billing Meter) & MEB97159 (Check Meter) with each corresponding CTR: 400/5A (M.F=80) and 1 (one) No. of HT-CT Meter No. MEB96378 (Check Meter with 11KV CT-PT Unit of CTR 30-25/5A connected at 25/5A as per real time measurement of CTR). However, it has been found that Y & B Phase CT secondary currents to Billing Meter No. MEB97158 were "Zero" in spite 34A & 42 A of respective currents in primary. Due to the CT rings being found defected (Video proof available), the energy consumption recorded by the billing Meter is lower (only 50% of the Total Consumption) than the actual consumption (details energy comparison statement enclosed).

In view of the above and to recover for the loss of revenue to MePDCL due to defected CT Rings, **58753.00 kVAh (or 52877.00kWh)** of Additional Units may please be included into the electricity bill of **N.E.S.A.C Gh & Ab (Consumer Id.: 1000345404), Nongsder Umiam** (preferably in the Bill Cycle of December, 2025).

Also, following the general instruction that all HT consumers have to be billed on HT sides, for this consumer, *w.e.f 26-11-2025, Billing may please be done from Meter No. MEB96378 with M.F: 500 (Initial Reading on 26-11-2025: kWh: 2145.58, kVAh: 2293.31, KVA: 0.106).*

This is for your kind information and necessary action.

Encl. Energy comparison statement cum Assessment of Additional Units.

Yours faithfully,

(Fullmoon L. Kynshi)

Assistant Executive Engineer-Cum-Assessing Officer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-96/2025-26/697(a)

Dated Umiam the 27th November, 2025

Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer (I&E), EZ, MePDCL, Shillong for kind information.
3. Executive Engineer, Umiam Distribution Division for kind information.
4. The Assistant Executive Engineer, MTI Sub-Division, MePDCL, Shillong for kind information.
5. The Junior Engineer (Central Billing Section), Umiam Distribution Division, MePDCL, Umiam for kind information and necessary action to include the additional unit as mentioned.
6. The Director/ Administrative Officer, North Eastern Space Applications Centre, Nongsder.
7. R/F.

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement
Consumer ID/ Account No. 1000345404
Consumer's Name : N.E.S.A.C Gh & Ab

Description		Billing Meter No: MEB97158	Check Meter No: MEB97159	Check Meter No: MEB96378	No. of Days
Types of metering		LT-CT	LT-CT	HT-CT	
M.F		80	80	500	
04-11-2025	KWH	8777.25	9492.5	2121.61	22
	KVAH	9714.4	10418.85	2268.48	
	KVA	0.352	0.678	0.106	
26-11-2025	KWH	8852.04	9631.92	2145.58	
	KVAH	9794.64	10561.44	2293.31	
	KVA	0.352	0.678	0.106	
Net Consumption between 04-11-2025 and 26-11-2025 (22 days)	KWH	5983.2	11153.6	11985	
	KVAH	6419.2	11407.2	12415	
	KVA	28.16	54.24	53	
(A). Billing Meter No: MEB97158 (Y & B Ph CT defected) 02/JUN/2025					9060.23
(B). Billing Meter No: MEB97158 (Y & B Ph CT defected) 26/NOV/2025					9794.64
Billed Unit between 02/JUN/2025 & 26/NOV/2025					58752.80
Number of units (in kVAh) to be included as additional units (next 50%)					58752.80


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.