



MePDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION
RIBHOI DISTRIBUTION CIRCLE, UMIAM
Email: aeeie.rb.mepdcl@meghalaya.gov.in

No. MePDCL /I&E/RBDC/T-96/2025-26/658

Dated Uiam the 23rd September, 2025

To,

The Assistant Executive Engineer,
Uiam Distribution Sub-Division
MePDCL, Uiam.

Sub: Additional Units (kVAh) to be included into the electricity bills of M/S L.L.Nongrum Veneer Mill, Unit-Ii (Consumer Id.: 1000198261), MIDC, Uiam.

Sir,

This office has in the month of July, 2025 found the Billing Meter No. MS5000716 of M/S L.L.Nongrum Veneer Mill, Unit-Ii (Consumer Id.: 1000198261), MIDC, Uiam failing to read B Ph Voltage but immediate correction (Meter Replacement) could not be taken due to unavailability of new LT-CT Meter. As per record, this case of failure by meter to read B Ph Voltage seems to have occurred prior to 21-09-2024. Meter Replacement cum correction was undertaken only on the 23-09-2025 and to account for the loss of revenue to MePDCL for the period w.e.f 21-09-2024 to 23-09-2025, 17849.00 kVAh of Additional Units may please be included into the electricity bill of M/S L.L.Nongrum Veneer Mill, Unit-Ii (preferably in the Bill Cycle of October, 2025).

The Additional Units above is exclusive of the system generated Meter Change Unit and shall be added independently.

This is for your kind information and necessary action.

Encl. Assessment of Additional Unit.

Yours faithfully,

(Fullmoon L. Kynshi)

Assistant Executive Engineer-Cum-Assessing Officer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Uiam

No. MePDCL /I&E/RBDC/T-96/2025-26/658(a)

Dated Uiam the 23rd September, 2025


Copy to:-

1. The Superintending Engineer, Ribhoi Distribution Circle, MePDCL, Uiam for kind information.
2. The Superintending Engineer (I&E), EZ, MePDCL, Shillong for kind information.
3. Executive Engineer, Uiam Distribution Division for kind information.
4. The Assistant Executive Engineer, MTI Sub-Division, MePDCL, Shillong for kind information.
5. The Junior Engineer (Central Billing Section), Uiam Distribution Division, MePDCL, Uiam for kind information and necessary action to include the additional unit as mentioned.
6. M/S L.L.Nongrum Veneer Mill, Unit-Ii (Consumer Id.: 1000198261), MIDC, Uiam for kind information.
7. R/F.

ASSISTANT EXECUTIVE ENGINEER

Energy Consumption Statement
Consumer ID/ Account No. 1000198261
Consumer's Name : M/S L.L.Nongrum Veneer Mill,Unit-Ii

Meter Readings for Meter ID:MS5000716 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	Kvah Meter	Recorded Demand	Recorded PF
Reading (B Ph PT missing date)	21-09-2024		1537.40		
Reading (MCD)	23-09-2025		3322.33		
Difference			1784.93		
Multiplying Factor			20.00		
Net Consumption			35698.60		
Additional Units to be included (kVAh)			17849.30		
B Ph weightage (=1/2 of R & Y together)					17849.30
Number of units (in kVAh) to be compensated as additional units					17849.30


(F.L Kynshi)

Asstt. Executive Engineer cum Assessing Officer
I & E Sub Division, Ribhoi (D) Circle
MePDCL, Umiam.