



and made for the
A. L. HEK.

24

03

2025

and his successor and assigns
hereinafter referred to as the consumer) of the consumer and the Meghalaya Power Distribution
Company Limited (hereinafter referred to as the distribution utility) and the consumer

Note: The term 'consumer' includes any person who takes or causes to be taken any supply of electricity for any purpose, whether for domestic or commercial or industrial or agricultural or other purposes.

Whereas the consumer applied to the distribution utility for supply of the premises and the
distribution utility has agreed to give the supply under the terms and conditions hereafter
appearing

Now therefore, the agreement is as follows:

- (1) That the supply shall be given to the consumer situated at **KUTREW KUMIAM**
with the Consumer as owner/occupier of **RI-BHOI - DIST.**
MEGHALAYA.
- (2) That the supply shall be for the purpose of **Embankment C/LT.**
the load whereof shall not exceed **6M to 10M** watts.
- (3) That the provision of the EA, 2003 and the regulations, code and orders including tariff
orders, as may be made from time to time by the MSEDCL shall apply and bind the consumers and
the distribution utility alike.
- (4) That the consumer shall regularly and timely pay to MSEDCL all charges may be due for
the supply of electricity.

that the agreement shall be for a period of two years and may be renewed for a further period. Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement be renewed.

(6) That the agreement shall be terminated if the consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or on the part of the MePDCL if it desires to terminate the agreement on the terms and conditions of the agreement.

Provided that part of the MePDCL notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case. The consumer may also be heard before the agreement is terminated and the supply of electricity cut off.

(7) The term of continuation of this agreement shall be effective from the date of supply of electricity commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.


Mr. A. L. Singh
For and on behalf of and by
Authorisation of the consumer

For and on behalf of MePDCL

Witness

1 Signature 

Name VINOD KUMAR SINGH.

Address R.R. colony Rynjah shillog.

2 Signature _____

Name _____

Address _____

TEST REPORT (T T SUPPLY)

The

This is to certify that repaired / renewed / additional / new electric installation at the premises of
(Full Name)

A. L. H. E. K. (Please leave one block between name & surname)

(Address)

K. M. T. R. E. W. W. N. I. A. M. R. I. B. H. O. I. D. I. S. T. M. E. C. H. A. L. A. Y. A.

is duly completed, tested and is ready for your authorized representatives to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	Phase - I		Phase - II		Phase - III		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total watt	
1. Light points (i) Fluorescent (ii) Incandescent (iii) CFL (iv) Halogen (v) Others								
2. Fan Points								
3. Plug points (3-pin) (i) 6 Amps (ii) 16 Amps	100w x 3 1000w x 1		300w 1000w		300w 1000w		300w 1000w	900w 3000w
4. Electrical gadgets (i) Water Heater (Geyser) (ii) Refrigerator (iii) Air Conditioner (v) Others								
5. Welding Transformer								
6. Motor								
Total			1300w		1300w		1300w	3900w
In case of load enhancement								6000w
Existing load (in watts)								
Total load in the premises (in watts)								9900w

Notes -

(a) Details of any apparatus (other than the above mentioned) should be given

(b) Rating of capacitor used in Induction Motor and Welding

Transformer (Test report of capacitor is to be enclosed) KVAR

II. Type of wiring *pvc ltr wiring - ltr*

III. Voltage and system of supply. *440V*

IV. Test Result:

Date of Testing by Licensed Contractor

2	4	0	3	2	5
---	---	---	---	---	---

Type of Test	Result of test carried out by licensed contractor (in M Ω) / Ω	Result of test carried out by the supplier under relevant IE Rules, (in M Ω) / Ω
a. Insulation resistance between earth and whole system of conductor.	$P_1 - E = 40M$ $P_L - E = 40M$ $P_2 - E = 40M$	
b. Insulation resistance between all conductors.	$P_1 - P_L = 45M$ $P_1 - P_2 = 45M$ $P_L - P_2 = 45M$	
c. Earth continuity between earth electrode and earth continuity conductor.	<i>0.2m</i>	
d. Polarity of non-linked SP switches	<i>phase -</i>	

V. Full Name with signature of Licensed contractor :
(with date)

LIC No *690*

ASHISH DEB
Electrical Contractor
LIC No : 690

VI. Full Name with signature of supervisor
(with date)

LIC No *824*

BABLU DEB
Electrical Supervisor's
BABLU DEB (No.-824)

VII. Full Name with signature of wireman
(with date)

PERMIT No. *4454*

B. S. Dab
4454

VIII. Signature of the authorized official who tested the installation of behalf of supplier (with date)

IX. Date of connection of supply to the installation :