

Slr/m

IN CORPORATION LIMITED
ORDER Date: 25/11/24

SECURE

ROUTINE TEST REPORT

BPL(U).

(186)

Serial Number: SS17223531

Customer: R.K. TRADING CO.

Customer P.O Number: RKTC/PO/Secure Meters/2023 - 24/011

Customer P.O Date: 27-JUN-2023

Voltage: 240V

Current: 05-30A

Accuracy Class: 1.0

Ref. Standard: IS : 13779

Meter Constant: 6400

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions: $V_{ref} = 240V/50Hz$ $I_b = 05-30A$ Amb. Temp = 27 ± 2 Deg. C

METER ACCURACY

% Active Import Errors

Load % I_b	0.5 Lag	0.8 Lead	UPF
600	0.3	0.0	0.0
100	0.1	0.0	0.0
10	0.1	0.0	0.0
5			0.0

00001.0

TEST DATE: 22/05/2023

7-4-25
[Signature]

This is Computer generated test report no signature required

Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong

Comid: 1000 267775
category: BPL(U)

kynteng. manas kumar. on 8/4/25
(Y. Passah)
Assistant Engineer
MTI Lab
MePDCL, Shillong.

DO S-7/4/25

sent to Bah
Yung Khoi