

II. Type of wiring *Cableway Capping*

III. Voltage and system of supply *230 volt*

IV. Test Result *ok*

Date of testing by licensed contractor

20012026

	Type of test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant Cea regulations, (in MΩ) / Ω
(a)	Insulation resistance between earth and whole system of conductor.	110 M Ω	
(b)	Insulation resistance between all conductors	107 M Ω	
(c)	Earth continuity between earth electrode and earth continuity conductor	3 Ω	
(d)	Polarity of non-linked SP switches	0.0 V (Pn - 230V) EM - 0.2	

V. Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.

VI. Full name with signature of supervisor (with date)

LIC No.

Mobile No.

VII. Full name with signature of wireman (with date)

LIC No.

Mobile No.

VIII. Signature of the authorized official who

tested the installation on behalf of supplier (with date)

Mobile No.

[Signature]
M/s. R. D. Electrical
ovt. Electrical Contractor
Lic. No : 381

[Signature]
Mr. P. Dohtdong
Electrical Supervisor
Regd. No: 459

[Signature]
Mr. P. Dohtdong
Electrical Wireman
Regd. NO - 2126

X. Date of connection of supply to the installation

Meghalaya Power Distribution Corporation Limited
SPOT COLLECTION
UMIAM RURAL DIST SUBDIVISION
DUPLICATE 2

Meghalaya Power Distribution Corporation Limited
ELECTRICITY BILL

Account Details
Sub-Division UMIAM SUBDIVISION
Consumer Id 1000207945
MR Code 2232001
Consumer Name Brill Warbah
Address Sumer Pool, Sumer Pool #3130910600
Category DLT
C.Demand/Load 1KW
Meter No. SS14740091
OMF(Cons) 1
VAN No. MEPDCL1000207945

Billing Details
Prev. Reading Date 18/11/2025
Curr. Reading Date 16/12/2025
No. of Days 28
Bill Number 223200125C160656
Bill Status OK(Normal)
Prev KWH 13444.8
Current KWH 13827.7
Billed Unit 382.9
Recorded MD 0
Power Factor 0
Average

Bill Charges
Fixed Charges (Unit, Rate, Amount)
1.0 KW 90.0 84.00
Energy Charges (Unit, Rate, Amount)
93.33 5.0 466.67
93.33 5.04 470.40
196.23 5.1 1000.79
ED Amount (Unit, Rate, Amount)
382.9 0.05 19.15
FPPAS -64.82
(OCT 25 TO OCT 25 : -64.820)
Current Bill Amt 1976.19
Consumer Credit -0.52
Adjustment 0.00
Gross Bill Amount 1975.67

Net Bill Amount ₹ 1976.00
Due Date 22/12/2025
Last Payment Date 25/11/2025
Last Payment Amount 1238

16/12/2025 14:32 V4.6

This bill will be construed as final notice under Section 9.2 of MSERC (Electricity Supply Code) Regulations, 2018. Supply of electricity shall be disconnected at any date, if dues of Electricity bill is not paid within 15 (fifteen) days (notice period) after due date of the bill. Thanks for paying, We really appreciate it!



For Bill Payments, Please visit www.meghapower.com OR
Download Megha Power App from Google Playstore

Receipt No. : 223101240909081
Consumer ID : 1000207945
Payment Mode : CASH
Payment Type : BILL
Date and Time : 22-12-2025 11:55:57
Consumer Name : Brill Warbah-Sumer Pool, Sumer Pool #3130910600
Paid Amount : Rs.1976.0/-
(One Thousand Nine Hundred Seventy Six Rupees Only.)

Secret Key : 44BZ
Drawn BY : IBADAAHUN SANDRA MAWLONG-CASHIER
(SUB DIV)

Verify the Consumer ID and Amount

Thank you for using i~EasyBill

Meghalaya Power Distribution Corporation Limited
Test Report

100 kVA
R. Name

This is to certify that repaired/renewed/additional/new electric installation at the premises of

Full name

BRILL WARBAN

(Please leave one block between name & surname)

Address

SUMER POOL

1. The load has been arranged as follows:

Details of load	Wattage of each item	Phase I		Phase II		Phase III		Total wattage of all 3 phases
		No. of points	Total wattage	No. of points	Total wattage	No. of points	Total wattage	
1. Light points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others /led		7 No	9 watt		63 watt			
2. Fan points								
3. Plug points (3-Pin)								
(i) 6 Amps	100	6 No	600 watt					
(ii) 16 Amps								
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) AC								
(iv) Others								
5. Welding transformer								
6. Motor								
Total					663 watt			
In case of load enhancement existing load (in watts)					1000 watt			
Total load in the premises (in watts)					1663 watt or 2kw			

Notes:

- (a) Details of any apparatus (other than the above mentioned) should be given.
- (b) Rating of capacitor used in induction Motor and welding Transformer (Test report of capacitor is to be enclosed)

Provided that on the part of the MePDCL notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any duly considered before the agreement is terminated and the supply of electricity cut off;

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

B. Waribah
Consumer ✓

For and behalf of MePDCL.

Witness.

1. Signature:
Name:
Address:

2. Signature:
Name:
Address:



Agreement for supply of electricity Low Tension

An agreement made this the 21st day of Jan of 2026 between _____ and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution Utility / MePDCL) of the other part.

Note: the term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereinafter appearing;

Now, therefore, the agreement witness –

- (1) That the supply shall be given to the premises located at Sumer Post with the consumer as owner / occupier of;
- (2) That the supply shall be for the purpose of Domestic
The load whereof shall not exceed (1+2) = 3 kw watts
- (3) That the provisions of the EA 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike;
- (4) That the consumer shall regularly and timely pay to MePDCL all charges as may be due for the supply of electricity;
- (5) That the agreement shall be a period of two years and may be renewed for a further period;
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- (6) That the agreement shall be terminated if the consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or, on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

Application form – Load Enhancement / Load Reduction

(Tick the applicable purpose)

Name of the Applicant/Organization:	Bull Warbah
Address of premises to which electricity is being supplied	
Service Connection Number	1000207945 Telephone no.: Mobile: Email 9862447305
In case of Load Enhancement:	
Existing sanctioned load (in kW):	1 Enhanced load requested (in kW): 2
In case of Load Reduction:	
Existing sanctioned load (in kW):	Reduced load requested (in kW):
Reason(s) for Load Enhancement / Reduction: from 1kw to 3kw	
Details of load added/ disconnected from supply, if applicable. (Please attach list of equipments category-wise)	
(a) Lighting (b) Motive Power (c) Agricultural (d) Other (please specify)	

Signature of the consumer
Name: B. Warbah

The following documents are attached with the application form (if applicable) ✓

1. A work completion certificate & test report from licensed Electrical Contractor if the consumer's installation has been altered.

2. Resolution for authorized signatory.