

Application form - Load Enhancement / Load Reduction

3144

(Tick the applicable purpose)

1	Name of the Applicant/Organization:	DRILIN - MARWEIN
2	Address of premises to which electricity is being supplied	UMKTIKH - PDENG,
3	Service Connection Number	Telephone no.: Mobile: Email 9612080215
4	In case of Load Enhancement:	
	Existing sanctioned load (in kW): 1 kW	Enhanced load requested (in kW): 1 kW.
5	In case of Load Reduction:	
	Existing sanctioned load (in kW):	Reduced load requested (in kW):
6	Reason(s) for Load Enhancement / Reduction:	From 1kW TO 2kW
7	Details of load added/ disconnected from supply, if applicable. (Please attach list of equipments category-wise)	
	(a) Lighting	
	(b) Motive Power	
	(c) Agricultural	
	(d) Other (please specify)	

Date: 29-01-2026Place: UmiamSignature of the consumer D. marwein.Name: DRILIN - MARWEIN

Note: The following documents are attached with the application form (if applicable)

1. A work completion certificate & test report from Licensed Electrical Contractor, if the consumer's installation has been altered.
2. Resolution for authorized signatory.

Acknowledgement

Application of for load enhancement load reduction against Service Connection No. is hereby received on (date)

In this regard, the applicant is given a reference no. to be used in all future correspondence.

Signature / Seal of Licensee's representative

Name and Designation:

APPLICATION FORM FOR PROVIDING LT SERVICE CONNECTION
(FOR ALL CATEGORY AND FOR ALL PURPOSE)

To
The Area Manager / Asst Executive Engineer
Service Connection Sub-Division / Distribution Sub-Division
MCDL Umiam
(Indicate the local area of the jurisdiction of the Engineer of the licensee)

- Su,
1. I / We hereby request you to supply electricity to the premises located at the address fully described below. I / We are the owner / lawful occupier of the premises.
 2. I / We agree to abide by the terms and conditions relating to the supply of electricity by MCDL and to make all payments as may be required and also to pay regularly all the charges as may become due.
 3. a) Full name and address of the applicant with contact telephone number

DRILIN - MARWEIN
UMKTIEH - PDEANG. mobile-no - 9612080215

b) Status in relation to the premises
Owner
Occupier

c) Location and address of the premises including Police Station

d) Nature of LT Supply
Commercial Domestic
Industrial General Purpose
WSLT PL
Agriculture KJ

Load Enhancement from 1KW To
KW ie 1KW Load Sanction from
Umktieh Pdeang 63 KVA DL

Date Blah
Assistant Executive Engineer
Jeniam Rural Distribution Sub-Division
MCDL Umiam

D. marwein.
Applicant's Signature

NB The following documents are to be enclosed:-

- 1) Test Report from Licensed contractor.
- 2) Agreement Form duly filled in.
- 3) Proof of ownership (in case the applicant is owner)
- 4) Number of the nearest Electric Pole.
- 5) NOC of the owner of the premises (in case the applicant is occupier).
- 6) Attested copy of permission obtained from Pollution Control Board.
- 7) Building permission from the concerned authority.

A. Charbuchi
15 mtr. Distance.
63 KVA.



Annexure - 3

Agreement for supply of electricity Low Tension

An agreement made this the 27 day of Jan of 2026 between D. Manu and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution Utility / MESPDC) of the other part

Note: The term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereinafter appearing;

Now, therefore, the agreement witness –

- (1) That the supply shall be given to the premises located at Umktich Poleng with the consumer as owner / occupier of;
- (2) That the supply shall be for the purpose of D.L.T
The load whereof shall not exceed 2KW watts
- (3) That the provisions of the EA 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike,
- (4) That the consumer shall regularly and timely pay to MePDCL all charges as may be due for the supply of electricity,
- (5) That the agreement shall be a period of two years and may be renewed for a further period;
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- (6) That the agreement shall be terminated if he consumer on its part desires it so and give to the MePDCL a prior notice of not less than one month or, on the part of the MePDCL if the consumer has violated any of the terms and conditions of the agreement.

SR/Scheduled Form 7

Meghalaya Power Distribution Corporation Limited
Test Report

This is to certify that repaired/renewed/additional/new electric installation at the premises of

Full name

S M T D R I L I N M A R G I N

(Please leave one block between name & surname)

Address

K I N I K T I C H

The load has been arranged as follows:

Details of load	Wattage of each item	Phase I		Phase II		Phase III		Total wattage of all 3 phases
		No. of points	Total wattage	No. of points	Total wattage	No. of points	Total wattage	
1. Light points								
(i) Fluorescent								
(ii) Incandescent								
<input checked="" type="checkbox"/> GFL LED	9W	15 Nos	135W					
(iv) Halogen								
(v) Others								
2. Fan points								
<input checked="" type="checkbox"/> Plug points (3 Pin)	100W	8 Nos	800W					
(i) 6 Amps								
<input checked="" type="checkbox"/> 16 Amps	1800W	1 No	1800W					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) AC								
(iv) Others								
5. Welding transformer								
6. Motor								
Total								
In case of load enhancement existing load (in watts)								
Total load in the premises (in watts)			1935W					

Notes:

Details of any apparatus (other than the above mentioned) should be given.

Rating of capacitor used in Induction Motor and welding

transformer (Test report of capacitor is to be enclosed)

2kw

KYAR

II. Type of wiring *Coping System*
 III. Voltage and system of supply *230V*
 IV. Test Result *O.K*
 Date of testing by licensed contractor

27012025

Type of test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant Cea regulations, (in MΩ) / Ω
(a) Insulation resistance between earth and whole system of conductor.	100 mΩ	
(b) Insulation resistance between all conductors	120 mΩ	
(c) Earth continuity between earth electrode and earth continuity conductor	3 Ω	
(d) Polarity of non-linked SP switches	PH - 220V RN - 0V	

Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.

Full name with signature of supervisor (with date)

LIC No.

Mobile No.

Full name with signature of wireman (with date)

LIC No.

Mobile No.

Signature of the authorized official who tested the installation on behalf of supplier (with date)

Mobile No.

Date of connection of supply to the installation

K. Nengneng
 K. Nengneng
 Govt. Regd. Electrical Contractor
 LIC No. - 1560
 Umroi, N. Lha District
 Meahlaava - 793103

F. Mahim
 F. Mahim
 Electrical Supervisor
 LIC - No. 1187

F. Mahim
 F. Mahim
 Wireman
 LIC - No. 8405

