



MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
UMIAM DISTRIBUTION SUB-DIVISION, UMIAM

No. MePDCL/UDSDT-2/2023-24/

"Save Energy for Benefit of Self and Nation"

To,

The Lineman, In-charge
Village: Myeshing

Sub:- Reconnection After Disconnection Drive.

Dated Umiam the

31/6/23

Kindly R/C the meter of the consumer mentioned below at the earliest for necessary action from this end.

Consumer Name : Doan's Rynthathiang

Category : BP(H) 1000215220

Meter Number

NA 1Kas

Date of Reconnection :

Signature of L/M :

[Signature] 31/6/23

[Signature]
Assistant Executive Engineer
Umiam Distribution Sub-Division

SECURE

ROUTINE TEST REPORT

Serial Number: SS17948196 Customer: M/S MAMTA ELECTRICALS
Customer P.O Number: MAMTA/23-24/017
Customer P.O Date: 16-DEC-2024
Voltage: 240V Current: 05-30A Accuracy Class: 1.0
Ref. Standard: IS : 13779

Meter Constant: 6400

1. AC VOLTAGE TEST: **PASS**
2. TEST OF NO LOAD CONDITION: **PASS**
3. TEST OF STARTING CURRENT: **PASS**
4. INSULATION TEST: **PASS**
5. METER ACCURACY:-

Reference Conditions: $V_{ref} = 240V/50Hz$ $I_b = 05-30A$ Amb. Temp = 27 ± 2 Deg. C

METER ACCURACY

% Active Import Errors

Load % I_b	0.5 Lag	0.8 Lead	UPF
600	0.4	0.0	0.0
100	0.2	0.0	0.0
10	0.2	0.0	0.0
5			0.0

00001.0

Date of in stallment
8/6/25
[Signature]
= 16/25

TEST DATE: 06/03/2025

This is computer generated test report no signature required

[Signature]
Meter Tester Gr - 1
MTI Laboratory
MePDCL, Lumjingshai
Shillong

[Signature]
Executive Engineer
MTI Division
MePDCL, Shillong