

Application form – Load Enhancement / Load Reduction

(Tick the applicable purpose)

1	Name of the Applicant/Organization:	ROSE MARY KHARBYNGAR
2	Address of premises to which electricity is being supplied	SUMERUMBANG
3	Service Connection Number	1000843208 Telephone no.: Mobile: Email 6909544813
4	In case of Load Enhancement:	
	Existing sanctioned load (in kW):	2kw- Enhanced load requested (in kW): 4kw
5	In case of Load Reduction:	
	Existing sanctioned load (in kW):	Reduced load requested (in kW):
6	Reason(s) for Load Enhancement / Reduction:	from 2kw to 6 kws
7	Details of load added/ disconnected from supply, if applicable. (Please attach list of equipments category-wise)	
	(a)	Lighting
	(b)	Motive Power
	(c)	Agricultural
	(d)	Other (please specify)

R. Syngar

Signature of the consumer

Name: ROSE MARY KHARBYNGAR

Date: _____

Place: _____

Note: The following documents are attached with the application form (if applicable)

✓ A work completion certificate & test report from Licensed Electrical Contractor, if the consumer's installation has been altered.

2. Resolution for authorized signatory.

Acknowledgement

Application offor load enhancement load reduction against Service Connection No..... is hereby received on (date)

In this regard, the applicant is given a reference no. to be used in all future correspondence.

Signature / Seal of Licensee's representative

Name and Designation:

K. J. Agilva Jorpa
[Signature]

ution Corporation Limited

COLLECTION

MIAM SUBDIVISION

ipt No. : 223202240912051
Consumer ID : 1000843207
Payment Mode : CASH
Payment Type : BILL
Date and Time : 25-02-2026 11:59:16
Consumer Name : Rose Mary Kharbyngar-SUMER UM
BANG - 1000843207
Paid Amount : Rs.5560.0/-
(Five Thousand Five Hundred Sixty Rupees Only.)
Secret Key : LC3A
Drawn BY : PRETTY M.UMLONG-CASHIER(SUB DIV)

Verify the Consumer ID and Amount

Thank you for using i~EasyBill

Account Details
Sub-Division
Consumer Id
MR Code
Consumer Name
Address
Category
C.Demand/Load
Meter No.
OMF(Cons)
VAN No.

UMIAM SUBDIVISION
1000843207
2232001
Rose Mary Kharbyngar
SUMER UMBANG
CLT
2KW
5762846
1
MEPDCL1000843207

Billing Details

Prev. Reading Date 20/01/2026
Curr. Reading Date **17/02/2026**
No. of Days 28
Bill Number 2232001262170653
Bill Status OK(Normal)
Prev KWH 6280.9
Current KWH 6608.4
Billed Unit 327.5
Recorded MD 0
Power Factor 0
Average 0

Bill Charges

Fixed Charges (Unit, Rate, Amount)		
2.0 KW	170.0	307.10
Energy Charges (Unit, Rate, Amount)		
327.5	7.5	2456.25
ED Amount (Unit, Rate, Amount)		
327.5	0.06	19.65
FPPAS		304.61
(DEC 25 TO DEC 25 : 304.610)		
DPC		24.30
Current Bill Amt		3111.91
Prev Outstanding		2447.40
Adjustment		0.00
Gross Bill Amount		5559.31

Net Bill Amount **₹ 5560.00**
Due Date **25/02/2026**
Last Payment Date 20/12/2025
Last Payment Amount 1996

17/02/2026 11:41 V4.7

This bill will be construed as final notice under Section 9.2 of MSERC (Electricity Supply Code) Regulations, 2018 Supply of electricity shall be disconnected at any date, if dues of Electricity bill is not paid within 15 (fifteen) days (notice period) after due date of the bill. Thanks for paying. We really appreciate it!



For Bill Payments, Please visit www.meghapower.com OR
Download Megha Power App from Google Playstore



भारत निर्वाचन आयोग
ELECTION COMMISSION OF INDIA
मतदाता फोटो पहचान पत्र - ELECTOR PHOTO IDENTITY CARD

DHJ0544916

Name: ROSE MARY
KHARBYNGAR

Father's Name: ARIAN NONGBRI

EPIC

SEX : Female
DATE OF BIRTH/AGE : 02/01/1987
ADDRESS:
HNo.9, UMBANG (ADA),
VILL-UMBANG (ADA),
DIST-RI-BHOI-793103

Handwritten signature

Date:26-7-2016 Electoral Registration Officer
Assembly Constituency No & Name:
11 - UMSNING
Part No and Name:
36 - SUMER

नोट / Note

1. इस कार्ड को धारण करने पर से यह कोई गारंटी नहीं है कि इस सदस्य निर्वाचक नामावली में शामिल है। कृपया अपने नाम प्रत्येक चुनाव से पहले निर्वाचक नामावली में जांच लें।
2. इस कार्ड में उल्लिखित जन्मदिनांक को निर्वाचक नामावली में परिवर्तन के अलावा अन्य किसी भी स्थिति में जाय के प्रमाण के रूप में नहीं माना जाएगा।
Date of Birth mentioned in this card shall not be treated as a proof of age/D.O.B for any purpose other than registration in electoral roll.

APPLICATION FORM FOR PROVIDING LT SERVICE CONNECTION
(FOR ALL CATEGORY AND FOR ALL PURPOSE)

200 KVA
201 M.T
R.R.

To,

The Area Manager Asstt. Executive Engineer
Service Connection Sub-Division Umiam Distribution Sub-Division
Me. SEB Umiam

(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

- 1) We hereby request you to supply electricity to the premises located at the address more fully described below. We are the owner lawful occupier of the premises
- 2) We agree to abide by the terms and conditions relating to the supply of electricity by Me. SEB and to make all payments as may be required and also to pay regularly all charges as may become due

a) Full name and address of the applicant with contact telephone number

b) Status in relation to the premises

Owner

Occupier

c) Location and address of the premises including Police Station

d) Nature of LT supply

Commercial

Domestics

Industrial

General Purpose

WSLT

PL

Agriculture

KJ

Load enhancement
from: 2KW to 6KW;
umbang 200 KVA
(LT)

[Signature]
Junior Engineer (EL)
Dist. Sub-Division
Umiam

Date

[Signature]
Applicant's Signature

NB The following documents are to be enclosed

- 1) Test Report from Licensed contractor
- 2) Agreement Form duly filled in
- 3) Proof of ownership (in case applicant is owner)
- 4) Number of nearest Electric Pole
- 5) NOC of the owner of the premises (in case the application is an occupier)
- 6) Attested copy of permission obtained from Pollution Control Board
- 7) Building permission from the concerned authority

AGREEMENT FOR SUPPLY OF ELECTRICITY
LOW TENSION.

AN AGREEMENT made this the 2nd day of March 2026
between: Rose Moly Kharbangar and his successors and assigns
(hereinafter referred to as the Consumer) of the One Part and the Meghalaya State Electricity Board
and electricity distribution licensee under the Electricity Act, 2003 and its successors and assigns
(hereinafter referred to as the Board) of the Other Part.

Note The term "consumer" includes and individual person (whether male or female), a body of persons, a company, society, firm, association or organization.

WHEREAS, the consumer has applied to the Board for supply of electricity to its premises and the Board has agreed to give the supply under the terms and conditions hereinafter appearing:

NOW, THEREFORE, the agreement witnesses-

- 1) That the supply shall be given to the premises located at Seemur Umbang with the consumer as owner-occupier of.
- 2) That the supply shall be for the purpose of CLT, the load whereof shall not exceed 2 (Frishty) + 4kw (Enhancement) = 6kw watt(s).
- 3) That the provisions of the Electricity Act, 2003 and the Regulations, Code and Orders, including Tariff Orders, as may be made from time to time by the Meghalaya State Electricity Regulatory Commission shall apply and bind the consumer and the Board alike.
- 4) That the consumer shall regularly and timely pay to the Board all charges and may be due for the supply of electricity.
- 5) That the Agreement shall be for a period of two years and may be renewed for a further period Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed.
- 6) That the Agreement shall be terminated if the consumer on its part desires it so and give to the Board a prior notice of not less than one month or, on the part of the Board, if the consumer has violated any of the terms and conditions of the agreement.



Provided that on the part of the Board notice shall be given to the consumer stating reasons for the proposed termination and giving him opportunity to state his case and statement, if any, duly considered before the agreement is terminated and the supply of electricity cut off.

7) That the terms and conditions of this Agreement shall be effective from the date supply of electricity commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

[Handwritten Signature]
The Consumer

()
For and on behalf of the Board

Witnesses

1. Signature

Name

Address

1. Signature

Name

Address

Total increase of load (in watts)	5024 wtt			
Existing load (in watts)	804 kw			
Total load in the premises (in watts)				

Notes -

- (a) Details of any apparatus (other than the above mentioned) should be given.
- (b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed) KVAR

II. Type of wiring *Wastey system*

III. Voltage and system of supply. *440vlt*

IV. Test Result: *OK.*

Date of Testing by Licensed Contractor

Type of Test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant IE Rules, (in MΩ) / Ω
a. Insulation resistance between earth and whole system of conductor	<i>47Ω, 47Ω, 47Ω</i>	
b. Insulation resistance between all conductors.	<i>46Ω, 46Ω, 46Ω</i>	
c. Earth continuity between earth electrode and earth continuity conductor.	<i>OK</i>	
d. Polarity of non-linked SP switches		

V. Full Name with signature of Licensed contractor (with date) LIC No :

[Signature]
S. Langstieh
Electrical Contractor
Regd. No : 652

VI. Full Name with signature of supervisor (with date) LIC No :

[Signature]
S. Songthiang
Electrical Supervisor
Govt. Regd - 1097

VII. Full Name with signature of wireman (with date) PERMIT No. :

VIII. Signature of the authorized official who tested the installation of behalf of supplier (with date) :

[Signature]
W. Rynthiang
Electrical Wireman
Regd. No. 4770

IX. Date of connection of supply to the installation :

Serial Number: SS22164631

Customer: M/S MAMTA ELECTRICALS

Customer P.O Number: MAMTA/25-28/03

Customer P.O Date: 11-JUL-2025

Voltage: 240V

Current: 10-100A

Accuracy Class: 1.0

Ref. Standard: IS : 13779

Meter Constant: 1600

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz Ib = 10-100A Amb. Temp = 27 +/- 2 Deg. C

METER ACCURACY

% Active Errors [Import]

Load % Ib	0.5 Lag	0.8 Lead	UPF
1000	-0.2	-0.1	-0.1
100	-0.1	0.0	0.0
10	0.1	0.1	0.1
5			0.1

% Reactive Errors [Import]

Load % Ib	0.5 Lag	0.8 Lead
1000	-0.1	-0.1
100	0.0	0.0
10	0.1	0.1

0000004.0

Mur
Meter Tester Gr. 1
MTI Laboratory
MePDCL, Lumjingshal
Shillong

[Signature]
Executive Engineer
MTI Division
MePDCL Shillong

TEST DATE: 13-11-2025