

Meghalaya Energy Power Distribution Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

SMT CAROLYN NE NONGRUM

(Please leave one block between name & surname)

(Full Name)

TYNRING

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1 The load has been arranged as follows :-

Details of Load	Wattage of each item							Total watt of all 3 phases
		No. of points	Total Watt	No. of points	Total Watt	No. of points	Total Watt	
1 Light points (i) Fluorescent (ii) Incandescent <input checked="" type="checkbox"/> (iii) CFL (iv) Halogen (v) Others	9w	20	180					
2 <input checked="" type="checkbox"/> Fan points	60w	2	120					
3 Plug points (3-pin) <input checked="" type="checkbox"/> (i) 5 Amps <input checked="" type="checkbox"/> (ii) 15 Amps	100w 1000w	6 2	600 2000					
4 Electrical gadgets (i) Water Heater <input checked="" type="checkbox"/> (Geysar) (ii) Refrigerator (iii) Air Conditioner (iv) Others	1000w	1	1000					
5. Welding Transformer								
6 Motor								
Total			3900					
In case of load enhancement Existing load (in watts)			1000					
Total load in premises (in watts)			4900w	Say	5kws			

Notes -

- (a) Details of any apparatus (other than the above mentioned) should be given
- (b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor

KVAR