

Meghalaya Energy Power Distribution Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

RIBELDA HONGRUM

(Please leave one block between name & surname)

(Full Name)

TIYNRIMG

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1 The load has been arranged as follows :-

Details of Load	Wattage of each item							Total watt of all 3 phases
		No. of points	Total Watt	No. of points	Total Watt	No. of points	Total Watt	
1 Light points (i) Fluorescent (ii) Incandescent (iii) CFL (iv) Halogen (v) Others	9W	10	90					
2 Fan points								
3 Plug points (3-pin) (i) 6 Amps (ii) 16 Amps	100 1000	4 2	400 2000					
4 Electrical gadgets (i) Water Heater (Geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Others								
5. Welding Transformer								
6 Motor								
Total			2490 kw					
In case of load enhancement Existing load (in watts)								
Total load in premises (in watts)			2490 kw					

Notes -

- (a) Details of any apparatus (other than the above mentioned) should be given
- (b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor

KVAR