

II. Type of wiring

Looping in system

III. Voltage and system of supply

220V - 240V

IV. Test Result:

Date of Testing by Licensed Contractor:

11/2/09/25

Type of Test	Result of test carried out by licensed contractor (In M Ω) / Ω	Result of test carried out by Supplier under relevant IE Rules, in (M Ω) / Ω
a. Insulation resistance between earth and whole system of conductor.	40 M Ω	
b. Insulation resistance between all conductors.	40 M Ω	
c. Earth continuity between earth electrode and earth continuity conductor.	1 Ω	
d. Polarity of non-linked SP switches.	Phase	

V. Full Name with signature of Licensed contractor :

I. Marngar

LIC No. :

Electrical Contractor

L.C. No: 1702

VI. Full Name with signature of supervisor
(with date) :

I. Marngar

Electrical Supervisor

LIC No. :

L.C. No: 1797

VII. Full Name with signature of wireman
(with date) :

S. Dkhar

S. Dkhar

Wireman

L.C. No: 11965

PERMIT No. :

VIII. Signature of the authorized official who tested
The installation of behalf of supplier. :

IX. Date of connection of supply to the installation :

X. Date of termination :

Malaya Energy Power Distribution Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

KIEWTIO RIMAI SYLEH CIEH

(Please leave one block between name & surname)

(Full Name)

DUBANG SUMER

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	No. of points	Total Watt	No. of points	Total Watt	No. of points	Total Watt	Total watt of all 3 phases
1. Light points	80W	4	240					
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL LED	9W	10	90W					
(iv) Halogen								
(v) Others								
2. Fan points								
3. Plug points (3-pin)								
(i) 6 Amps	100W	6	600W					
(ii) 16 Amps	1000W	3	3000W					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) Air Conditioner								
(iv) Others								
5. Welding Transformer								
6. Motor								
Total			3930W					
In case of load enhancement Existing load (in watts)			2kw					
Total load in premises (in watts)			7930W					

Notes :-

- Details of any apparatus (other than the above mentioned) should be given.
- Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed).



KVAR

Provided that on the part of the MeECL notice shall be given to the consumer stating reasons for the proposed termination and giving him opportunity to state his case and his statement, if any, duly considered before the agreement is terminated and the supply of electricity cut off.

7. That the terms and conditions of this Agreement shall be effective from the date supply of electricity is commenced

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

(*Shi*)

The Consumer

()

For and on behalf of the MeECL

Witnesses :-

1. Signature : *Pl*

Name : *St Paul, C. Savina*


Address :

1. Signature :

Name :

Address :

**AGREEMENT FOR SUPPLY OF ELECTRICITY
LOW TENSION**



AN AGREEMENT made this the 12th day of September 2025 between Kiew Jirimai Syemlieh and his successors and assigns (hereinafter referred to as the Consumer) of the One Part and the Meghalaya Energy Corporation Ltd. an electricity distribution licensee under the Electricity Act, 2003 and its successors and assigns (hereinafter referred to as MeECL) of the Other Part.

Note: The term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

WHEREAS, the consumer has applied to the MeECL for supply of electricity to its premises and the MeECL has agreed to give the supply under the terms and conditions hereinafter appearing.

NOW, THEREFORE, the agreement witnesses -

1. That the supply shall be given to the premises located at Umbang with the consumer as owner/occupier of.
2. That the supply shall be for the purpose of C.L.T the load whereof shall not exceed 3+3 = 6 KW 2+6 = 8 KW watt(s).
3. That the provisions of the Electricity Act, 2003 and the Regulations, Code and Orders, including Tariff Orders, as may be made from time to time by the Meghalaya State Electricity Regulatory Commission shall apply and bind the consumer and the MeECL alike.
4. That the consumer shall regularly and timely pay to the MeECL all charges and may be due for the supply of electricity.
5. That the Agreement shall be a period of two years and may be renewed for a further period: Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed.
6. That the Agreement shall be terminated if the consumer on its part desires it so and gives to the MeECL a prior notice of not less than one month or, on the part of the MeECL, if the consumer has violated any of the terms and conditions of the agreement.

Transformer:- 25 kVA
Distance:- 30 mtr
Sig of Am:- Oshabo.

Annexure - 1

Meghalaya Power Distribution Corporation Limited
Application form for providing LT Service Connection
(for all categories and for all purposes)

To

The Area Manager / Asst. Executive Engineer
Service Connection Sub-Division / _____ Distribution Sub-Division
Meghalaya Power Distribution Corporation Limited

(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

I / We hereby request you to supply electricity to the premises located at the address fully described below:

I / We agree to abide by the terms and conditions relating to the supply of electricity by MePDCL and to make all payments as may be required and also to pay regularly all the charges as may become due.

(a) Full name and address of the applicant with contact telephone number, Mobile Number,
E-Mail SUN KIEWTORINAI SYENKISH.

(b) Status in relation to the premises

Owner ☒ Occupier ☐

(c) Location and address of the premises including Police Station

Umbar, Sumer, Umbar Police station.

(d) Nature of LT supply

Commercial	<input checked="" type="checkbox"/>	Domestic	<input type="checkbox"/>
Industrial	<input type="checkbox"/>	General purpose	<input type="checkbox"/>
WSLT	<input type="checkbox"/>	Public lighting	<input type="checkbox"/>
Agriculture	<input type="checkbox"/>	KJ	<input type="checkbox"/>
		MeECL employee	<input type="checkbox"/>

load of 8 Kw is
sanctioned from 25 kVA
Xⁿ at Umbar Sumer.
DATE: 29/09/2025

Ashu

Syenkish
Applicant's Signature

Transformer:- 25 kVA
Distance:- 30 mtr
Sig of Am:- Oshabo.

Annexure - 1

Meghalaya Power Distribution Corporation Limited
Application form for providing LT Service Connection
(for all categories and for all purposes)

To

The Area Manager / Asst. Executive Engineer
Service Connection Sub-Division / _____ Distribution Sub-Division
Meghalaya Power Distribution Corporation Limited

(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

I / We hereby request you to supply electricity to the premises located at the address fully described below:

I / We agree to abide by the terms and conditions relating to the supply of electricity by MePDCL and to make all payments as may be required and also to pay regularly all the charges as may become due.

(a) Full name and address of the applicant with contact telephone number, Mobile Number,
E-Mail SUN KIEWTORINAI SYENKISH.

(b) Status in relation to the premises

Owner ☒ Occupier ☐

(c) Location and address of the premises including Police Station

Umbar, Sumer, Umbar Police station.

(d) Nature of LT supply

Commercial	<input checked="" type="checkbox"/>	Domestic	<input type="checkbox"/>
Industrial	<input type="checkbox"/>	General purpose	<input type="checkbox"/>
WSLT	<input type="checkbox"/>	Public lighting	<input type="checkbox"/>
Agriculture	<input type="checkbox"/>	KJ	<input type="checkbox"/>
		MeECL employee	<input type="checkbox"/>

load of 8 Kw is
sanctioned from 25 kVA
Xⁿ at Umbar Sumer.
DATE: 29/09/2025

Ashu

Syenkish
Applicant's Signature

Megha Power Distribution Corporation Limited
 11, B. P. S. Road, Guwahati, Assam, India

Account No. 1000207841
 Consumer Name Umbarga Umbarga
 Address #3130115700
 Category DT
 C. Demand Load 2KW
 Meter No. 5517270380
 OMR (Cons) 1
 Total Tariff Diff 907.10

Billing Details
 Prev. Reading Date 11/07/2025
 Curr. Reading Date 14/08/2025
 No. of Days 34
 Prev. Reading 223200.254140475
 Bill Status OK (Normal)
 Prev. KWH 1497.0
 Current KWH 1575.9
 Billed Unit 78.9
 Recorded MD 0
 Power Factor 0
 Average

Bill Charges
 Fixed Charges (Unit, Rate, Amount)
 2.0 KW 90.0 197.42
 Energy Charges (Unit, Rate, Amount)
 78.9 5.0 394.50
 ED Amount (Unit, Rate, Amount)
 78.9 0.05 3.95
 FPPAS -2.94
 (JUN 25 TO JUN 25) -2.94
 Current Bill Amt 592.95
 Consumer Credit -0.15
 Adjustment 0.00
 Tariff Diff (D. Inst.) 100.79
 Gross Bill Amount 693.52

Net Bill Amount ₹ 694.00
 Due Date 27/08/2025
 Last Payment Date 17/07/2025
 Last Payment Amount 251

14/08/2025 11:26 V1.4
 This bill will be considered as final notice under Section 9.2 of
 MSERC (Electricity Supply) Regulations, 2018. Supply
 will be discontinued if the bill is not paid within 15 (fifteen) days (notice
 period) after due date of the bill. Thanks for paying. We really
 appreciate it!



For Bill Payments, Please visit www.meghpower.com OR
 Download Megha Power App from Google Playstore

The current bill has been issued with a new tariff difference amount
 as per the MSERC approved Distribution Tariff for
 2024-25. To be collected in nine equal installments. For
 any queries, please contact the AEFs of the respective
 sub-divisions.

DORBAR SHNONG SUMER UMBANG MYLLIEM SYIEMSHIP

Raid Mawbuh
Ri-Bhoi District

Ref. No. Nil

Date. 15 / Jan 2025

NO OBJECTION CERTIFICATE

This is to certify that the Dorbar Shnong Sumer Umbang has no objection to Smti. Fidelia K. Lyngkhoi Resident of Mawlai Kynton Massar Block 'C' daughter of Shri.Lamboklang Kharpuri for setting up the Home Stay at Sumer Umbang Village, Ri-Bhoi District In the Land of Smti. Kiewtiorimai Syiemlieh located at Sumer Umbang, Ri, Bhoi District, subject to adherence to the Rules and conditions as laid down by the Dorbar shnong Authority.

We wish her successful in this venture.


(Shri. Arkini Sumer)

Headman
Sumer Umbang Village
Ri-Bhoi District


(Shri. L.S. Thabah)

Secretary
Sumer Umbang Village
Ri-Bhoi District

SEX

: Female

DATE OF BIRTH/AGE : 10/07/1958

ADDRESS:

HNo.207, NONGMALI - I,
VILL MAWLAI,
DIST-EAST KHASI HILLS-793008



Date: 16-2-2018 Electoral Registration Officer

Assembly Constituency No & Name :

16 - MAWLAI

Part No and Name :

16 - MAWLAI MAWDATBAKI C

Note / Note :

1. इस कार्ड को धारण करने मात्र से यह कोई गारंटी नहीं है कि आप वर्तमान
विधान सभा में निर्वाचक हैं। कृपया अपने नाम प्रत्येक चुनाव से पहले
वर्तमान विधान सभा में जांच लें।

2. Mere possession of this card is no guarantee that you
are elector of the current electoral roll. Please check your
name in the current electoral roll before every election.


3. इस कार्ड में उल्लिखित जानकारी को निर्वाचक सभासदों में प्रमाण के रूप में नहीं माना जाएगा।
Date of Birth mentioned in this card shall not be treated
as a proof of age/D.O.B. for any purpose other than
registration in electoral roll.



भारत निर्वाचन आयोग
ELECTION COMMISSION OF INDIA



मतदाता फोटो पहचान कार्ड - ELECTION PHOTO IDENTITY CARD



MTL0644724



Name : KIEN THORMAI
SYIEN LIEN

Husband's: S. WARJRI

Name

Annexure - 11 (1483)

Application form – Load Enhancement / Load Reduction

(Tick the applicable purpose)

1	Name of the Applicant/Organization:	KIEWTORIMAI SYZMCHET.
2	Address of premises to which electricity is being supplied	Sumar, Vn Long.
3	Service Connection Number 1000 207841	Telephone no.: Mobile: Email 9802055820
4	In case of Load Enhancement: Existing sanctioned load (in kW): 2 kW	Enhanced load requested (in kW): 6 kW
5	In case of Load Reduction: Existing sanctioned load (in kW):	Reduced load requested (in kW):
6	Reason(s) for Load Enhancement / Reduction:	
7	Details of load added/ disconnected from supply, if applicable. (Please attach list of equipments category-wise) (a) Lighting (b) Motive Power (c) Agricultural (d) Other (please specify)	

Date: _____

Place: _____

Signature of the consumer

Name: KIEWTORIMAI SYZMCHET.

Note: The following documents are attached with the application form (if applicable)

1. A work completion certificate & test report from Licensed Electrical Contractor, if the consumer's installation has been altered.

2. Resolution for authorized signatory.